

PARARI POWER PRIVATE LIMITED

H. No. 99, Ward No. 8, Dhalpur, Kullu - 175101

Email : gangananna@gmail.com

PH. 01902 222120

Ref No.PPL/DFO/FCA/2025-26/26

date-23/08/25

The Divisional Forest Officer,
Kullu ,Forest Division,
Kullu,Distt.Kullu(H.P.).

Sub: Diversion of 0.4476 ha.(Instead 0.5959 ha.) of forest land in favour of M/s Pharari Power Pvt. Ltd., House No. 99, Ward No. 8 Dhalpur, H.P. for the construction of Pharari SHEP 2.00 MW, within the jurisdiction of Kullu Forest Division, Distt. Kullu, H.P (Online no. FP/HP/HYD/41259/2020)

Ref. HP Forest Department Kullu Forest Circle Kullu, Letter No. DIV569-377 Dated 25-04-23

Respected Sir,

Kindly refer EDS raised by your office on dated 07/08/2025 on the above cited subject, the reply has been submitted as under.

Sr. No.	Observation	Reply
1	The observation of point no. 2 has not been attended completely. The component wise area in part-1ParaB 2.4 is required to be mentioned separately.	In this regard, the component-wise area under Part-1, Para B 2.4 has been indicated separately, and the details relating to Road, Bridge, and U/G Transmission have been uploaded on the portal At Sr.No.36
2	In reply of Point no 3, it has been mentioned that necessary correction has been made but from the perusal of Part-II of Parivesh Portal the Observation is still unattended.	This point is pertaining to your good office please.
3	In reply to point No. 11, the approved copy of HPPTCL regarding power evacuation plan is required to be submitted.	In this context, the Power Evacuation Plan for the Pharari Small Hydro Electric Project(SHEP)entails the laying of a 33 kV underground transmission cable in joint mode with the Hamshu-1 SHEP, extending up to the 33/220 kV Phojal Substation of HPPTCL. The approved copy has been uploaded on the portal at Sr. No. 37 under the title 'Power Evacuation Approval Letter and Plan.

Yours Truly

for Parari Power Pvt. Ltd.

N.Ganapadhar Rao
Director



PARARI POWER PRIVATE LIMITED

H. No. 99, Ward No. 8, Dhalpur, Kullu - 175101
Email : gangananna@gmail.com
PH. 01902 222120

Date -23/8/25
Place- Kullu

Statement Showing Details Regarding Road in Pharari SHEP(2.00 MW)in Tehsil & Distt. Kullu, Patlikuhal Forest Range, Kullu Forest Division, Distt. Kullu (H.P.)

Road, Bridge Cum U/G Transmission line and MD-1

Sr.No.	Muhal/Fathi	Khasra No.	Length in Meter	Width in Meter	Area in Ha.	Component
1	Runga-2	132/2	20	4	0.008	MD-1,Road&U/G Transmission Line
2	Muhal Meha/Kothi Baragarh	8081/	12	4	0.0048	Road cum U/G Transmission Line
		841/1	40	4	0.016	Bridge Cum U/G Transmission Line
	Total Area in Ha.				0.0288	

for Parari Power Pvt. Ltd.

N. G. Gaddha Rao
Director





H.P. Power Transmission Corporation Limited
(A State Govt. Undertaking)
Himfed Bhawan, Panjari, Below Old MLA Quarters,
Shimla-171005

NO. HPPTCL/Interconnection-Vol-VII/2017- 10149-50

Dated:- 15/12/17

To

Chief Engineer (Energy),
Directorate of Energy, GoHP,
Shanti Bhawan, Phase-III, Sector-VI,
New Shimla-171009.

Subject: - Evacuation arrangement for Pharari (2 MW) HEP

Sir:

Approved evacuation arrangement for Pharari HEP envisages construction of 33 kV S/C line in joint mode with Hamsu-I HEP to 33/220 kV Phojal substation of HPPTCL.. IPP vide his letter dated 12.12.2017 (copy enclosed) has requested to evacuate power of Pharari HEP by laying 33 kV underground cable instead of overhead line. IPP's proposal to evacuate power by laying 33 kV underground cable is technically in order and accordingly TEC of the Pharari HEP may be amended by replacing the word "33 kV line" by "33 kV line/underground cable" please.

Yours faithfully,

Dy. General Manager (Planning)

Copy to M/S Alvasa Power (India) Ltd, Vashisht Bhawan, Village Rabon, P.O. Saproon,
Distt. Solan-173211 w.r.t his letter under reference.

Dy. General Manager (Planning)

