

Regd.

HIMURJA
(H.P. GOVT. ENERGY DEVELOPMENT AGENCY)
SHIMLA - 171 009.

No. HIMURJA/SHP-2016 - 64610

Dated 22-07-2017

To

M/s Baldev Singh S/o Diwan Chand,
VPO, Sahaura, Tehsil & Distt. Kangra (HP)

Subject: - Consent for exclusive time bound right for preparation of Project Report for the Small
Hydel Project Lower Iqu-I (1.00MW) in Kangra District, Himachal Pradesh -
Submission of feasibility report of (1.00MW) capacity

Dear Sir,

This is in reference to your letter No.Himurja/SHP/Lower IQU-I(109)17/TEC-021 dated 17.03.2017 vide which Feasibility Report in respect of Lower Iqu-I SHEP in District Kangra has been submitted to Himurja. After examining the Feasibility Report, the parameters are frozen as under:

Sr. No	Name of Project	River/ Stream	District	Elevation Range (Diversion to Tail race)	Capacity	Tentative Land Required
						Forest/ Private Land
1	Lower Iqu-I	Iku Khad	Kangra	EL:±1155m to ±1090m	1.00MW	3-45-96 Hac

It is further stated that the approval of the Feasibility Report (FR) of Lower Iqu-I SHEP in District Kangra shall be subject to the following conditions -

1. There shall be no change in the elevations from the elevation frozen in the FR.
2. Discharge data has to be observed for optimization of capacity in the DPR, if it varies from the figure of Feasibility Report. Technical Concurrence is required to be obtained from DOE.
3. Evacuation point has to be got finalized from HPSEBL/HPPTCL. However the land for transmission has been included in the Land requirement.
4. As per laid down guidelines riparian distance of 50 mtrs elevation wise or 250m horizontal distance is to be maintained between upstream and downstream projects to allow visible flow of water in the stream/Nalla while carrying out detailed survey/studies, but it is not demonstrated in the FR. The same should be followed strictly, failing which the allotment is liable to be cancelled for violation of the same.
5. Elevations of each component must be marked in the Contour plan and should also be included in the salient feature after carrying proper survey. Copy of which is also to be forwarded to Himurja.

Therefore, you may go ahead for obtaining various clearances/NOC's on the basis of parameters frozen herein above.

Yours Sincerely,

(Er K. L. Thakur)
Director
Himurja, Shimla-171009