



LAYOUT PLAN
SCALE:-1:200

TOTAL PLOT AREA-1225 SQ. M.(1465.08 SQ. YARD)




CROSS SECTION AT 'A-A'




LONGITUDINAL SECTION 20KL TANK

TYPICAL SECTION OF U/G TANK


SECTION OF DRAIN AS PER IRC SP-13 TYPE-A




BUILDING PLAN




FRONT ELEVATION



CANOPY SECTION



X-SECTION OF B.M. BOUNDARY WALL



X-SECTION OF KERB WALL

PUMP SCHEDULE :-

PRODUCT	NO. OF PUMP	NO. OF NOZZLE
MS	1	4
HSD	2	4


TANK SCHEDULE :-

TANK NO.	PRODUCT	CAPACITY
1	MS	20KL
2	HSD	20KL
3	HSD	20KL

अभिधासी अभियन्ता प्रमाणित किया जाता है कि
 1- प्रस्तावित निर्माण कार्य सेपित मार्ग की मध्य रेखा के 10.30 मीटर दूरी पर है तथा विभाग की सीमा 18.79 मीटर दूरी पर स्थित है।
 2- निर्माण कार्य अर्ध/काल क्षेत्र में है।
 3- प्रस्तावित निर्माण कार्य नव निर्माण/पुन-निर्माण है।
 4- प्रस्तावित निर्माण कार्य का निर्माण कार्य आरम्भ नहीं किया गया है।
 5- प्रस्तावित निर्माण कार्य के अनुसार विभाग के भूमि पर कोई अतिक्रमण नहीं है।
 6- प्रस्तावित निर्माण कार्य के आगे सभी विकास हेतु 100 सेमी व्यास की पुलिस जंक्शन आवश्यक है।
 7- प्रस्तावित निर्माण कार्य राज्य मार्ग/प्रमुख-किसल-मार्ग/अन्ध-किसल-मार्ग/प्रयोग-मार्ग, सड़क-जंक्शन-अमरोहा-जोधा भन्ने पर पड़ता है।
 8- प्रस्तावित निर्माण कार्य सेपित मार्ग की मध्य रेखा से 10.30 मीटर दूरी पर होने से मार्ग पर अतिक्रमण नहीं है।
 9- प्रस्तावित निर्माण कार्य नव अनार्यत प्रमाण पत्र दिये जाने की संसुति की जाती है।

अभिधासी अभियन्ता
 प्रदीप खन्ड, लोनिन्डि
 अमरोहा, उत्तर प्रदेश (उ.प्र.)

सहायक अभियन्ता
 प्रदीप खन्ड, लोनिन्डि
 अमरोहा



SITE PLAN
SCALE:-N.T.S.

- पत्रांक में लिखित शर्तों के अन्तर्गत निर्माण कार्य कराना होगा।
- निर्माण कार्य अर्ध/काल क्षेत्र (उ.प्र.) में है।
- निर्माण कार्य के आगे सभी विकास हेतु 100 सेमी व्यास की पुलिस जंक्शन आवश्यक है।

SPECIFICATION NOTES-1

- CERTIFIED THAT NO OTHER STRUCTURE WILL BE ERRECTED NOR ANY OTHER SERVICE RENDERED EXCEPT THAT CONNECTED WITH PETROL PUMP WITHOUT THE PRIOR APPROVAL OF P.W.D.
- CERTIFIED THAT THERE IS NO CROSSING WITHIN 300M BETWEEN THE TANGENT POINTS OF THE CURVES OF SIDE ROAD AND THAT OF THE FUEL-FILLING CUM SERVICE STATION.
- CERTIFIED THAT THERE IS NO OBJECTION FROM ROAD POINT OF VIEW FOR THE INSTALLATION OF THIS PUMP. THIS PROPOSAL WILL NOT AFFECT THE FUTURE IMPROVEMENT OF THE ROAD.
- CERTIFIED THAT NO OTHER PETROL PUMP EXISTS WITHIN THE DISTANCE OF 300M ON EITHER SIDE OF THE PLOT.
- CERTIFIED THAT ALL CONDITIONS LAID DOWN BY THE GOVT. OF INDIA AND IRC FROM TIME TO TIME WITH REGARD TO THE LOCATION OF ROAD SIDE FUEL-FILLING CUM SERVICE STATIONS SHALL BE COMPLIED WITH & ENTIRE CONSTRUCTION WILL BE ON CORPORATION LAND.
- NO DRAIN, SEWER OR STRUCTURE WITHIN 1.5M FROM UNDER GROUND TANKS.
- SUCTION PIPES, UNDER DRIVEWAY HOUSED IN PIPE SLEEVES.
- ELECTRIC FITTINGS CONFORM TO IS CODE NO- 2148 FOR DISPENSING PUMP ONLY.
- G.P.S BOARD IS FIXED 1.5M HIGH FROM FLOOR LEVEL AND WILL NOT BE KEPT UNDER LOCK AND KEY.
- 40MM Ø VENT PIPES, 4M HIGH FROM GROUND LEVEL AND 4M CLEAR AROUND. THE OPEN END OF VENT PIPE COVERED WITH TWO LAYERS OF NONE CORRODIBLE METAL WIRE GAUGE OF 11MESH PER LINER CM.
- 80MM Ø FILL PIPES, TO BE PROVIDED 3.65M CLEAR ALL ROUND.
- FIRE FIGHTING EQUIPMENT:-
 5 NOS. FOAM TYPE OF FIRE EXTINGUISHERS OF CAPACITY 9KG EACH FOR PETROLEUM FIRE, 2NOS CO2 TYPE FIRE EXTINGUISHERS OF CAPACITY OF 3KG EACH FOR FIGHTING ELECTRICAL FIRE AND 6NOS. OF FIRE BUCKETS FILLED WITH DRY SAND SHALL BE PROVIDED AT THE PETROL PUMP.
- CERTIFIED THAT THERE WILL NOT BE ANY HINDRANCES FROM OVER HEAD HT LINES.
- CERTIFIED THAT THE SURPLUS WATER WILL NOT BE DISPOSED OFF ON P.W.D LAND.
- CERTIFIED THAT ALL THE CONDITIONS OF IRC-1963/2003 SHALL BE COMPLIED WITH.

IMPORTANT NOTES:-

- CERTIFIED THAT THIS IS A NEW RETAIL OUTLET (KSK).
- CERTIFIED THAT NO COURT CASE IS PENDING IN ANY COURT OF INDIA AGAINST THIS SITE/DEALERSHIP.
- CERTIFIED THAT ALL THE CLEARANCES/APPROVALS FROM MCP/IRC AND OTHER RELEVANT GOVT. DEPTT. SHALL BE OBTAINED.
- CERTIFIED THAT ALL FACILITIES AS SHOWN IN THE DRAWING SHALL BE INSTALLED/PROVIDED AT ABOVE R/O.
- STEEL CANOPY APPROVAL NO. CCE G-40 (NC) P-CANOPY dt. 26.07.89.

SPECIFICATIONS FOR TANKS:-

- MS TANK OF 20KL CAPACITY FABRICATED AS PER ORG. APPROVED BY CCE VIDE LETTER NO. P-6(3) S1 DATED 23.01.2007.

STP CCOE APPROVAL NO. : R1(1)136/SUM/679 DATED 01.04.2010

SITE INFORMATION

KHASRA NO.	289
VILLAGE	KISHANGARH
ROAD	SH-77
TEHSIL	AMROHA
DISTT.	AMROHA
STATE	U.P.
POLICE STATION	AMROHA
RAILWAY STATION	AMROHA
PINCODE	244221

REV. NO.	DESCRIPTION	DATE	REV. BY.	APP. BY.
<p>INDIAN OIL CORPORATION LTD. (MARKETING DIVISION) MORADABAD DIVISIONAL OFFICE</p>				
PROJECT-		PROPOSED M/S/HSD RETAIL OUTLET AT KISHANGARH (AMROHA W/L) ON AMROHA - NOORPUR (S.H.-77) ROAD, TEHSIL - AMROHA, DISTT - AMROHA (U.P.)		
TITLE-		SITE & LAYOUT PLAN OF RETAIL OUTLET		
DRAWN BY:-		DRG NO:- RO/MDO/KISHANGARH/2019		
SCALE:-		AS SHOWN		
DATE:-		26.08.2019		
CHKD BY:-		CHKD BY:-		
RECOMND BY:-		FIELD OFFICER		
APPRD BY:-		APPRD BY:-		
CONSULTANT:-		M/S ABHIKALPAN ENGINEERS (NEW DELHI) PH. 011-85001458,+91-8527237383		