

Registered/AD

101 Road Constructions Coy (GREF)

Pin : 930101

C/o 56 APO

2030/19 /E2

16 Mar 2016

Er. A.K. Malhotra

Executive Engineer (C&M, TCC-IX)

R.R.V.P.N. Ltd

KV GSS Premise, Sagar Road

Bikaner, Rajasthan

GRANTING PERMISSION FOR ROAD CROSSING FOR LAYING OF 132 KV S/C NOKHADAIYA-KHAJUWALA TRANSMISSION LINE OF DISTRICT BIKANER IN RAJASTHAN STATE AND RESTORATION/REPAIR WORKS UNDER TAKING THERE OF

1. Reference your letter No. RRVPNL/XEN (C&M-TCC IX)/BKN/Tech./Estt/D 1163 dated 14 Jan 2016 and "undertaking letter No. 1426 dated 14 Mar 2016" for permission for road crossing for laying of 132 KV S/C Nokhadaiya-Khajuwala transmission line of District Bikaner.
2. This permission for road crossing for laying of 132 KV S/C Nokhadaiya-Khajuwala transmission line of District Bikaner is given on the basis of HQ CE (P) Chetak letter No. 20000-A/Gen/77/E2 Wks dated 15 Jan 2016 .
3. This permission of road crossing for laying of 132 KV S/C Nokhadaiya-Khajuwala transmission line as accorded will become null & void if, either the work is not commenced within 90 days from the date of issue of this letter or not followed as per the plan. The same will also become null and void if the terms & conditions of the "Undertaking and Joint Inspection Report" as given below are not followed by the Executive engineer (C&M,TCC-IX) RRVPN Ltd, Bikaner.
 - (a) That the traffic will not be affected during execution of the work.
 - (b) Provide suitable diversion along with adequate safety measure for traffic during execution of work.
 - (c) Erection of tower is far away from the Right of Way and it will not provide any obstacle in the extension of road in future if required.
 - (d) No claim will be raised by R.R.V.P.N. Ltd Bikaner, Rajasthan at future date in case the Transmission line are to be disturbed/dismantled by BRO for improvement of road or road or for any other technical/administrative initiatives reasons.

Contd- P/2


Tej
20
28/3/16

(e) All restoration work if occurred will be carried out by R.R.V.P.N. Ltd Bikaner, Rajasthan within 10 days with their own resources to make roads its original shape.

(f) Maintenance and repair of line in future after laying of transmission line, if at all required shall be done by RRVPN Ltd, Bikaner.

(g) "The vertical clearance of transmission line from the road surface to fulfill requirement of ARMY or any other agency in future" will be carried out by RRVPN Ltd, Bikaner without any compensation/claim from BRO.

4. This permission of road crossing for laying of 132 KV S/C Nokhadaiya-Khajuwala transmission line is granted with condition that "Payment to the contractor/subcontractor" by R.R.V.P.N. Ltd will be cleared only after clearance from BRO(OC/ Offg OC 101 RCC/ CE(P) Chetak).



(Prasad Sawnt)
Major
Officer Commanding

Copy to -

- HQ CE(P) Chetak
C/o 56 APO : For info wrt your letter No. 20000-A/Gen/77/E2 Wks dated 15 Jan 2016 pl.
- HQ 49 BRTF
C/o 56 APO : 1. For info wrt your letter No. 2001/Gen/236/E2 dated 23 Jan 2016 pl.
2. Copy of "Undertaking and Joint Inspection Report" duly signed by Executive engineer (C&M,TCC-IX) RRVPN Ltd, Bikaner, Rajasthan is enclosed herewith.
- Shri Ashok Kumar,
AE(Civ), OIC }
Shri Kailash Chand,
AE(Civ), OIC }
1. For info & ensure action on ground as per above please.
2. Also ensure to submit confirmation report to this HQ.

JOINT SURVEY REPORT BETWEEN M/S BORDER ROAD ORGANISATION
& M/S RVPNL DONE ON DATED 23.02.2016


Sub: - Regarding NOC of road crossing for the laying of 132 KV S/C Nokhadaiya-Khajuwala Transmission Line.


Ref: - Letter no- 2030 NOC/17/E2 dated 09.02.2016 from Sh. Prasad Sawant, Major (Office commanding).


- 32-8
1. Joint survey between M/S BRO & M/S RVPNL Representative has done on dated 23.02.2016 regarding NOC of road crossing for the laying of 132 KV S/C Nokhadaiya-Khajuwala Transmission Line.
 2. M/S RVPNL representative showed all the road crossings. The above said Transmission Line crosses from Khajuwala- Gharsana road in b/w milestone 132-133 under the OIC- Sh. Ashok Kumar, AE (Civ). Also the line crosses from Pugal - Khajuwala road at 85-86 milestone; Sattasar-IADM road at 32-33 milestone & B-P-B road at 149-150 milestone under the OIC- Sh. Kailash Chand, AE (Civ).
 3. During the site visit it is found that erection of tower is far away from the road and it will not provide any obstacle in the extension of road in future if required.
 4. During the site visit it is found that height of tower is adequate to maintain ground clearance of 6.10 mtrs as per RVPNL electricity norms enclosed and thus it will not provide any obstacle in the traffic movement. (Sketch of 132 KV tower enclosed herewith)
 5. M/s RVPNL representative ensured that they will ensure full safety & will not provide any damage to road while laying of transmission line.
 6. M/s RVPNL representative are strictly instructed by OIC that they will inform this office while road crossing & will ensure full safety of traffic movement while laying of transmission line on priority basis.
 7. After the site visit it is concluded that OICs of the above areas have no objection in road crossing of 132 KV S/C Nokhadaiya-Khajuwala Transmission line.


For M/S BORDER ROAD ORG.

For M/S RVPNL




Kailash Chand
AE (CIVIL)
OIC Platoon


CSO Purnendu Parashar


EER RAVINDER SINGH
JUNIOR ENGINEER-I