



(H.P. Govt. Energy Development Agency)

HIMURJA, Urja Bhawan SJA Complex Kasumpti Shimla-171009

PHONE-177-2620365, 2621783, 2625306, 2621923, FAX 177-2622635

No. HIMURJA/ SHP/Siul-IV (309)/2015-2778 Dated : 01-4-16

To

M/s Friends Him Energies (Partnership-4),
Near Happy School, Jail Road, Tehsil & Distt Gurdaspur-143521

Subject:- Consent for exclusive time bound right for preparation of Project Report for the Small Hydel Project Siul-IV (3.00 MW) in Chamba District , Himachal Pradesh.-
Submission of feasibility report of (4.00 MW) capacity.

Dear Sir,

This is in reference to your letter No. Nil dated Nil vide which Feasibility Report in respect of Siul-IV SHEP in District Chamba has been submitted to Himurja. After examining the Feasibility Report the parameters are frozen as under:

Sr. No.	Name of Project	River/ Stream	District	Elevation Range (Diversion to Tail race)	Capacity	Tentative Land Required	
						Forest	Private Land
1	Siul-IV	Siul	Chamba	Weir -1813.3m PH -1745m MTWL- 1741m	4.00	1.00 Ha	

It is further stated that the approval of the Feasibility Report (FR) of Siul-IV SHEP in District Chamba shall be subject to the following conditions:-

1. There shall be no change in the elevations from the elevation freezes in the FR.
2. Discharge data has to be observed for optimization of capacity in the DPR, if it varies from the figure of Feasibility Report, Technical Concurrence is required to be obtained from DoE.
3. Evacuation point has to be got finalized from HPSEBL/HPPTCL, However land for the same has been included in the Land requirement.
4. As per laid down guidelines riparian distance of 50 mtrs elevation wise or 250m horizontal distance is to be maintained between upstream and downstream projects to allow visible flow of water in the stream/Nalla while carrying out detailed survey/studies, but it is not demonstrated in the FR. The same should be followed strictly, failing which the allotment is liable to be cancelled for violation of the same.
5. Elevations of each component must be marked in the Contour plan and should also be included in the salient feature, after carrying proper survey. Copy of which is also to be forwarded to Himurja.

Therefore, you may go ahead for obtaining various clearances/NOCs on the basis of parameters frozen herein above.

Yours Sincerely,

Dy Chief Executive Officer,
HIMURJA, Urja Bhawan,
Kasumpti-Shimla-171009.

-PTO-