

## Comments of JBVNL regarding use of Insulated Aerial Bundled Cables or Underground Cable

This is in reference to the letter number 2465 dated 20<sup>th</sup> Jul-2021 issued from the office of DFO– Hazaribagh West Forest Division, where in it has been asked to provide undertaking / comments for the use of Insulated Aerial Bundled Cables or Underground Cable in 33KV Line from Padma Substation to Nachanwe Substation, for which forest clearance approval in the process. In this regard, JBVNL would like to inform the followings –

1. 33KV line from Padma to Nachanwe Power Substation is proposed to energize 33/11kv 2X5MVA Nachanwe Power Substation which is constructed under Deen Dayal Upadhaya Gramin Jyoti Yojna (DDUGJY Scheme) to provide grid connectivity to the larger masses that have been devoid of the basic facility. This energy poverty is compounding the existing poor living conditions and opportunities for increasing cropping intensity due to lack of irrigation despite presence of sufficient water resources.
2. "Guidelines for laying transmission lines through Forest Area" has been issued by MoEF, Government of India vide circular F.No.7-25/2012-FC dated 05.05.2014 wherein use of bare conductor has been envisaged in 33KV line with special conditions for "width of Right of Way" and "width clearance between conductors and conductor & trees". Use of Insulated Conductors has only been

  
**Gopal Prasad Barnwal**  
Electrical Executive Engineer-Project  
Electric Supply Circle  
Hazaribagh

mandated if the power line passes through National Parks and Wildlife Sanctuaries.

As per the verified land schedule for the proposed route of 33KV line from Padma substation to Nachanwe Substation, the line does not pass through any designated National Parks or Wildlife Sanctuaries, therefore, use of insulated conductors may not be mandatory as per guidelines.

3. Aerial Bunch Cable for 33KV is not readily available in market due to very rare use of this cable in utility sector. Main reason for this is the high failure rate of HV Aerial Bunch Cable wherever it has been used till date. Hence, Aerial Bunch Cable for 33KV is not advisable to be used in this proposed 33KV line from Padma to Nachanwe Substation.
4. The route for 33KV line from Padma to Nachanwe Power Substation (6.7 KM) passes through tough terrain comprising of undulated surface profile, hard rock, rivers, culverts, and agriculture fields. Trench for underground cable is not advisable in agriculture fields considering the use of tractor / manual plough for ploughing the field during farming season. Similarly, river crossing is not possible with underground cable. Trenching / HDD will be very challenging in forest land considering the possibility of hard rock.

Also, general drum length for 33KV UG cable is 250 meters and cable laying is usually done in smaller runs to restrict mid span

  
**Gopal Prasad Barnwal**  
Electrical Executive Engineer-Project  
Electric Supply Circle  
Hazaribagh

joints. If the entire route of Padma Nachanwe (6.7km) is to be done with UG Cable then the number of joints would be in excess of 25nos which will make cable highly susceptible to failure. In case of fault, maintenance of UG cable would require deployment of special machines and special skilled personnel which would be very challenging to arrange immediately. Further it may be noted that -

### **Power restoration**

Damage to underground transmission lines is difficult to pinpoint, and repairs may take a few weeks to several months to complete. Sometimes it causes unrest in the local population.

### **Capacity requirements**

For underground transmission, a large number of cables are often required to match the capacity of the overhead circuit. Additional components increase the underground cost as a duct bank, vaults, splices and terminations are required which can also reduce overall system reliability.

### **Line-length challenges**

Underground lines may require additional equipment to ensure proper electrical performance along the distance of the transmission line. The additional equipment translates to a higher overall cost, limits the length of the underground line installation and increases the likelihood of failure because of additional components.

  
**Gopal Prasad Barnwal**  
Electrical Executive Engineer-Project  
Electric Supply Circle  
Hazaribagh

## **Multiple cables and cooling options**

Overhead lines are air cooled and widely spaced for safety. Underground cables are installed in concrete encased PVC duct banks. Heat generated by the cables is dissipated into the earth.

## **Construction impacts**

Burying transmission lines has more environmental impacts than placing them overhead. Considerable clearing and grading would be necessary, and dust and noise from construction would last three to six times longer than it would for overhead construction.

## **Easement and land purchase requirement**

An overhead line typically has a wider easement footprint than an underground line.

## **Life expectancy**

Underground high-voltage transmission lines have a life expectancy of 40+ years, while overhead lines have a life expectancy of more than 80 years. Considering that Jharkhand being a poor state, cost and life expectancy should be considered.

## **Costs**

An underground line costs 10 to 15 times the cost of an overhead line due to time, materials, processes, the need to include transition substations and the use of specialized labor. An overhead line often can be routed around or over these difficult areas.

  
**Gopal Prasad Barnwal**  
Electrical Executive Engineer-Project  
Electric Supply Circle  
Hazariabagh

## Site restoration

Site restoration for underground construction is a much larger endeavour than it is for overhead construction because soil is disturbed along the entire route. Top soils have to be restored and returned to vegetated areas, and all hard surface areas must be re-established.

Moreover, cost of the project with bare conductor is envisaged to be Rs. 72.64 Lacs, however, cost with double circuit UG cable will increase approximately by 10 times making the project economically unviable.

Considering the above technical challenges and economical viability, it is requested to allow use of conductors in line with conditions as per guidelines issued by MoEF for laying transmission lines through forest areas.

Yours truly



**Gopal Prasad Barnwal**

Electrical Executive Engineer-Project

Electric Supply Circle

(Electrical Executive Engineer-Project)

Electric Supply Circle- Hazaribag