

DDA-96 dt 30/03/2021



Phone No. 01274-256759

Email Id:- kenwsdvnri1@gmail.com

O/o EXECUTIVE ENGINEER, WATER SERVICES DIVISION No.1, REWARI

No. 1725 / 2W

Dated 25/03/2021

To: Sub Divisional Officer,
Const. Sub Division, HVPNL,
Rewari

Subject: Providing No Objection Certificate for 2 Nos. new 132KV Single circuit line on double circuit tower Lula Ahir, one will end at 132 KV S/Stn Buroli & Second will end at 132KV S/Stn Pali Gothra.

Reference: Your office Memo No. 1414 dated 05.02.2021.

In this connection it is submitted that this office has no objection in this regard after fulfilling the following conditions by the Haryana Vidhyut Prasaran Nigam Ltd.

1. The clear distance between Canal Bank/TOL and wire/conductor should be sufficient so that it will not create any hindrance during execution of work by Machinery i.e. Internal Clearance, Rehabilitation of Channel etc.
2. Tower/Poles should be erected away from the land boundary of the channel.
3. During erection of pole/conductor wires, ensure proper safety measures that there should not be any damage to channel and its allied works.

This is for your information and necessary action please..

Executive Engineer,
Water Services Division No.1,
Rewari