

To

The Sub Divisional Officer,
Construction sub division HVPNL,
Rewari.

No. 21460

Dated 02/08/2021

Subject:

Providing No Objection certificate for 2nos new 132 kv single circuit line on double circuit tower from Lula Ahir, one will be end at 132 kv substation Pali Gothra.

Reference your office letter no. 1415 dated 05.02.2021.

The NOC for crossing the 132 KV electric line over the roads falls under the jurisdiction of this division is hereby granted subject to the following conditions :-

1. Electric line passes over PWD (B&R) roads should be at safe height i.e. more than 7.00mtr.
2. No tower /pole should be constructed in the PWD B&R land /ROW of roads.
3. Any type of damage on PWD B&R road must be avoided. However, any damages occur, the same should be restored immediately as per the PWD Specifications.
4. In future, if road will be raised /widened the tower /poles line will be raised /shifted at his own cost during crossing of road safety work may be ensured.
5. The HVPNL will be responsible for the safety of the road users during and after execution of the work.
6. All the road safety measures shall be adopted while executing the work.
7. The NOC is not for legal /court purposes.

DA/ Nil.

Executive Engineer,
Provl. Division PWD B&R Br.,
Rewari.

Endst. No.

Dated

Copy of the above is forwarded to the Sub Divisional Engineer, Provl. Sub Division No.1/2 PWD B&R Br., Rewari for information w.r.t. his letter no.311 dated 16.04.2021 & no. 1078 dated 15.04.2021.

DA/ nil

Executive Engineer,
Provl. Division PWD B&R Br.,
Rewari.