

North Western Railway

No. 63-Elect/Xing/OH/2020 – 972

DRM Office,
Bikaner.
Dt. 05.12.2020

XEN/TS/Division,
HVPNL,
Rewari - 123401

Sub: 132 KV DC overhead power line track crossing at KM 99/1-2 between Dahina –Nangal mundi stations in RE-SDLP section.

Ref: Your office Memo no. 342, dt. 09.06.2020.

-X-X-X-X-

In reference to above and instructions contained in Rly. Bd. letter no. 2010/Elect(G)/148/6 dt.30.01.17, following is to bring to your kind notice:

1. Subject to final verification of Railway boundary, permission is hereby accorded to execute the erection work of the above crossing without energization in the position and manner shown in Railway's approved drawing no. NW Rly. BKN Div. **Sr.DEE/G-972/2020** submitted by you for approval and in accordance with the Agreement / Memo of terms incorporating the condition and specification therein and also the 'Regulation Governing' the placing of 'Electrical Transmission Line across the Railway Track' issued and as latest amended by Railway Board.
2. Under clause 3(II) of the Agreement / Memo of terms you are required to give a notice of sufficient days to the Senior Section Engineer (P Way), N.W. Rly at Mahendergarh and Asst. Engineer, N.W. Rly at Bhiwani to enable them to take safety and precautionary measures where necessary before any work is actually commenced across or on the Railway Land and Track.
3. The SSE/S&T and Asst. Divisional Signal & Telecom Engineer concerned of the S&T Deptt. should also be addressed by you to enable them to check the safety arrangements for S&T line coming in this crossing area, to their satisfaction.
4. Permitted block time total **3 Hrs.** Block will be provided in breaks as per the suitability of Railway.

It is requested to submit the joint inspection report to this office about the completion of construction work of the crossing. It may please be noted that electric crossing can be energized after prior approval of EIG from competent authority of SEBs/Owner of crossing and same is submitted with compliance certificate. The performa for joint inspection is attached herewith.

- DA:
1. Copy of approved drawing mentioned above.
 2. Performa for joint inspection & compliance certificate

Signed by Bhagwan Sahay
Meena
DRM (Electric),
N.W. Railway, Bikaner
Date: 07-12-2020 18:54:32
Reason: Approved

Copy forwarded for information and necessary action along with drawing to:

1. ADEN/BNW
2. SSE(P Way)/MHRG
3. SSE/Elect./SDLP
4. SSE/Tele/SDLP
5. SSE/TRD/KSI

Copy for kind information please:

1. Sr.DOM/BKN
2. DEN(S)/BKN
3. Sr. DSTE/BKN
4. Sr.DEE/TRD/BKN