# TAMIL NADU GENERATION AND DISTRIBUTION CORPORATION LTD. (Abstract)

\*\*\*\*

Electricity - Madurai Region - Dindigul EDC- Extension of One number OHT Service Connection to The President, Sirumalai Panchayat at S.F No. 783/2 A, Sirumalai Village, Thenmalai habitation - Administrative approval - Accorded.

\_\_\_\_\_\_

#### **TECHNICAL BRANCH**

(Per) (CMD) TANGEDCO Proceedings No:313

Dated: 28.07.2015.

Aadi : 12

Sri Manamatha Varudam Thiruvalluvar Aandu : 2046

Read: 1)Memo.No.CE/D/MDU/EEE/AEE.3/F.H.Q Prop.No/D.No.62/14, Dt.24.02.14.

2) Lr.No.CE/D/MDU/EEE/AEE.3/F.H.Q PRO/D.No.253/15, Dt.02.07.15.

\*\*\*

### **Proceedings:**

Approval is hereby accorded for extension of supply to 1 No. OHT Service Connection to The President, Sirumalai Panchayat at S.F No. 783/2 A, Sirumalai Village, Thenmalai habitation in Dindigul EDC superseding the sanction already accorded by Chief Engineer/Distribution/Madurai vide reference 1<sup>st</sup> cited above subject to the following conditions.

- i) All the relevant documents required as per the procedures in the TNERC Distribution Code should be verified before according technical sanction to the estimate.
- ii) The OHT Service Connection may be effected after carrying out the following works proposed in the feasibility report.

### **HT SIDE**

- 1. Erection of HT special structure with 100 KVA DT
- 2. Erection of 22 KV 3 wire line with 7/3.35 mm AAAC 7/2.59 mm to a distance of 2.812 Km (Land belongs to Revenue and Private Party).
- 3. Laying of 22 KV, 3  $\times$  50 sq.mm cable to a distance of 3.0 Km (Land belongs to Forest Department).
  - 4. Erection of 1 No. DP Structure.

### **LT SIDE**

- 1. Stringing of 35 Mtr. 7/3.15 mm AAAC.
- 2. 1. No New OHT Sc with 5 HP + 180 watts is to be effected.
- iii) The expenditure of Rs. 58,34,390/- (Rupees Fifty Eight lakh thirty four thousand three hundred and ninety only) (Gross & Nett) is chargeable to TANGEDCO Funds Capital expenditure Dindigul EDC A/c Code No.14.656.

iv) By virtue of the Board provision contained in sub sections (2) (a) of section 185 of the Electricity Supply Act 2003, the Board being the Transmission utility and Licensee will exercise the power of Telegraph authority under the provision of Section 164 of the Electricity Supply Act 2003, which have already been conferred upon the Board under section 51 of the Indian Electricity Act 1910.

## (BY ORDER OF THE CHAIRMAN CUM MANAGING DIRECTOR)

**Sd/--** (S.SHANMUGAM) CHIEF ENGINEER/COMMERCIAL

To

The Chief Engineer/Distribution/Madurai Region.

Copy to the Superintending Engineer/Dindigul EDC.

Copy to the Executive Engineer/ Director(Distribution) office.

Copy to B.P section/Adm. Branch.

Copy to Stock file.