

ANNEXURE - E



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केंद्रीय विद्युत प्राधिकरण

Central Electricity Authority



विद्युत प्रणाली योजना एवं परियोजना मूल्यांकन प्रभाग-II [ISO: 9001:2008]

Power System Planning & Appraisal Division-II

सेवा भवन, रा. कृ. पुरम, नयी दिल्ली -110066

Sewa Bhawan, R. K. Puram, New Delhi-110066

No. 81/7/2015/PSPA-III/109

Dated: 08.02.2015

To,
 ✓ Sanjay Nayak, AVP,
 PFC Consulting Limited
 First Floor, "Urjanidhi", 1, Barakhamba Lane,
 Connaught Place, New Delhi-110001

Subject: Prior approval of the Government under Section 68(1) of Electricity Act, 2003 for "North Eastern Region Strengthening Scheme-VI (NERSS-VI)" by Kohima-Mariani Transmission Limited (SPV).

Reference: PFCCL letter no 03/ITP-23/15-16/KMTL dated 27.01.2016

Sir,

This has reference to PFCCL letter dated 27.01.2016 seeking prior approval of Government under section 68 (1) of the Electricity Act, 2003 for North Eastern Region Strengthening Scheme-VI (NERSS-VI) with following scope of works.

(i) Establishment of 400/220 kV, 2x500 MVA S/S at New Kohima

400 kV

- ICTs: 400/220 kV, 2x500 MVA
- ICTs bays: 2 no.
- Line bays: 4 no.
- Bus reactor: 2x125 MVAR
- 400 kV bus reactor bays: 2 no.
- Space for future bays: 4 no.
- Space for 400/220kV 500 MVA ICT along with associated bays

220 kV

- ICTs bays: 2 no.
- Line bays: 4 no.
- Space for future bays: 4 no.

(ii) Imphal – New Kohima 400kV D/c line

(iii) New Kohima – New Mariani 400kV D/c line

2. The scope of works mentioned above, has been agreed in the 5th Standing Committee Meeting on Power System Planning of North Eastern Region held on 08.08.2015 at Imphal (Manipur).

Act, 2003 for the scheme "North Eastern Region Strengthening Scheme-VI (NERSS-VI)" with above scope of works.

4. This approval is subject to compliance of
 - (a) The requirement of the relevant provisions of the Electricity Act, 2003, as amended from time to time and the rules and regulations framed thereunder and
 - (b) CEA's (Measures relating to Safety and Electricity Supply) Regulations, 2010 framed under the Electricity Act, 2003.
5. The approval is also subject to the following conditions:
 - (i) The implementing agency will commence construction of the project within three years, unless this term is extended by the Central Electricity Authority.
 - (ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one month notice.
 - (iii) "The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Government of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006)".

Provided that "*nothing contained in this rule shall effect the powers conferred upon the licensee under section 164 of the Electricity Act, 2003*"

Yours faithfully,


(P. D. Siwal)
Secretary (CEA)

Copy to:

1. Joint Secretary (Trans), MOP, Shram Shakti Bhawan, New Delhi.