Operation and Maintenance,

Rural- II/Sendurai

Tangedco.

To:-

The Principle Chief conservator of forest

Panagal Maaligai

Saithapet,

Chennai--600015

Respected sir,

Sub:Elecy- Forest Clearance –Trichy Circle-Ariyalur Division Proposal for diversion of .ha of forest land for erection of 11Kv(HT) feeder from ayyur to Vallam village via kuvugam and Muthukulam reserved forests- Justification certificate submission of –reg

Referance 1:FP/TN/others/45417/2020

Referance 2:TS4/13226/2020 dated 02.06.2020

Referance3: Revised proposal uploaded by user agency on 28.09.2020

Referance 4:TS4/13226/2020 dated 28.10.2020

The forest clearance approval was requested vide Ref (1) for erection of 11Kv(HT) feeder from ayyur to vallam village via Kuvagam reserved forests by the user

agency of assistant Engineer ,Rural II Sendurai, ariyalur district. The same proposal was returned vide refeance no (2) which was attended and resubmitted vide ref (3).

The proposal is again returned for want of justification certification for issuing approval for erection of 11 LV HT feeder vide ref (4).

It is certified that the now proposed New 11KV HT line passes through along the road side of District panchayat roads and also along the road side of SH 144 (ie) Ayyur to Edaiyakurichi and vallam via Kuvagam reserved forests.

Eventhough the width of right of way is 7 meter for 11 KV transmission line according to the forest conservation act 1980, the minimum clearance between conductor and trees of forest area is well maintained (ie) above 2.6 mtr in this proposal.

The route alignment through the forest area does not have any line deviation, since the line passes through parallel with road side. It is certified that the no tree cutting is involved while laying the 11KV lines and endangers to the wild animals in this RF area.

Consider the above reason, the route approval may please be accorded as early please.

Copy to .District Forest Officer/Forest office /ariyalur

O &M RURAL -2 TANGED Co SENDURAL - 621714

Chief Conservator of forest /Trichy

3.Copy Submitted to Superintending Engineer /PEDC/Perambalur for kind information
Please