

**OFFICE OF THE EXECUTIVE ENGINEER PHED DIVISION RAJGARH, ALWAR**

Date 10 .09.2017

**JUSTIFICATION FOR LOCATING THE PROJECT IN FOREST AREA**

The Village Sokhar Tehsil Kathumar Code073795 having population 4318 souls as per 2011 census and design population is 6002 souls. Village is covered by piped water supply scheme. There are 10 no. of working hand pumps in village and 2 nos single phase bore wells also. Design demand of scheme is 240 KLD. Present service level is 15 lpcd by Piped scheme. Existing 2 nos tube well has near about dry. The present piped scheme does not fulfill the daily requirement of the villagers. To provide safe , potable drinking water to the villagers for solving water supply problem , augmentation of piped water scheme has been proposed.

In this proposal provision for construction and commissioning of 2 nos 200mm dia. tube well , provision for construction of GLSR 2 nos capacity 235 KL has been included in the proposal. Proposal for providing , laying and jointing of rising main and distribution pipe line system have also been included in the proposal .

SA  
8/9/17  
अधिसायी अभियन्ता  
जन स्वास्थ्य अभियांत्रिक विभाग  
खण्ड राजगढ कोड स. 10743

Place: - Rajgarh  
Date:- 10-09-2017

Signature of User Agency  
Office Seal.....