

**Delhi Tourism & Transportation
Development Corporation Ltd.**

(A Government Undertaking)

New India Petrol Pump, Majnu Ka Tilla

Old Delhi, New Delhi, Wazirabad, Delhi, India.

Phone: 011-23103211, 23103212, 23103213, 23103214, 23103215

No. DTTDC/Engg/WB/EI (E)/54/224/2017

Date: 11 August, 2017

To,

The Chief Manager,
Delhi Project,
The Power Grid Corporation of India Limited
44/220KV, G.I.S., Maharani Bag Sub-station,
Bahadurpur Khadar, Sarai Kalen Khan, ISBT,
New Delhi-110013

**Subject: - NOC for crossing of Signature Bridge Road by LILO of 400KV
Mandola Bawana transmission line at Maharani Bagh on multi circuit
tower.**

Ref: - Power Grid Corporation letter No. NR 1/PG/MBGH/H. way Proposal/
dated 05.07.2017 and subsequent letter no. NR 1/PG/MBGH/H. way
Proposal/dated 09.08.2017(Revised).

Dear Sir,

Kindly refer your above said letter vide which you have asked for N.O.C for
crossing the Signature bridge road by 440/220KV LILO Mandola transmission line.

In the regard, it is intimated that the revised proposal submitted vide your letter No
NR 1/PG/MBGH/H. way Proposal/dated 09.08.2017. (Revised) has been scrutinized by
this office which is found in order and this office has NO OBJECTION for this proposal.

This letter is issued with the approval of Chief Project Manager, Wazirabad
Bridge Project, DTTDC Ltd, Majnu KA Tilla, New Delhi.


Executive Engineer (Elect)
WBP, DTTDC Ltd.


Copy to:-

1. The Chief Project Manager, Wazirabad Bridge Project, DTTDC Ltd, Majnu KA
Tilla, New Delhi.
2. The Supervision Engineer (Elect), Wazirabad Bridge Project, DTTDC Ltd,
Majnu KA Tilla, New Delhi.


Executive Engineer (Elect)



राष्ट्रीय राजधानी क्षेत्र दिल्ली सरकार
GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI
लोक निर्माण विभाग
PUBLIC WORKS DEPARTMENT



कार्यालय मुख्य अभियंता
पूर्व अंचल (एम), लोक निर्माण विभाग,
दिल्ली सरकार, तृतीय तल, एम.एस.ओ. भवन,
इन्द्रप्रस्थ एस्टेट, नई दिल्ली -110002
23(Elect.)/CE /East/Zone/EE(P)/2017-18/ 438-18 E

OFFICE OF CHIEF ENGINEER
EAST ZONE (M) PWD,
GNCTD, 3rd Floor, M.S.O. Building,
I.P. Estate, New Delhi -110002.

Date: 13/12/17

To,

The Chief Manager, Delhi Project
Power Grid Corporation India Ltd.
400-220 KV G.I.S. Maharani Bagh Substation,
Behlol Pur Khadar,
Infront of Sarai Kale Khan ISBL,
New Delhi-110013
Email id: sk_singh@powergridindia.com

**Sub: NOC for crossing of Kashmiri Gate Ghaziabad Yamuna Bridge by L.H.O of 400 KV
Mandola-Bawana Transmission Line at Maharani Bagh on Multi Circuit Tower.**

Ref: Your letter no. NR1/PG/MBGH/H.way/Proposal/4 dated-05/07/2017

Dear Sir,

This is with reference to your request for grant of NOC for crossing of Kashmiri Gate Ghaziabad Yamuna Bridge for laying of 400 KV Mandola-Bawana Transmission Line at Maharani Bagh on Multi Circuit Tower. In this regard, the NOC for laying of 400 KV transmission line is hereby granted subject to following conditions:-

1. The PGCIL shall keep the minimum clearance of 86 mtrs. of towers from the edge of road of Kashmiri Gate Ghaziabad Yamuna Bridge at both sides


Further, PGCIL shall obtain all other statutory clearances required for laying of 400 KV transmission line at the aforesaid location.

This issues with approval of Chief Engineer (East) M.

Executive Engineer (E) Planning
GNCTD, 3rd Floor, M.S.O. Building,
I.P. Estate, New Delhi -110002



राष्ट्रीय राजधानी क्षेत्र दिल्ली सरकार
GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI
लोक निर्माण विभाग
PUBLIC WORKS DEPARTMENT



कार्यालय मुख्य अभियंता
पूर्व अंचल (एम.), लोक निर्माण विभाग,
दिल्ली सरकार, तृतीय तल, एम.एस.ओ. भवन,
इन्द्रप्रस्थ एस्टेट, नई दिल्ली -110002
23(Elect.)/CE /East/Zone/EE(P)/2017-18/ 435 E

OFFICE OF CHIEF ENGINEER
EAST ZONE (M) PWD,
GNCTD, 3rd Floor, M.S.O. Building,
I.P. Estate, New Delhi -110002.

Date: 13/12/17

To,

The Chief Manager, Delhi Project
Power Grid Corporation India Ltd.
400/220 KV G.I.S. Maharani Bagh Substation,
Behlol Pur Khadar,
Infront of Sarai Kale Khan ISBL,
New Delhi-110013
Email id: sk_singh@powergridindia.com

Sub: NOC for crossing of ITO Yamuna Bridge Road by L.L.O of 400 KV Mandola-Bawana Transmission Line at Maharani Bagh on Multi Circuit Tower.

Ref: Your letter no. NR1/PG/MBGH/H.way/Proposal/3 dated 05/07/2017

Dear Sir,

This is with reference to your request for grant of NOC for crossing of ITO Yamuna Bridge Road for laying of 400 KV Mandola-Bawana Transmission Line at Maharani Bagh on Multi Circuit Tower. In this regard, the NOC for laying of 400 KV transmission line is hereby granted subject to following conditions:-

1. The height of lowest conductor from top of road of Geeta Colony Yamuna Bridge road should be kept atleast 32 Mtr. instead of 16.2 Mtr. proposed.
2. The distance of tower from edge of road of ITO Yamuna Bridge (Vikas Marg) be kept as minimum 86 Mtr. from both the side.


Further, PGCI shall obtain all other statutory clearances required for laying of 400 KV transmission line at the aforesaid location.

This issues with approval of Chief Engineer (East) M.

Executive Engineer (E) Planning
GNCTD, 3rd Floor, M.S.O. Building,
I.P. Estate, New Delhi -110002



राष्ट्रीय राजधानी क्षेत्र दिल्ली सरकार
GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI
लोक निर्माण विभाग
PUBLIC WORKS DEPARTMENT



कार्यालय मुख्य अभियंता
पूर्व अंचल (एम), लोक निर्माण विभाग,
दिल्ली सरकार, तृतीय तल, एम.एस.ओ. भवन,
इन्द्रप्रस्थ एस्टेट, नई दिल्ली - 110002
23(Elect.)/CE /East/Zone/EE(P)/2017-18/ 436 E

OFFICE OF CHIEF ENGINEER
EAST ZONE (M) PWD,
GNCTD, 3rd Floor, M.S.O. Building,
I.P. Estate, New Delhi -110002.

Date: 13.12.17

To,

The Chief Manager, Delhi Project
Power Grid Corporation India Ltd.
400/220 KV G.I.S. Maharani Bagh Substation,
Behlol Pur Khadar,
Infront of Sarai Kale Khan ISBT,
New Delhi-110013
E mail id: sk_singh@powergridindia.com

Sub: NOC for crossing of Geeta Colony Yamuna Bridge Road by LILO of 400 KV Mandola-Bawana Transmission Line at Maharani Bagh on Multi Circuit Tower.

Ref: Your letter no. NRI/PG/MBGH/H.way/Proposal/2 dated 05/07/2017

Dear Sir,


This is with reference to your request for grant of NOC for crossing of Geeta Colony Yamuna Bridge Road for laying of 400 KV Mandola-Bawana Transmission Line at Maharani Bagh on Multi Circuit Tower. In this regard, the NOC for laying of 400 KV transmission line is hereby granted subject to condition that PGCIH may provide maximum spans between the piers at the crossings so that further widening if any, may not be affected. Further, PGCIH shall obtain all other statutory clearances required for laying of 400 KV transmission line at the aforesaid location.

This issues with approval of Chief Engineer (East) M.

Executive Engineer (E) Planning
GNCTD, 3rd Floor, M.S.O. Building,
I.P. Estate, New Delhi -110002



राष्ट्रीय राजधानी क्षेत्र दिल्ली सरकार
GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI
लोक निर्माण विभाग
PUBLIC WORKS DEPARTMENT



कार्यालय मुख्य अभियंता
पूर्व अंचल (एम.), लोक निर्माण विभाग,
दिल्ली सरकार, तृतीय तल, एम.एस.ओ. भवन,
इन्द्रप्रस्थ एस्टेट, नई दिल्ली - 110002
23(Elect.)/CE /East/Zone/EE(P)/2017-18/ 43) फि. ए

OFFICE OF CHIEF ENGINEER
EAST ZONE (M) PWD,
GNCTD, 3rd Floor, M.S.O. Building,
I.P. Estate, New Delhi - 110002.

Date: 13/12/17

To,

The Chief Manager, Delhi Project
Power Grid Corporation India Ltd.
400/220 KV G.I.S. Maharani Bagh Substation,
Behlol Pur Khadar,
Infront of Sarai Kale Khan ISBT,
New Delhi-110013
Email id: sk_singh@powergridindia.com

Sub: NOC for crossing of Wazirabad Yamuna Bridge Road by L.I.O of 400 KV Mandola-Bawana Transmission Line at Maharani Bagh on Multi Circuit Tower.

Ref: Your letter no. NR1/PG/MBGH/H.way/Proposal/1 dated 05/07/2017

Dear Sir,

This is with reference to your request for grant of NOC for crossing of Wazirabad Yamuna Road for laying of 400 KV Mandola-Bawana Transmission Line at Maharani Bagh on Multi Circuit Tower. In this regard, the NOC for laying of 400 KV transmission line is hereby granted subject to following conditions:-

1. There is a new proposal of six lane elevated road from Salimgarh Bypass to DND. The proposed transmission line will cross this proposed elevated road at Maharani Bagh near Sarai Kale Khan at the height of 42 mtrs. Further, there is another proposal of East West corridor which will cross Yamuna River along Railway Line coming from Akshardham. The PGCH shall keep the aforesaid proposals in mind while erecting the new transmission line for which they may contact Sh. V.K. Singh, PM I-1, Mukarba Chowk, GI Karnal Road, Near CNG Petrol Pump (Telephone No. 27691871) and Sh. G.P. Bansal PM I-5, Brar Square Intersection, Ring Road, Behind IGI, Delhi Cantonment Area (Mobile No. 9818199786) of PWD before taking up the work of transmission line to avoid any interference in future.

Further, PGCH, shall obtain all other statutory clearances required for laying of 400 KV transmission line at the aforesaid location.

This issues with approval of Chief Engineer (East) M.

Executive Engineer (E) Planning
GNCTD, 3rd Floor, M.S.O. Building,
I.P. Estate, New Delhi - 110002