



**HARYANA STATE POLLUTION CONTROL
BOARD**
**SCO-180, 2nd Floor, Sector-5, Panchkula Ph. 0172-
2566286**

Website: www.hspcb.gov.in E-Mail - hspcb.pkl@sifymail.com

Telephone No.: 0172-2577870-73



No. HSPCB/Consent/ : 313128718PANCTE5459260

Dated:09/07/2018

To.

M/s : Aloft Industries Private Limited
Village Kazampur, Raipur Rani, Panchkula
PANCHKULA
130410

Sub. : Grant of consent to Establish to M/s Aloft Industries Private Limited

Please refer to your application no. 5459260 received on dated 2018-06-27 in regional office Panchkula.

With reference to your above application for consent to establish, M/s Aloft Industries Private Limited is hereby granted consent as per following specification/Terms and conditions.

Consent Under	AIR/WATER
Period of consent	09/07/2018 - 08/07/2023
Industry Type	Spray painting, paint baking, paint shipping
Category	ORANGE
Investment(In Lakh)	160.0
Total Land Area (Sq. meter)	3245.0
Total Builtup Area (Sq. meter)	1350.0
Quantity of effluent	
1. Trade	0.0 KL/Day
2. Domestic	0.8 KL/Day
Number of outlets	1.0
Mode of discharge	
1. Domestic	septic tank
2. Trade	
Permissible Domestic Effluent Parameters	
1. NA	0
Permissible Trade Effluent Parameters	
1. NA	0 mg/l
Number of stacks	1
Height of stack	
1. stack attached to dust collector	15 feet

Permissible Emission parameters	
1. NA	0
Capacity of boiler	
1. na	0 Ton/hr
Type of Furnace	
1. na	0
Type of Fuel	
1. Diesel	0.01 KL/day

Regional Officer, Panchkula
Haryana State Pollution Control Board.

Terms and conditions

1. The industry has declared that the quantity of effluent shall be 0.8 KL/Day i.e 0KL/Day for Trade Effluent, 0 KL/Day for Cooling, 0.8 KL/Day for Domestic and the same should not exceed .
2. The above 'Consent to Establish' is valid for 60 months from the date of its issue to be extended for another one year at the discretion of the Board or till the time the unit starts its trial production whichever is earlier. The unit will have to set up the plant and obtain consent during this period.
3. The officer/official of the Board shall have the right to access and inspection of the industry in connection with the various processes and the treatment facilities being provided simultaneously with the construction of building/machinery. The effluent should conform the effluent standards as applicable
4. That necessary arrangement shall be made by the industry for the control of Air Pollution before commissioning the plant. The emitted pollutants will meet the emission and other standards as laid/will be prescribed by the Board from time to time.
5. The applicant will obtain consent under section 25/26 of the Water (Prevention & Control of Pollution) Act, 1974 and under section 21/22 of the Air (Prevention & Control of Pollution) Act, 1981 as amended to-date-even before starting trial production
6. The above Consent to Establish is further subject to the conditions that the unit complies with all the laws/rules/decisions and competent directions of the Board/Government and its functionaries in all respects before commissioning of the operation and during its actual working strictly.
7. No in-process or post-process objectionable emission or the effluent will be allowed, if the scheme furnished by the unit turns out to be defective in any actual experience
8. The Electricity Department will give only temporary connection and permanent connection to the unit will be given after verifying the consent granted by the Board, both under Water Act and Air Act.
9. Unit will raise the stack height of DG Set/Boiler as per Board's norms.
10. Unit will maintain proper logbook of Water meter/sub meter before/after commissioning.
11. That in the case of an industry or any other process the activity is located in an area approved and that in case the activity is sited in an residential or institutional or commercial or agricultural area, the necessary permission for siting such industry and process in an residential or institutional or commercial or agricultural area or controlled area under Town and Country Planning laws CLU or Municipal laws has to be obtained from the competent Authority in law permitting this deviation and be submitted in original with the request for consent to operate.

12. That there is no discharge directly or indirectly from the unit or the process into any interstate river or Yamuna River or River Ghaggar.
13. That the industry or the unit concerned is not sited within any prohibited distances according to the Environmental Laws and Rules, Notification, Orders and Policies of Central Pollution control Board and Haryana State Pollution Control Board.
14. That of the unit is discharging its sewage or trade effluent into the public sewer meant to receive trade effluent from industries etc. then the permission of the Competent Authority owing and operating such public sewer giving permission letter to his unit shall be submitted at time of consent to operate.
15. That if at any time, there is adverse report from any adjoining neighbor or any other aggrieved party or Municipal Committee or Zila Parishad or any other public body against the unit's pollution; the Consent to Establish so granted shall be revoked.
16. That all the financial dues required under the rules and policies of the Board have been deposited in full by the unit for this Consent to Establish.
17. In case of change of name from previous Consent to Establish granted, fresh Consent to Establish fee shall be levied.
18. Industry should adopt water conservation measures to ensure minimum consumption of water in their Process. Ground water based proposals of new industries should get clearance from Central Ground Water Authority for scientific development of previous resource.
19. That the unit will take all other clearances from concerned agencies, whenever required.
20. That the unit will not change its process without the prior permission of the Board.
21. That the Consent to Establish so granted will be invalid, if the unit falls in Aravali Area or non conforming area.
22. That the unit will comply with the Hazardous Waste Management Rules and will also make the non-leachate pit for storage of Hazardous waste and will undertake not to dispose off the same except for pit in their own premises or with the authorized disposal authority.
23. That the unit will submit an undertaking that it will comply with all the specific and general conditions as imposed in the above Consent to Establish within 30 days failing which Consent to Establish will be revoked.
24. That unit will obtain EIA from MoEF, if required at any stage.
25. In case of unit does not comply with the above conditions within the stipulated period, Consent to Establish will be revoked.
26. That unit will obtain consent to operate from the board before the start of product activity.

Specific Conditions

Other Conditions :

1. Unit will not generate and discharge trade effluent without prior permission of the Board and will provide septic tank/soak pit for treatment of domestic effluent discharge of 800 litres/day.
2. Unit will provide adequate stack height as per norms and Acoustic enclosures on DG Set.
3. Unit will provide adequate APCM with adequate stack on powder coating process as per scheme submitted to achieve prescribed standards Under EPA Rules, 1986.
4. Unit will provide proper sampling arrangements on their stack.
5. Unit will comply with Hazardous and Other Wastes (Management & Transboundary Movement) Rules, 2016.
6. The CTE so granted is valid in case the site falls in the area for which NOC has been granted by Town and country Planning Deptt. vide memo no. DTP(E)PKL-2018/NOC/262 dated 07.06.2018 for land measuring 6 kanal 8 marla in khasra no. 12//11/1 Hadbast No. 211 of village Kazimpur, Tehsil Raipur Rani, District Panchkula and will become invalid in case, at any stage, site is found existing in Residential or non-confirming area or controlled area declared by T&CP Deptt.
7. Unit will obtain prior CTO even starting before trial production.
8. Unit will comply Construction and Demolition Waste Management Rules, 2016 notified by MoEF & CC, Govt. of India on 29.03.2016.
9. The CTE so granted is valid for production/installed capacity of Curtain Pipes (4500 pcs /day) as mentioned in the application form and for investment cost of Rs. 185.89 lac as per CA certificate issued by M/s Jain Sharma and Chawla CAs issued on 04.07.2018.
10. Unit will not use pet coke/furnace oil in view of directions of Hon'ble Supreme Court of India.

VINAY GAUTAM

Digitally signed by VINAY
GAUTAM
Date: 2018.07.09 13:41:27 +05'30'

Regional Officer, Panchkula

Haryana State Pollution Control Board.