



कार्यालय आधिशासी अभियन्ता, उरई खण्ड उ०प्र० जल निगम (ग्रामीण), उरई

Phone No. 05162-258025 Email Add:- eoraidiv@gmail.com

Letter no :-/

3194

/ काप - 79

/ 306

Date- 07/08/2022

To

The Divisional forest officer
Forest division orai

Subject: proposed forest land to be delivered laying of water distribution line along different roads, under Sala group of villages drinking water scheme of Jal Jeevan mission of govt of India, in district: -jalaun (Uttar Pradesh). Online proposed no. FP/UP/WATER/155109/2022.

Reference: Govt. of India, ministry of Environment, Forest & climate Change integrated regional office LUCKNOW Letter NO. 8B/UP/08/155/2022/FC/280, Dated: 25.07.2022

Dear sir / Madam

SR.NO	Essential details sought	Replies
1	AS PER THE GOOGLE EARTH imageries dated 23.05.2018 plantation activity is visible on the proposed CA land Area. This needs clarification rectification	As per raised objection, CA digital map SOI toposheet and KML file have been prepared as per GPS coordinates provide by DFO and as per the google earth imageries dated 23.05.2018 trench of soil work seen no plantation. Proposed land is totally open
02	NOCs from concerned departments (NHAI / PWD, Irrigation, etc.) needs to be submitted.	As per the objection, raised NOC from PWD and NHAI departments attached
03	Whether laying of water pipeline is in existing ROWs within the diverted forest area or not? This needs clarification in respect of exemption in CA for area proposed for diversion in jalaun district.	YES, the proposed water pipe line is being laid in the existing ROW within the diverted forest area.
04	The size of trench for laying of underground pipeline within existing ROWs is not mentioned. This needs clarification in respect of exemption in CA area proposed for diversion in jalaun district	As per raised objection, Size of the trench for laying of underground pipeline within existing ROWs is 1X1 m.

उरई
जल
07/09/22
सांम 4:30
वजे

↓

Authorized Signatory

UP Jal Nigam (Rural), Orai

