

CHECK LIST SERIAL NUMBER-09

Full Title of the Project: Diversion of **0.2484 Hectare** of forest land for erection of Tower No: 28 and gantry for loop in loop out arrangement in respect of proposed 132 KV double circuit EHV transmission line from Village- Palauhra (Tehsil-Jawali) to proposed 132 KV Sub Station site at Fatehpur, Distt- Kangra (HP) in favor of Additional Superintending Engineer, 220 KV Sub Station (ES) Division, HPSEB Ltd. Jassure within the jurisdiction of Nurpur Forest Division, Distt. Kangra (HP).

File No: _____

Date of Proposal: _____

(b) JUSTIFICATION FOR LOCATING THE PROJECT IN FOREST AREA.


HPSEBL has the proposal for up gradation of existing 33/11 KV, 2X3.15 MVA Sub Station at Fatehpur into 132/33 KV, 2X 16 MVA capacity. Stage-1 approval of the forest land measuring 0.9250 Hectare for the up gradation of existing Substation has already been granted by the MOEF (GOI) as intimated vide letter No: -9-HPB/707/2014-CHA/224 Dated: -11-05-2015.


The electricity power to the proposed Substation will be fed through proposed 132 KV double circuit EHV transmission line originating from Village- Palauhra, Tehsil- Jawali (*Tapping point of existing 132 KV D/C EHV transmission line from Jassure to Dehra, Ckt- No: 2*) to proposed Substation site at Fatehpur.

For the erection of Tower No: 28 and gantry for loop in loop out arrangement in respect of above mentioned line at Fatehpur, forest land measuring 0.2484 Hectares is urgently required to be diverted. The forest land proposed for diversion is adjoining proposed 132 KV switchyard of Substation and moreover is in line with the line route.

Due to the reasons as explained above no any alternate piece of land could be selected for the project.

Countersigned


Divisional Forests Officer
Nurpur Forest Division
Divisional Forest Officer
Nurpur Forest Division


Addl. Superintending Engineer,
220 KV Sub Stn. (ES) Division,
HPSEBL Jassure.