

The consolidated condition wise compliance report for the diversion of Forest land for the subject work for laying of 220KV single phase DC line from proposed 400/220 KVSS Nirmal to the proposed 220/132 Kv Substation at Uttnoor is submitted to the Forest Divisional Officer, Nirmal as follows.

Sl. No.	Description of the Condition	Compliance												
1	2	3												
1.	The legal status of the forest land shall remain unchanged.	Will be complied with. An undertaking is submitted												
2.	Demarcation of the proposed forest area shall be carried out by erecting 4 feet high cement concrete pillars duly numbered at an interval of 20 meters by the User Agency in consultation with the DFO concerned at the project cost before the Stage II approval.	<p>The Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad has deposited an amount of 5,68,000/- (part of Rs. 8,90,453/- with UTR No: SBINR52020060200131329 Dt: 02.06.2020) in favour of Forest Divisional Officer, Nirmal PD A/c. No. 29930100016819, IFSC Code BARB0NIRMAL, Bank of Baroda, Nirmal branch for demarcation of the area by concrete pillars.</p> <table border="1"> <thead> <tr> <th>Sl. No</th> <th>Item</th> <th>Amount (in Rs.)</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Construction of 26 Nos RCC Big pillars @ 10000/-</td> <td>2,60,000/-</td> </tr> <tr> <td>2</td> <td>Construction of 280 Nos RCC small pillars at an interval of 20 mts @ 1100/-</td> <td>3,08,000/-</td> </tr> <tr> <td colspan="2">Total :</td><td>5,68,000/-</td></tr> </tbody> </table>	Sl. No	Item	Amount (in Rs.)	1.	Construction of 26 Nos RCC Big pillars @ 10000/-	2,60,000/-	2	Construction of 280 Nos RCC small pillars at an interval of 20 mts @ 1100/-	3,08,000/-	Total :		5,68,000/-
Sl. No	Item	Amount (in Rs.)												
1.	Construction of 26 Nos RCC Big pillars @ 10000/-	2,60,000/-												
2	Construction of 280 Nos RCC small pillars at an interval of 20 mts @ 1100/-	3,08,000/-												
Total :		5,68,000/-												
3	The State Forest Department shall carryout Compensatory Afforestation (CA) and its maintenance over 19.60 ha of degraded forest area in Compt No 148 of Kadamba RF of Pothepally Beat, Checkwal Section, Penchikalpet Range of Kagaznagar Division and 8.40 ha of degraded forest area in Compt No 08 of Kaddam RF of Kowta (S) Beat, Sonala Section, Boath Range of Echoda Division , at the cost of the User Agency.	<table border="1"> <thead> <tr> <th>Sl No</th> <th>Item</th> <th>Amount in Rs.</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Compensatory Afforestation (CA) in 19.60 ha DFL</td> <td>Rs. 1,37,84,724/-</td> </tr> </tbody> </table> <p>The Superintending Engineer, OMC Circle, Tstranco, Adilabad has deposited an amount of Rs.1,37,84,724/- (part of Rs. 4,18,58,370/- with UTNR No. SBINR52020060200130467 Dt:02.06.2020). towards CA scheme, into the account of TELANGANA STATE Ad-hoc CAMPA, New Delhi against the above Project. Against the challan generated.</p>	Sl No	Item	Amount in Rs.	1	Compensatory Afforestation (CA) in 19.60 ha DFL	Rs. 1,37,84,724/-						
Sl No	Item	Amount in Rs.												
1	Compensatory Afforestation (CA) in 19.60 ha DFL	Rs. 1,37,84,724/-												
4	The degraded forest land identified for CA and CA scheme shall not be changed without the prior approval of the Central Government.	Will be complied with. An Undertaking is submitted.												
5	The State Forest Department shall certify that no plantation / afforestation activities was taken up under any scheme, over the degraded forest area identified and accepted for raising compensatory afforestation;	Will be complied with. An Undertaking is submitted.												

	<p>6 The cost of compensatory afforestation as per the CA scheme and cost of survey, demarcation and erection of permanent pillars if required on the CA lance shall be deposited in advance with the Forest Department by the project authority. The CA will be maintained for 10 years.</p>	<table border="1" data-bbox="865 85 1522 273"> <thead> <tr> <th>Sl No</th><th>Item</th><th>Amount in Rs.</th></tr> </thead> <tbody> <tr> <td>1</td><td>Compensatory Afforestation (CA) in 19.60 ha DFL</td><td>Rs. 1,37,84,724/-</td></tr> </tbody> </table> <p>The Superintending Engineer, OMC Circle, Tstranco, Adilabad has deposited an amount of Rs.1,37,84,724/- (part of Rs. 4,18,58,370/- with UTNR No. SBINR52020060200130467 Dt:02.06.2020), towards CA scheme, into the account of TELANGANA STATE Ad-hoc CAMPA, New Delhi against the above Project. Against the challan generated.</p>	Sl No	Item	Amount in Rs.	1	Compensatory Afforestation (CA) in 19.60 ha DFL	Rs. 1,37,84,724/-			
Sl No	Item	Amount in Rs.									
1	Compensatory Afforestation (CA) in 19.60 ha DFL	Rs. 1,37,84,724/-									
7	<p>The State Government shall charge the Net Present Value of the diverted forest land measuring 13.9887 ha from User Agency as per the orders of the Hon'ble Supreme Court dated 28.03.2008 and 09.05.2008 in IA Nos. 826 in 566 with related IA's in Writ Petition (Civil) No.202/1995.</p>	<table border="1" data-bbox="865 526 1522 748"> <thead> <tr> <th>Sl No</th><th>Item</th><th>Amount in Rs.</th></tr> </thead> <tbody> <tr> <td>1</td><td>NPV charges @ 6.26 Lakhs per Ha. (9.7887 Ha. x 6.26 Lakhs = Rs.33,72,600/-)</td><td>Rs. 61,27,726/-</td></tr> </tbody> </table> <p>The Superintending Engineer OMC Circle, Tstranco Adilabad has uploaded the demand notice at forestsclearance.nic.in and generate challan through the Ministry's Website, after approval by Nodal officer and then deposited the above amount Rs. 61,27,726/- (part of Rs. 4,18,58,370/- with UTNR No. SBINR52020060200130467 Dt:02.06.2020) against the challan generated.</p>	Sl No	Item	Amount in Rs.	1	NPV charges @ 6.26 Lakhs per Ha. (9.7887 Ha. x 6.26 Lakhs = Rs.33,72,600/-)	Rs. 61,27,726/-			
Sl No	Item	Amount in Rs.									
1	NPV charges @ 6.26 Lakhs per Ha. (9.7887 Ha. x 6.26 Lakhs = Rs.33,72,600/-)	Rs. 61,27,726/-									
8	<p>Additional amount of Act Present Value (NPV) of the diverted forest land if any, becoming due after revision of the same by the Hon'ble Supreme Court of India in future, shall be charged by the State Government from the User Agency. The User Agency shall furnish an undertaking to this effect;</p>	: Will be complied with. An Undertaking is submitted.									
9	<p>All the funds received from the User Agency) under the project shall be transferred/ deposited to CAMPA fund only through e-portal (https://parivesh.nic.in/);</p>	: As per the demand notice issued by FDO Nirmal an amount of Rs. 2,38,79,170.00 (part of Rs. 4,18,58,370/- with UTNR No. SBINR52020060200130467 Dt:02.06.2020) deposited into Adhoc CAMPA account towards NPV, CA raising and maintenance for 10 years.									
10	<p>The User Agency shall restrict the felling of trees to the minimum in the diverted width of 35 meters of the forest land and the trees shall be felled under the strict supervision of the State Forest Department and the cost of felling of trees shall be deposited by the User Agency with the State Forest Department;</p>	<p>: Will be complied with. An Undertaking is submitted. The Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad has deposited an amount of Rs.3,22,453/- (part of Rs. 8,90,453/- with UTR No. SBINR52020060200131329 Dt: 02.06.2020)- in favour of Forest Divisional Officer, Echoda PD A/c. No. 29930100016819, IFSC Code BARB0NIRMAL, Bank of Baroda, Nirmal branch with UTNR No. Dt:</p> <table border="1" data-bbox="886 1950 1506 2097"> <thead> <tr> <th>Sl. No</th><th>Item</th><th>Amount (in Rs.)</th></tr> </thead> <tbody> <tr> <td>1.</td><td>Extraction of tree growth</td><td>3,22,453/-</td></tr> <tr> <td></td><td>Total :</td><td>3,22,453/-</td></tr> </tbody> </table>	Sl. No	Item	Amount (in Rs.)	1.	Extraction of tree growth	3,22,453/-		Total :	3,22,453/-
Sl. No	Item	Amount (in Rs.)									
1.	Extraction of tree growth	3,22,453/-									
	Total :	3,22,453/-									

	<p>11 The User Agency in consultation with the State Forest Department shall prepare and implement a detailed scheme for creation and maintenance of plantation of dwarf species (preferably medicinal plants) in the right of way under the transmission line at its cost.</p>	<table border="1" data-bbox="846 101 1509 282"> <thead> <tr> <th>Sl No</th><th>Item</th><th>Amount in Rs.</th></tr> </thead> <tbody> <tr> <td>1</td><td>Raising and Maintenance for (10) years dwarf species</td><td>Rs. 39,66,720/-</td></tr> </tbody> </table> <p>The Superintending Engineer OMC Circle transco, Adilabad has uploaded the demand notice at forestsclearance.nic.in and generated challan through the Ministry's Website, after approval by Nodal officer and then deposited the above amount Rs. 39.66.720/- (part of Rs. 4.18,58,370/- with UTNR No. SBINR52020060200130467 Dt:02.06.2020) against the challan generated.</p>	Sl No	Item	Amount in Rs.	1	Raising and Maintenance for (10) years dwarf species	Rs. 39,66,720/-
Sl No	Item	Amount in Rs.						
1	Raising and Maintenance for (10) years dwarf species	Rs. 39,66,720/-						
12	<p>The User Agency at its cost shall provide bird deflectors, which are to be fixed on the upper conductor of the transmission line at suitable intervals to avoid bird hits.</p>	<p>Will be complied with An Undertaking is submitted.</p>						
13	<p>The User Agency shall comply with the guidelines issued by the Ministry for laying transmission lines through forest areas.</p>	<p>Will be complied with.AnUndertaking is submitted.</p>						
14	<p>The layout plan of the proposal shall not be changed without prior approval of the Central Government.</p>	<p>will be complied with.An Undertaking is submitted.</p>						
15.	<p>Sufficient fire wood, preferably the alternate fuel, shall be provided by the User Agency to the labourer after purchasing the same from the State Forest Department or the Forest Development Corporation or any other legal source of alternate fuel. No labour camp shall be established on the forest land.</p>	<p>Will be complied with.AnUndertaking is submitted.</p>						
16.	<p>No additional or new path will be constructed inside the forest area for the transportation of construction materials for execution of the project work.</p>	<p>will be complied with.An Undertaking is submitted.</p>						
17.	<p>The compliance report shall be uploaded on e-portal (https://parivesh.nic.in/)</p>	<p>will be complied with.AnUndertaking is submitted.</p>						
18.	<p>The forest land proposed for diversion shall under no circumstances be transferred / sublet to any other agency, department or person without prior approval of the Central Government.</p>	<p>will be complied with.An Undertaking is submitted.</p>						
19.	<p>Disturbance shall be kept minimal by creating labour camps outside the forest area as far as possible and it will be the responsibility of the User Agency to ensure that the labourers & staff engaged in execution of work do not destruct nearby forest flora & fauna.</p>	<p>will be complied with.An Undertaking is submitted.</p>						
20.	<p>The trees on strips would have to be felled but after stringing work is completed, natural regeneration will be allowed to come up. Future pollarding / pruning of trees will be done with</p>	<p>will be complied with.An Undertaking is submitted.</p>						

	the permission of the local Forest Officer, wherever necessary for the maintenance of the transmission lines.	
21.	During construction of transmission line, pollarding / pruning of trees located outside the 35 meters width of the strips whose branches / parts infringe with conductor stringing, shall be permitted to the extent necessary, as may be decided by the local Forest Officer.	Will be complied with.An Undertaking is submitted.
22.	In case the portion of the transmission line to be constructed is located in hilly areas, where adequate clearance is already available, trees shall not be cut.	will be complied with.An Undertaking is submitted.
23.	All efforts shall be taken to minimize the felling of trees and the State Forest Department shall be carry out translocation of the trees wherever feasible at the cost of the User Agency.	will be complied with.An Undertaking is submitted.
24.	The total forest area utilized for the project shall not exceed 13.9887 ha and the forest area diverted shall not be used for any purpose other than those shown in the diversion proposal. The User Agency shall furnish an undertaking to this effect.	will be complied with.An Undertaking is submitted.
25.	The approval under FCA, 1980 is subject to the clearance under all other Acts, Rules, Guidelines, Regulations and Court Orders applicable to such project.	will be complied with.An Undertaking is submitted.
26.	Any other conditions that the Central Government or DDG(Central) of Regional Office, Chennai may impose from time to time in the interest of afforestation, conservation and management of flora and fauna in the area, shall be complied by the User Agency.	will be complied with.An Undertaking is submitted.
27.	In the event of failure to comply with any of the above conditions the User Agency is liable for penal action provision under FCA, 1980 and guidelines madeunder.	will be complied with.An Undertaking is submitted.-


 Superintending Engineer, (FAC)
 Adilabad OMC Circle, TSTRANSCO,
 Mancherial.

Undertaking to Condition-1

I hereby undertake and confirm that, the legal status of the diverted forest land will remain unchanged in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- 4

I hereby undertake the following, in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

Identified CA land and approved CA scheme shall not be changed without the prior approval of the Central Government.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- 8

I hereby undertake the following, in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

Additional amount of Act Present Value (NPV) of the diverted forest land if any, becoming due after revision of the same by the Hon'ble Supreme Court of India in future, shall be charged by the State Government from the User Agency. The User Agency shall furnish an undertaking to this effect.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- 10

I hereby undertake the tree felling in the proposed forest area will be carried out wherever with the prior permission of the Forest Divisional Officer concerned, in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to carry out planned muck disposal condition-(12)

I hereby undertake the following in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.

The User Agency at its cost shall provide bird deflectors, which are to be fixed on the upper conductor of the transmission line at suitable intervals to avoid bird hits


Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- 13

I hereby undertake the following, in respect Diversion of 9.7887 ha of forest land in Nirmal for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

The User Agency shall comply with the guidelines issued by the Ministry for laying transmission lines through forest areas.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (14), (18) , (23) & (24)

I hereby undertake the following, in respect of Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 KV Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.

- a) The layout plan of the proposal shall not be changed without the prior approval of the, Central Government.
- b) The forest land proposed for diversion shall under no circumstances be transferred or sublet to any other agency, department or person without prior approval of the Central Government.
- c) All efforts shall be taken to minimize the felling of trees and the state Forest Department shall translocate the trees, wherever feasible instead of felling at the cost of user agency.
- d) The total forest area utilized for the project will not exceed 9.7887 ha and the forest area diverted will not be used for any purpose other than those shown in the diversion proposal.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (15)

I hereby undertake the following, in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

Sufficient fire wood, preferably the alternate fuel, shall be provided by the User Agency to the labourer after purchasing the same from the State Forest Department or the Forest Development, Corporation or any other legal source of alternate fuel. No labour camp shall be established on the forest land.


Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (16)

I hereby undertake the following, in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

No additional or new path will be constructed inside the forest area for the transportation of construction materials for execution of the project work.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (17)

I hereby undertake the following, in respect Diversion of 9.7887 ha of forest land in Nirmal ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO .Adilabad.

The compliance report shall be uploaded on e-portal (<https://parivesh.nic.in/>)



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to condition-(19)

I hereby undertake to ensure minimal disturbance by creating labour camps outside the forest area as far as possible and it will be the responsibility of the UA to ensure that the labourers & staff engaged in execution of work fob not destruct nearby forest flora & fauna, in respect of Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 KV Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.




Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (20)

I hereby undertake the following, in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.


The trees on strips would have to be felled but after stringing work is completed, natural regeneration will be allowed to come up. Future pollarding / pruning of trees will be done with the permission of the local Forest Officer, wherever necessary for the maintenance of the transmission lines.


Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (21)

I hereby undertake the following, in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

During construction of transmission line, pollarding / pruning of trees located outside the 35 meters width of the strips whose branches / parts infringe with conductor stringing, shall be permitted to the extent necessary, as may be decided by the local Forest Officer.


Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (22)

I hereby undertake the following, in respect Diversion of 9.7887 ha of forest land in Nirmal Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

In case the portion of the transmission line to be constructed is located in hilly areas, where adequate clearance is already available, trees shall not be cut.


Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

FORM-I
(For Linear projects)
Government of Telangana
Office of the District Collector, Nirmal

No.E/1093/2018,

Dated: 27.01.2020

TO WHOM SO EVER IT MAY CONCERN

In compliance of the Ministry of Environment and Forests (MoEF), Government of India letter No.11-9/98-FC (pt.), dated: 3rd August, 2009 wherein the MoEF issued guidelines on submission of evidences for having initiated and completed the process of settlement of rights under the Scheduled Tribes and Other Traditional Forest Dwellers (Recognition of Forest Rights) Act, 2006 ('FRA; for short) on the forest land proposed to be diverted for non-forest purposes read with MoEF's letter, dated: 5th February, 2013 wherein MoEF issued certain relaxation in respect of linear projects, it is certified that 9.7887 Ha. of forest land proposed to be diverted in favour of Superintending Engineer, OMC, Adilabad Circle, TS TRANSCO for construction of 220 KV DC line from 400/220 KV SS Nirmal to the proposed 220/132 KV SS Utnoor (Adilabad District) under Thermal Power Transmission Scheme for Evacuation of Power from 3x600 MW units in Nirmal District falls within the jurisdiction of Sarangapur Gram Panchayat in Sarangapur Revenue Mandal.

It is further certified that:

- a) The complete process for identification and settlement of Rights under the FRA has been carried out for the entire 9.7887 Ha. of forest area proposed for diversion in Compt. Nos. 1018 & 1020, Jam Forest Block notified U/s 15 of AP Forest Act, 1967, Nirmal Forest Division. A copy of records of all consultations and meetings of the Forest Rights Committee (s), Gram Sabha (s), Sub-Division Level Committee (s) and the District Level Committee are enclosed as Annexure -I to Annexure-III.
- b) The diversion of forest land for facilities managed by the Govt. as required Under Section 3 (2) of the FRA have been completed and the Grama Sabhas have given their consent to it.
- c) The proposals does not involve recognized right of Primitive Tribal Groups and Pre-Agricultural Communities.

"Affected"

Executive Engineer
Construction Division
TS Transco, Adilabad

U.P.
(Mr. Prashanthi, IAS)
Chairperson, District Level Committee under FRA
& District Collector, Nirmal
District Collector
Nirmal

AGENCY COPY

NEFT / RTGS CHALLAN for Ad-HOC CAMPA
Date : 02-06-2020

Agency Name.	TSTRANSCO
Application No.	6427295071
MoEF/SG File No.	4-TSC162/2019-CHN
Location.	Telangana
Address.	SE, OMC Circle, TSTRANSCO, 132/33 KV SS, Near GS Estate, AdilabadAdilabad
Amount(in Rs)	41858370/-

Amount in Words :Four Crore Eighteen Lakh Fifty-Eight Thousand Three Hundred and Seventy Rupees Only

NEFT/RTGS to be made as per following details;

Beneficiary Name:	Telangana CAMPA
IFSC Code:	CORP0000371
Pay to Account No.	155706427295071 Valid only for this challan amount.
Bank Name & Address:	Corporation Bank Lodhi Complex Branch, Block 11,CGO Complex, Phase I, Lodhi Road, New Delhi -110003

- This Challan is strictly to be used for making payment to CAMPA by NEFT/RTGS only
- This challan is valid only for seven days.

BANK COPY

NEFT / RTGS CHALLAN for Ad-HOC CAMPA
Date : 02-06-2020

Agency Name.	TSTRANSCO
Application No.	6427295071
MoEF/SG File No.	4-TSC162/2019-CHN
Location.	Telangana
Address:	SE, OMC Circle, TSTRANSCO, 132/33 KV SS, Near GS Estate, Adilabad Adilabad
Amount(in Rs)	41858370/-

Amount in Words :Four Crore Eighteen Lakh Fifty-Eight Thousand Three Hundred and Seventy Rupees Only

NEFT/RTGS to be made as per following details;

Beneficiary Name:	Telangana CAMPA
IFSC Code:	CORP0000371
Pay to Account No.	155706427295071 Valid only for this challan amount.
Bank Name & Address:	Corporation Bank Lodhi Complex Branch, Block 11,CGO Complex, Phase I, Lodhi Road, New Delhi -110003

- This Challan is strictly to be used for making payment to CAMPA by NEFT/RTGS only
- This challan is valid only for seven days.

After making successful payment, User Agencies may send a line of confirmation through
Email: helpdeskcampainfo@corpbank.co.in

UTR NO-SB/NR 52020060200132457

User ID No.	6363725	V. GOPALA KRISHNA
Queue No.		
SBI 20124 - 2 JUN 2020		MANC HERIAL MAIN
CASH/TRANSFER		
Journal No.		Initials
Checker ID No.		

gopala

"affected"
gopala
Executive Engineer
Construction Division
TS Transco, Adilabad



STATE BANK OF INDIA

Branch Mava
Date 2-09-2020

Received _____
from _____

For remittance of NEFT/RTGS by way of (i) Transfer(only NEFT), (ii) Cash (only NEFT), (iii) Cheque (NEFT/RTGS) using cheque No. 416455

avouring Telangana CAMP

AcNo. 155706427295031

IFSC Code: CORP0000371

Beneficiary Bank & Branch Corporation Bank
New Delhi

Amount₹ : 418 58.370-5

Bank's Charges ₹

Total ₹ _____.

(Rupees four crore eight hundred fifty
Eight thousand Four hundred and Seven only)

For office Use.

UTR No. _____ Branch Manager

Affected
Issue
Executive Engineer
Construction Division
TS Transco, Adilabad

SBINR 5202006202130057

User ID No.	6363725	V. GOPALA
Queue No.		KRISHNA
SBI - 2 JUN 2020		MANC
20124	CASH/TRANSFER	HERAL
Journal No.		MAIN
Checker ID No.		BRANCH

Initials

"Attested"

gjse

Executive Engineer
Construction Division
TS Transco, Adilabad



STATE BANK OF INDIA

Branch Male
Date 2/6/2020

Received 10/01/05
from


For remittance of NEFT/RTGS by way of (i) Transfer (only NEFT), (ii) Cash (only NEFT), (iii) Cheque (NEFT/RTGS) using cheque No. 1441

favouring forest growing after
Nielsen

A/c No. 299 ~~3500000000~~

~~Beneficiary Bank & Branch _____~~ ~~Branch _____~~ ~~Branch _____~~ ~~Branch _____~~
~~Beneficiary _____~~ ~~Beneficiary _____~~ ~~Beneficiary _____~~ ~~Beneficiary _____~~

Bank's Charges ₹

For office Use 

UTR No. _____ Branch Manager

'Arrested'

glove

Executive Engineer,
Construction Division
TS Transco, Adilabad



TRANSMISSION CORPORATION OF TELANGANA LIMITED

NOTIFICATION

The Transmission Corporation of Telangana Limited. **Name of the works:** In-principa approval of Diversion of 13.9887 ha (Nirmal - 9.7887 ha and Echoda- 4.20 ha (revised from 8.0972 ha) of Forest land for Erection of 220 KV DC Line from 400/220 KV SS Nirmal to the proposed 200/132 KV SS Utnoor in Nirmal District under Thermal Power Transmission Scheme for Evacuation of Power from SCCL Jaipur in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad has been accorded by the Ministry of Environment, Forest & Climate change, Government of India, Regional Office, Chennai vide: F.No. 4-TSC 162/2019-CHN/410, Dt: 22.04.2020. **NOTE:** Further details please visit ministry's website: <http://www.parivesh.nic.in>against the proposal No: FP/TG/TRANS/27295/2017.

R.O.No.05/20

Sd/- CHIEF ENGINEER, CONSTRUCTION

"Affected"
glo

Executive Engineer
Construction Division
TS Transco, Adilabad

భూవ్యవస్థ కార్బింగ్ ఆఫ్ తెలంగాణ లిమిటెడ్



భూవ్యవస్థ కార్బింగ్ ఆఫ్ తెలంగాణ లిమిటెడ్, మహిల యొక్క పేరు: మాచరింటెండింగ్ ఇంజినీర్, బెంగి వర్కర్, బెంగి భూవ్యవస్థ ఆదిలాబాద్ వారి పేరున ఎవసిపిఎల్ ప్లాటర్ నుండి ఎద్దుత తరలించుట కొరకు ధర్మల వివర భూవ్యవస్థ వథకము క్రింద నిర్మల జల్లాలో ప్రతిపాదిత 200/132 కెవి ఎవసిపి ఉట్టుయు మండి 400/220 కెవి ఎవసిపి నిర్మల మండి 220 కెవి డిపి లైస్యుట్ కొరకు ఆటవీ భూమి యొక్క 13.9887 పొక్కార్ (నిర్మల - 9.7887 పొక్కార్ మరియు ఇచ్చేర్ - 4.20 పొక్కార్) (8.0972 పొక్కార్ మండి వివరించబడినది) యొక్క మార్గింది యొక్క ఆమోదము ప్రధానంగా వర్యావరణ, ఆటవీ & వాతావరణ మార్పు మంత్రిత్వ శాఖ, భారత ప్రభుత్వం, ప్రాంతియ కార్బింగ్ ము, చెన్నె వారిచే ఎఫ్ పెం.4-బెంగి నెం.162/2019-సిప్పెంచువు/410, తేది: 22.04.2020 ప్రకారం ఇవ్వబడినది. శమిక: తదునరి వివరాల కొరకు మంత్రిత్వ శాఖ యొక్క వెబ్సైట్లలో ప్రపాజల్ పెం: ఎఫ్పి/లెజి/భూవ్య/27295/2017 ను వెబ్సైట్ <http://www.parivesh.nic.in> లో మాడవచ్చుము.

అర్.పి. పెం.05/20

పం/ - చిఫ్ ఇంజినీర్, విర్మలం

"Affected"

[Signature]

Executive Engineer
Construction Division
TS Transco, Adilabad

The consolidated condition wise compliance report for the diversion of Forest land for the subject work for laying of 220KV single moose DC line from proposed 400/220 KVSS Nirmal to the proposed 220/132 Kv Substation at Utnoor is submitted to the District Forest Officer, Adilabad as follows.

Sl. No.	Description of the Condition	Compliance													
		2	3												
1.	The legal status of the forest land shall remain unchanged.		Will be complied with. An undertaking is submitted												
2.	Demarcation of the proposed forest area shall be carried out by erecting 4 feet high cement concrete pillars duly numbered at an interval of 20 meters by the User Agency in consultation with the DFO concerned at the project cost before the Stage II approval.		The Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad has deposited an amount of 2,12,000/- (part of 2,74,000/- deposited into SBI account on Dt: 02.06.2020) in favour of Forest Divisional Officer, Echoda PD A/c. No. 37128426300, IFSC Code SBIN0020284, SBI, Main branch, Echoda for demarcation of the area by concrete pillars.												
			<table border="1"> <thead> <tr> <th>Sl. No.</th> <th>Item</th> <th>Amount (in Rs.)</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Construction of 8 Nos RCC Big pillars @ 10000/-</td> <td>80,000</td> </tr> <tr> <td>2</td> <td>Construction of 120 Nos RCC small pillars at an interval of 20 mts @ 1100/-</td> <td>1,32,000</td> </tr> <tr> <td></td> <td>Total :</td> <td>2,12,000</td> </tr> </tbody> </table>	Sl. No.	Item	Amount (in Rs.)	1.	Construction of 8 Nos RCC Big pillars @ 10000/-	80,000	2	Construction of 120 Nos RCC small pillars at an interval of 20 mts @ 1100/-	1,32,000		Total :	2,12,000
Sl. No.	Item	Amount (in Rs.)													
1.	Construction of 8 Nos RCC Big pillars @ 10000/-	80,000													
2	Construction of 120 Nos RCC small pillars at an interval of 20 mts @ 1100/-	1,32,000													
	Total :	2,12,000													
3	The State Forest Department shall carryout Compensatory Afforestation (CA) and its maintenance over 19.60 ha of degraded forest area in Compt No 14b of Kadamba RF of Potheppally Beat, Checkwal Section, Penchikalpet Range of Kagaznagar Division and 8.40 ha of degraded forest area in Compt No 08 of Kaddam RF of Kowta (S) Beat, Sonala Section, Boath Range of Echoda Division , at the cost of the User Agency.		<table border="1"> <thead> <tr> <th>Sl No</th> <th>Item</th> <th>Amount in Rs.</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Compensatory Afforestation (CA) in 8.40 ha DFL</td> <td>Rs. 1,14,60,000/-</td> </tr> </tbody> </table> <p>The Superintending Engineer, OMC Circle, Tstranco, Adilabad has deposited an amount of Rs.1,14,60,000/- (part of Rs. 4,18,58,370/- with UTNR No.SBINR52020060200130467 Dt:02.06.2020), towards CA scheme, into the account of TELANGANA STATE Ad-hoc CAMPA, New Delhi against the above Project, Against the challan generated.</p>	Sl No	Item	Amount in Rs.	1	Compensatory Afforestation (CA) in 8.40 ha DFL	Rs. 1,14,60,000/-						
Sl No	Item	Amount in Rs.													
1	Compensatory Afforestation (CA) in 8.40 ha DFL	Rs. 1,14,60,000/-													
4	The degraded forest land identified for CA and CA scheme shall not be changed without the prior approval of the Central Government.		Will be complied with. An Undertaking is submitted.												
5	The State Forest Department shall certify that no plantation / afforestation activities was taken up under and scheme, over the degraded forest area identified and accepted for raising compensatory afforestation;														

6	The cost of compensatory afforestation as per the CA scheme and cost of survey, demarcation and erection of permanent pillars if required on the CA land shall be deposited in advance with the Forest Department by the project authority. The CA will be maintained for 10 years.	Will be complied with. An Undertaking is submitted.												
7	The State Government shall charge the Net Present Value of the diverted forest land measuring 13.9887 ha from User Agency as per the orders of the Hon'ble Supreme Court dated 28.03.2008 and 09.05.2008 in IA Nos. 826 in 566 with related IA's in Writ Petition (Civil) No.202/1995.	<table border="1" data-bbox="855 498 1516 708"> <thead> <tr> <th>Sl No</th> <th>Item</th> <th>Amount in Rs.</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>NPV charges @ 8.030 Lakhs per Ha. (4.20 Ha. x 8.030 Lakhs = Rs.33,72,600/-)</td> <td>Rs. 33,72,600/-</td> </tr> </tbody> </table> <p>The Superintending Engineer OMC Circle, Tstranco Adilabad has uploaded the demand notice at forestsclearance.nic.in and generate challan through the Ministry's Website, after approval by Nodal officer and then deposited the above amount of Rs. 33.72.600/- (part of Rs. Rs. 4,18,58,370/- with UTNR No. SBINR52020060200130467 Dt:02.06.2020) against the challan generated.</p>	Sl No	Item	Amount in Rs.	1	NPV charges @ 8.030 Lakhs per Ha. (4.20 Ha. x 8.030 Lakhs = Rs.33,72,600/-)	Rs. 33,72,600/-						
Sl No	Item	Amount in Rs.												
1	NPV charges @ 8.030 Lakhs per Ha. (4.20 Ha. x 8.030 Lakhs = Rs.33,72,600/-)	Rs. 33,72,600/-												
8	Additional amount of Act Present Value (NPV) of the diverted forest land if any, becoming due after revision of the same by the Hon'ble Supreme Court of India in future, shall be charged by the State Government from the User Agency. The User Agency shall furnish an undertaking to this effect;	Will be complied with. An Undertaking is submitted.												
9	All the funds received from the User Agency under the project shall be transferred/ deposited to CAMPA fund only through e-portal (https://parivesh.nic.in/);	Will be complied with. An Undertaking is submitted.												
10	The User Agency shall restrict the felling of trees to the minimum in the diverted width of 35 meters of the forest land and the trees shall be felled under the strict supervision of the State Forest Department and the cost of felling of trees shall be deposited by the User Agency with the State Forest Department;	<p>Will be complied with. An Undertaking is submitted.</p> <p>The Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad has deposited an amount of 62,000/- (part of Rs.2,74,000/- deposited into SBI account on Dt: 02.06.2020) - in favour of Forest Divisional Officer, Echoda PD A/c. No. 37128466300, IFSC Code SBIN0020284, SBI, Main branch, Echoda.</p> <table border="1" data-bbox="887 1867 1500 2041"> <thead> <tr> <th>Sl. No</th> <th>Item</th> <th>Amount (in Rs.)</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Extraction of tree growth</td> <td>52,000</td> </tr> <tr> <td>2</td> <td>Survey charges</td> <td>10,000</td> </tr> <tr> <td></td> <td>Total :</td> <td>62,000</td> </tr> </tbody> </table>	Sl. No	Item	Amount (in Rs.)	1.	Extraction of tree growth	52,000	2	Survey charges	10,000		Total :	62,000
Sl. No	Item	Amount (in Rs.)												
1.	Extraction of tree growth	52,000												
2	Survey charges	10,000												
	Total :	62,000												

Sl No	Item	Amount in Rs.			
11.	The User Agency in consultation with the State Forest Department shall prepare and implement a detailed scheme for creation and maintenance of plantation of dwarf species (preferably medicinal plants) in the right of way under the transmission line at its cost.	<table border="1"> <tr> <td>1</td> <td>Raising and Maintenance for (10) years dwarf species</td> <td>Rs. 31,46,600/-</td> </tr> </table> <p>The Superintending Engineer OMC Circle transco, Adilabad has uploaded the demand notice at forestsclearance.nic.in and generated challan through the Ministry's Website, after approval by Nodal officer and then deposited the above amount of Rs. 31,46,600/- (part of Rs. 4,18,58,370/- with UTNR No. SBINR52020060200130467 Dt:02.06.2020) against the challan generated.</p>	1	Raising and Maintenance for (10) years dwarf species	Rs. 31,46,600/-
1	Raising and Maintenance for (10) years dwarf species	Rs. 31,46,600/-			
12	The User Agency at its cost shall provide bird deflectors, which are to be fixed on the upper conductor of the transmission line at suitable intervals to avoid bird hits.	Will be complied with. An Undertaking is submitted.			
13	The User Agency shall comply with the guidelines issued by the Ministry for laying transmission lines through forest areas.	Will be complied with. An Undertaking is submitted.			
14	The layout plan of the proposal shall not be changed without prior approval of the Central Government.	Will be complied with. An Undertaking is submitted.			
15.	Sufficient fire wood, preferably the alternate fuel, shall be provided by the User Agency to the laborer after purchasing the same from the State Forest Department or the Forest Development Corporation or any other legal source of alternate fuel. No labor camp shall be established on the forest land.	Will be complied with. An Undertaking is submitted.			
16.	No additional or new path will be constructed inside the forest area for the transportation of construction materials for execution of the project work.	Will be complied with. An Undertaking is submitted.			
17.	The compliance report shall be uploaded on e-portal (https://parivesh.nic.in/)	Will be complied with. An Undertaking is submitted.			
18.	The forest land proposed for diversion shall under no circumstances be transferred / sublet to any other agency, department or person without prior approval of the Central Government.	Will be complied with. An Undertaking is submitted.			
19.	Disturbance shall be kept minimal by creating labor camps outside the forest area as far as possible and it will be the responsibility of the User Agency to ensure that the laborers & staff engaged in execution of work do not destruct nearby forest flora & fauna.	Will be complied with. An Undertaking is submitted.			
20.	The trees on strips would have to be felled but after stringing work is completed, natural regeneration will be allowed to come up. Future pollarding / pruning of trees will be done with	Will be complied with. An Undertaking is submitted.			

	the permission of the local Forest Officer, wherever necessary for the maintenance of the transmission lines.	
21.	During construction of transmission line, pollarding / pruning of trees located outside the 35 meters width of the strips whose branches / parts infringe with conductor stringing, shall be permitted to the extent necessary, as may be decided by the local Forest Officer.	Will be complied with. An Undertaking is submitted.
22.	In case the portion of the transmission line to be constructed is located in hilly areas, where adequate clearance is already available, trees shall not be cut.	Will be complied with. An Undertaking is submitted.
23.	All efforts shall be taken to minimize the felling of trees and the State Forest Department shall be carry out translocation of the trees wherever feasible at the cost of the User Agency.	Will be complied with. An Undertaking is submitted.
24.	The total forest area utilized for the project shall not exceed 13.9887 ha and the forest area diverted shall not be used for any purpose other than those shown in the diversion proposal. The User Agency shall furnish an undertaking to this effect.	Will be complied with. An Undertaking is submitted.
25.	The approval under FCA, 1980 is subject to the clearance under all other Acts, Rules, Guidelines, Regulations and Court Orders applicable to such project.	Will be complied with. An Undertaking is submitted.
26.	Any other conditions that the Central Government or DDG(Central) of Regional Office, Chennai may impose from time to time in the interest of afforestation, conservation and management of flora and fauna in the area, shall be complied by the User Agency.	Will be complied with. An Undertaking is submitted.
27.	In the event of failure to comply with any of the above conditions the User Agency is liable for penal action provision under FCA, 1980 and guidelines made under.	Will be complied with. An Undertaking is submitted.-



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to Condition-1

I hereby undertake and confirm that, the legal status of the diverted forest land will remain unchanged in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.




Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- 4 & 6

I hereby undertake the following, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

Identified CA land and approved CA scheme shall not be changed without the prior approval of the Central Government.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- 8

I hereby undertake the following, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

Additional amount of Act Present Value (NPV) of the diverted forest land if any, becoming due after revision of the same by the Hon'ble Supreme Court of India in future, shall be charged by the State Government from the User Agency. The User Agency shall furnish an undertaking to this effect.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to pay additional amount of Net Present Value (NPV)- conditions-(9)

I hereby undertake to pay the additional amount of Net Present Value (NPV) of the diverted forest land if any, becoming due after revision of the same by the Hon'ble Supreme Court of India in future.

I also hereby undertake to pay the differential NPV amount, if any, due to escalation or revision of NPV, as and when demanded by the Forest Department in respect of Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- 10

I hereby undertake the tree felling in the proposed forest area will be carried out wherever with the prior permission of the Forest Divisional Officer concerned, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to carry out planned muck disposal condition-(12)

I hereby undertake the following in respect Diversion of 4.2 ha of forest land in Echoda Division for erection proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.

The User Agency at its cost shall provide bird deflectors, which are to be fixed on the upper conductor of the transmission line at suitable intervals to avoid bird hits


Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- 13

I hereby undertake the following, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

The User Agency shall comply with the guidelines issued by the Ministry for laying transmission lines through forest areas.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (14), (18) , (23) & (24)

I hereby undertake the following, in respect of Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 KV Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.

- a) The layout plan of the proposal shall not be changed without the prior approval of the Central Government.
- b) The forest land proposed for diversion shall under no circumstances be transferred or sublet to any other agency, department or person without prior approval of the Central Government.
- c) All efforts shall be taken to minimize the felling of trees and the state Forest Department shall translocate the trees, wherever feasible instead of felling at the cost of user agency.
- d) The total forest area utilized for the project will not exceed 4.2 ha and the forest area diverted will not be used for any purpose other than those shown in the diversion proposal.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (15)

I hereby undertake the following, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

Sufficient fire wood, preferably the alternate fuel, shall be provided by the User Agency to the labourer after purchasing the same from the State Forest Department or the Forest Development Corporation or any other legal source of alternate fuel. No labour camp shall be established on the forest land.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (16)

I hereby undertake the following, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO .Adilabad.

No additional or new path will be constructed inside the forest area for the transportation of construction materials for execution of the project work.


Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (17)

I hereby undertake the following, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

The compliance report shall be uploaded on e-portal (<https://parivesh.nic.in/>)



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to condition-(19)

I hereby undertake to ensure minimal disturbance by creating labour camps outside the forest area as far as possible and it will be the responsibility of the UA to ensure that the labourers & staff engaged in execution of work fob not destruct nearby forest flora & fauna, in respect of Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 KV Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.


Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (20)

I hereby undertake the following, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

The trees on strips would have to be felled but after stringing work is completed, natural regeneration will be allowed to come up. Future pollarding / pruning of trees will be done with the permission of the local Forest Officer, wherever necessary for the maintenance of the transmission lines.




Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (21)

I hereby undertake the following, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD.. in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

During construction of transmission line, pollarding / pruning of trees located outside the 35 meters width of the strips whose branches / parts infringe with conductor stringing, shall be permitted to the extent necessary, as may be decided by the local Forest Officer.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions- (22)

I hereby undertake the following, in respect Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 Kv Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD.. in favour of Superintending Engineer, OMC Circle, TSTRANSCO ,Adilabad.

In case the portion of the transmission line to be constructed is located in hilly areas. where adequate clearance is already available, trees shall not be cut.



Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

Undertaking to conditions (25), (26) and (27)

I hereby undertake the following, in respect of Diversion of 4.2 ha of forest land in Echoda Division for erection of proposed 220 KV single moose DC line from proposed 400/220KV Substation Nirmal to proposed 220/132 KV Substation at Utnoor in Adilabad District under Thermal power Transmission Scheme for evacuation power at Nirmal for providing of Power supply to erstwhile Adilabad District under TRANSMISSION CORPORATION OF TELANGANA LTD., in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad.

- a) User agency and the State Government shall ensure compliance to provisions of the all Acts, Rules, Regulations and Guidelines, for the time being in force, as applicable to the project.
- b) Any other conditions that the Central Government or DDG (Central) of Regional Office, Chennai or Addl. PCCF, TS may impose from time to time in the interest of afforestation, conservation and management of flora and fauna in the area, will be complied by the user agency.
- c) In the event of failure to comply with any of the above conditions the user agency is liable for penal action as per the provisions under FCA 1980 and as decided by the Additional PCCF (Central), Regional Office, Chennai.


Superintending Engineer, (FAC)
Adilabad OMC Circle, TSTRANSCO,
Mancherial.

AGENCY COPY

NEFT / RTGS CHALLAN for Ad-HOC CAMPA

Date : 02-06-2020

Agency Name.	TSTRANSCO
Application No.	6427295071
MoEF/SG File No.	4-TSC162/2019-CHN
Location.	Telangana
Address.	SE, OMC Circle, TSTRANSCO, 132/33 KV SS, Near GS Estate, AdilabadAdilabad
Amount(in Rs)	41858370/-

Amount in Words :Four Crore Eighteen Lakh Fifty-Eight
Thousand Three Hundred and Seventy Rupees Only

**NEFT/RTGS to be made as per following
details;**

Beneficiary Name:	Telangana CAMPA
IFSC Code:	CORP0000371
Pay to Account No.	155706427295071 Valid only for this challan amount.
Bank Name & Address:	Corporation Bank Lodhi Complex Branch, Block 11,CGO Complex, Phase I, Lodhi Road, New Delhi -110003

- This Challan is strictly to be used for making payment to CAMPA by NEFT/RTGS only
- This challan is valid only for seven days.

BANK COPY

NEFT / RTGS CHALLAN for Ad-HOC CAMPA

Date : 02-06-2020

Agency Name.	TSTRANSCO
Application No.	6427295071
MoEF/SG File No.	4-TSC162/2019-CHN
Location.	Telangana
Address:	SE, OMC Circle, TSTRANSCO, 132/33 KV SS, Near GS Estate, Adilabad Adilabad
Amount(in Rs)	41858370/-

Amount in Words :Four Crore Eighteen Lakh Fifty-Eight
Thousand Three Hundred and Seventy Rupees Only

**NEFT/RTGS to be made as per following
details;**

Beneficiary Name:	Telangana CAMPA
IFSC Code:	CORP0000371
Pay to Account No.	155706427295071 Valid only for this challan amount.
Bank Name & Address:	Corporation Bank Lodhi Complex Branch, Block 11,CGO Complex, Phase I, Lodhi Road, New Delhi -110003

- This Challan is strictly to be used for making payment to CAMPA by NEFT/RTGS only
- This challan is valid only for seven days.

After making successful payment, User Agencies may send a line of confirmation through
Email: helpdeskcampainfo@corpbank.co.in

UTR NO - SB/NR 5202006020013245

User ID No.	6363725	V. GOPALA KRISHNA
Queue No.		
SBI - 2 JUN 2020		MANC
20124		HERAL
CASH/TRANSFER		MAIN
Journal No.		BRANCH
Checker ID No.		Initials

"After 25"
guru
Executive Engineer
Construction Division
TS Transco, Adilabad

FORM-I
(For linear projects)

GOVERNMENT OF TELANGANA
OFFICE OF THE DISTRICT COLLECTOR::ADILABAD

Rc.No.E5/14/2020

Dt: 25.02.2020

TO WHOM SO EVER IT MAY CONCERN

In compliance of the Ministry of Environment and Forests (MoEF), Government of India's letter No.11-9/98-FC (Pt.) dated 3rd August, 2009 wherein the MoEF issued Guidelines on submission of evidence for having initiated and completed the process of settlement of rights under the Scheduled Tribes and Other Traditional Forest Dwellers (Recognition of Forest Right) Act, 2006 (FRA, for short) on the forest land Proposed to be diverted for non-forest purposes read with MoEF's letter dated 5th February 2013 wherein MoEF issued certain relaxation in respect of linear projects, It is Certified that **8.0972** hectares of forest land proposed to be diverted in favour of Superintending Engineer, OMC Circle, TSTRASNCO, Adilabad for erection of 220 KV single Moose DC line (110KM) from proposed 400/200 KV SS Nirmal to proposed 220/132 KV SS, Indervelli (Utnoor) in Adilabad district falls within jurisdiction of Andur G.P of Boath mandal.

It is further certified that:

- (a) The complete process for identification and settlement of rights under the FRA has been carried out for the entire **8.0972** hectares of forest area proposed for diversion. A copy of records of all consultations and meeting of the Forest Rights Committee (s), Grama Sabha(s), Sub-Division Level committee(s) and District Level Committee(s) are enclosed.
- (b) The diversion of forest land for facilities managed by the Government as required under section 3(2) of the FRA have been completed and the Grama sabha have given their consent to it.
- (c) The proposal does not involve recognized rights of Primitive Tribal Groups and Pre-agricultural communities.

Encl: (as above)

'Attested'
guru
Executive Engineer
Construction Division
TS Transco, Adilabad

Sri Devaray
Collector & District Magistrate,
Adilabad

DISTRICT COLLECTOR,
ADILABAD

SBINR 5202006200130467



"Affectus"
Amma
Executive Engineer
Construction Division
TS Transca, Adilabad



STATE BANK OF INDIA

Branch Mysore
Date 2-06-2020

Received _____
from _____

For remittance of NEFT/RTGS by way of (i) Transfer(only NEFT), (ii) Cash (only NEFT), (iii) Cheque (NEFT/RTGS) using cheque No. 416455

avouring Telangana CAMP

A/c No. 15570642729 5031

IFSC Code: CORP0000371

Beneficiary Bank & Branch Corporation Bank
New Delhi

Amount ₹ : 4,18,58,370-0

Bank's Charges ₹ _____

Total ₹ _____.

(Rupees four crore eighty lakh fifty
Eight (turning) Four hundred and Sixty only)

For office Use.

UTR No. _____ Branch Manager

Affected
gmc
Executive Engineer
Construction Division
TS Transco, Adilabad



DEPOSIT / PAY IN SLIP

State Bank of India

Date : 2/16/2020

Branch : Garimella-20744, Mancherial

SB/CA/RD/OD/CC/TL/DL A/c No./Credit Card No.

37 1 2 8 4 8 6 3 0 0

Name Forest Division Office Erwadi

Tel. No. _____

Amount 6441336 NEHA SHARMA P.
1000000

Rupees in words Sixty four thousand three hundred and thirty six BRANCH

Cash/Cheque No./Date & Name of Bank & Branch ₹ P.
CG6452 20/01/2020 CASH 294000
Journal No. Check No. Total

SWO / Passing Officer

SBI toll free 24 Hours Call Centre
No. 18004253800, 1800112211

'Affected'

Executive Engineer
Construction Division
TS Transco, Adilabad



TRANSMISSION CORPORATION OF TELANGANA LIMITED

NOTIFICATION

The Transmission Corporation of Telangana Limited. **Name of the works:** In-principa approval of Diversion of 13.9887 ha (Nirmal - 9.7887 ha and Echoda- 4.20 ha (revised from 8.0972 ha) of Forest land for Erection of 220 KV DC Line from 400/220 KV SS Nirmal to the proposed 200/132 KV SS Uttnoor in Nirmal District under Thermal Power Transmission Scheme for Evacuation of Power from SCCL Jaipur in favour of Superintending Engineer, OMC Circle, TSTRANSCO, Adilabad has been accorded by the Ministry of Environment, Forest & Climate change, Government of India, Regional Office, Chennai vide: F.No. 4-TSC 162/2019-CHN/410, Dt: 22.04.2020. **NOTE:** Further details please visit ministry's website: <http://www.parivesh.nic.in>against the proposal No: FP/TG/TRANS/27295/2017.

R.O.No.05/20

Sd/- CHIEF ENGINEER, CONSTRUCTION

"Affected"
gms
Executive Engineer
Construction Division
TS Transco, Adilabad



ట్రాన్స్‌మిషన్ కార్పొరేషన్ ఇంజినియర్స్ తెలంగాణ విభాగం

ట్రాన్స్‌మిషన్ కార్పొరేషన్ ఆఫ్ తెలంగాణ విభాగం, మమం యొక్క పేరు: మాపరించెండింగ్ ఇంజినీర్, బెంగాలు పర్సైల్, బెంగ ట్రాన్స్‌మిషన్, ఆదిలాబాద్ వారి పేరున ఎవసిపెట్ షైఫ్ట్‌సర్ నుండి విద్యుత్ తరలించుట కోరకు థర్మల్ వవర్ ట్రాన్స్‌మిషన్ వథకము క్రింద నిర్మల్ ఇల్లాల్ ప్రతిపాదిత 200/132 కెవి ఎనెనెన్ ఉట్టుకురు మండి 400/220 కెవి ఎనెనెన్ నిర్మల్ నుండి 220 కెవి దివె రైన్ వెలకోల్పుట కోరకు తట్టి భూమి యొక్క 13.9887 పొక్కార్డు (నిర్మల్ - 9.7887 పొక్కార్డు మరియు ఇచ్చేద - 4.20 పొక్కార్డు) (8.0972 పొక్కార్డు మండి వపరించబడినది) యొక్క మార్గింది యొక్క ఆమోదము ప్రధానంగా వర్యావరణ, తట్టి & వాతావరణ మార్పు మంత్రిత్వ శాఖ, భారత ప్రభుత్వం, ప్రాంతియ కార్బూరయము, చెంప్రె వారిచే ఎన్ వెం.4-బీవెనె 162/2019-నేపొచెవె/410, తేది: 22.04.2020 ప్రకారం ఇవ్వబడినది. దమిక: తదుపరి వివరాల కోరకు మంత్రిత్వ శాఖ యొక్క వెబ్‌సైట్‌లో ప్రపాకల్ వెం: ఎఫ్సి/లెషి/ట్రాన్స్/27295/2017 ను వెబ్‌సైట్ <http://www.parivesh.nic.in> లో చూదవచ్చును.

అర్థ. వెం.05/20

పం/- చిన్ ఇంజినీర్, వర్యావరణ

"Affected"

 Executive Engineer
 Construction Division
 TS Transco, Adilabad