

JUSTIFICATION REPORT ON LOCATING THE PROJECT IN FOREST LAND

The pipeline was laid during 1979, the pipe line served more than 35 year. The Government of Tamil Nadu has approved the more than 35 years aged Tambaram-Pallavaram CWSS for revival of outlived components under Capital Grand fund under 5th State Finance Commission. The 600mm AC pipe line laid from Krishna Nagar Booster station at Tambaram to Break Pressure tank at Oragadam near Global Automotive Research Centre comes under middle of BT road due to widened road, which is occurring frequent leak & burst. Hence 600mm AC pipe has been proposed to be replaced with 600mm DI pipe and proposed.

As the pipeline already runs in this alignment (Via Vattambakkam Reserve Forest) and there is no other alternative route (no Alternative non-forest land) .Hence unavoidable circumstances, portion of land from KM 44/905 to 45/200 is coming under **Vattambakkam Reserve Forest land** in Sriperumbudur Range in Kanchipuram District (area required for laying of pipe line is 295 Sq.m or 0.0295 Ha is very minimum).

I request necessary permission to lay the new pipe in the above said forest land.

Signature

: 

Name in Block Letter

: Er.A.Azhaguvel, B.E, M.I.E, M.B.A

Designation

: Executive Engineer

Address (of User Agency)

: TWAD Board, Maintenance Division,
No.95,SelliyammanKoil Street,
Kattankulathur-603203