

## COST BENEFIT ANALYSIS

**Name of the District:** - East Garo Hills

**Name of the Block:** - Songsak

**Name of the Scheme:** - RGGVY

**Name of work:** - Construction of 33 kV line from Williamnagar to Songsak

1	No. of Villages to be covered (nos)	376
2	No. of Households to be benefitted (nos)	10381
3	No. of BPL connections to be released (nos)	3925
4	Expected no. of APL consumers (nos)	6456
5	Approx Revenue return (Rs)	25,95,250 Per month 3,11,43,000 Per Annum

### Information on Grid connection: -

There is existing 33 KV line from Nongalbibra 132/33 KV Sub-Station to Williamnagar. From Williamnagar the proposed Sub-Station to Songsak new 33/11 KV Sub Station will be connected from the existing 33/11 KV Williamnagar sub-station by the proposed 33 KV line, as there is no existing Power Station in the proposed site. Therefore to provide the better Power Supply to this area with the proper voltage, this 33 KV line has been proposed and your kind clearance is solicited.

### Status of Power Supply to Williamnagar: -

At present there is only one existing 33 KV line from 132/33 KV Nongalbibra Sub Station to Williamnagar 33/11 KV Sub Station.



Executive Engineer  
RE Construction Division  
MePDCL, Williamnagar.