

Note of Justification

It is certified that Village **Bhutti at Darka** is centre point of Lug -Valley area. For the Construction of 33/11KV 2x1.6MVA un-manned Sub Station, **Lug Valley, Bhutti at Darka, Kullu (H. P.) 0.12 hac** land is required **nearby Darka**. And there is no private/Government land available nearby Bhutti at Darka for the above mentioned purpose.

So, HPSEBL proposed **0.12 Hac. Forest land at village Bhutti at Darka** for the construction of 33/11KV, 2X1.6 MVA un-manned Sub-Station. The proposed site is on **forest land** which is already connected to link road. More over the proposed site is already developed & no cutting/ levelling/ dumping required and only **one tree cutting & felling is required**. The site is also well connected with the HPSEBL existing 11 KV Network. And laying of additional 11KV HT lines is not required.

Due to above mentioned facts the **proposed forest land is suitable/Justified in all the means for the construction of 33/11KV 2x1.6MVA unmanned Sub Station, Lug- Vellay, Bhutti at Darka, Kullu (H. P.)**



Sr. Executive Engineer,
Elect. Division Kullu,
HPSEBL, Kullu (H. P.)