


## SITE INSPECTION REPORT

The Superintending Engineer, General Construction Circle, TANTRANSCO, Tatabad, Coimbatore has submitted online application Form-A Part- I under section 2 of Forest (Conservation) Act, 1980 for proposal for diversion of 2.09 ha of Forest land in Bolampatti Block- III and Thadagam RF of Bolampatti & Coimbatore Ranges for laying 110 KV Double circuit line on Kanuvai hills from Othakkalmandapam to Thudiyalur at Somayampalayam 110 KV SS in Coimbatore District.

I have inspected the above area on 10 . 01.2015 and found there is no tree growth on the proposed area and I recommend the laying of 110 KV Double circuit line in the Forest Land as the area required by the user agency is minimum. Since the user agency is creating 110 KV double circuit line and height of the line is 13 meter from the ground level it will not hinder the movement of wild animals and there is no Possibility of alternative alignment. Therefore I request that this proposal may kindly be considered in the interest of public to provide Electricity.

  
District Forest Officer,  
Coimbatore Division,  
Coimbatore.