

## SITE INSPECTION REPORT

Inspected the site on 16-03-2017. The proposal is for laying 11KV LT single phase 2 wire line and provide service connection to Shri. Samad.K.V. under **Total electrification Scheme**. Area to be diverted for drawing electric line is 0.07 ha. The area is having young acacia plantation. Tree felling and lopping is to be carried out if line is drawn as proposed. It is therefore recommended that user agency should plan for laying UG cable instead of overhead line. The project in the present form is therefore rejected



Deepak Mishra IFS  
The Chief Conservator of Forests  
Southern Circle ,Kollam