

SITE INSPECTION REPORT

Division Name	Circle	Site Inspected By	Whether Site Inspected	No. Of times Site Visit	Site Inspection report	Date of Visit
Palakkad	Eastern	DFO	Yes	Two	<p>The Proposed line will be drawn through the RDF II (NFC 168/I) forest area which falls under Akathethara Section, Walayar Range. On Field verification it was found out that only drawal of 66.8m PVC insulated twincore WP wire line across the forest area with 1 PSC pole (7m) execution inside forest area is required. The total land utilization will be only $66.8\text{m} \times 0.1\text{m} = 6.68\text{m}^2$. A walkway exists through this area presumably used by the applicant for going to his house. No felling of trees is needed for this purpose and only cutting of small branches will be sufficient and also the line after construction will not create any disturbance to wild animals or birds in the locality.</p> <p>Boundary :</p> <p>North : Edamala Vested forest East: Sasthanagar RDF II West : Sasthanagar RDF II South: Sasthanagar RDF II</p>	23.05.2017 27.06.2017

