


Justification

Basic view of the project is to give uninterrupted Reliable power supply to Subramanya area which is the most famous Piligrimic place. Proposed 33/11KV Station should be installed at load center . Subramanya is only the available place where we can divide the existing electrical load equally and is the only available load center place. There is no alternate way to draw 33 KV line to the proposed substation and also this proposed route is the only available economical route to draw the line. Therefore it is proposed to draw the new 33KV line through this route for which FC is required .In the Earlier submitted FC proposal the forest land proposed for diversion is mensioned as 0.7956Hactare ,which was calculated by taking the width of line as 13meters.But as per the new government norms area should be calculated by taking the width as 15meters .In accordance to this total area of the forest land proposed for diversion is recalculated as 0.918Hactare,kind approval for this proposal is requested.


ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರು (ವಿ)
ಜಿಲ್ಲಾ ವಿ. ಸಂ. ಕೆ. ನಿ. ಸಂಸ್ಥೆ