

ಹುಬ್ಬಳ್ಳಿ-ಧಾರವಾಡ  
Hubli-Dharwad



ಮಹಾನಗರ ಪಾಲಿಕೆ  
Municipal Corporation

No. C/HDMC/KUWSMP/KUIDFC/H-D/Forest/2021-22/

734

Dated: 3 01.2022

To,  
The Nodal Officer and  
Addl. Principal Chief Conservator of forests,  
(Forest Conservation Bengaluru)

**Sub:** Diversion of 0.16945 hectare of forest land in FRS No.30 in Rayapur Village of Taluka & District Dharwad for KUWSMP 24X7 Water Supply Project to Hubballi-Dharwad City. To lay Clear Water Transmission main (1219, 864, 762 & 250 mm Diameter) MS & DI pipes from proposed Water Treatment Plant at Amminabhavi to various service reservoirs in favour of commissioner, Hubballi-Dharwad Municipal Corporation, Hubballi.

Ref: Proposal No. FP/KA/Water/141926/2021

**JUSTIFICATION REPORT**

The Water Treatment Plant at Amminbhavi is the only existing WTP (73+68+40=181MLD) for Hubballi Dharwad. Under KUWSMP project, additionally 43 MLD WTP is proposed in existing WTP premises at Amminabhavi to cater the future demand along with 1219mm dia OD MS Clear Water Transmission Main ( CWTM) from 43 MLD WTP to existing Rayapura GLSR in Forest area S.No.30 to feed water to the existing and proposed ELSRs / GLSRs and Bulk Supply points. These works are designed and proposed as per the hydraulic designs and also as per the required demand at supply zones.

The proposed 1219 mm dia MS Pipeline of 17.714Km follows the alignment along Kavalageri road, along Navalur Sullya road and further along KIADB road and after crossing BRTS road and then in the Forest Land to connect to existing Rayapura GLSR. There is no alternate proposal to reach Rayapura GLSR as this route is viable and economical which also satisfy the designs criteria.

Thus it is justified for the diversion of 0.19477 Ha of Forest land for the project.

Thanking you.

Yours Faithfully

  
Commissioner

Hubballi Dharwad Municipal Corporation

Hubballi-Dharwad