



Office of the
Executive Engineer
K.U.W.S. & D. Board
Division, Bidar.
Mobile: 9480689498
E-mail:-eebdrkuws@ymail.com

KARNATAKA URBAN WATER SUPPLY & DRAINAGE BOARD

COST BENEFIT ANALYSIS

The proposed location for construction of 20.00MLD Water treatment Plant under CWSS to Bhalki Town and 23 enroute villages of Khatak Chincholi Village in Sy. No. 178 of Bhalki Taluka Reserve Forest Division Bidar is having average GL-646.90mtrs from MSL by which the water can be fed to all Over Head Tanks of Bhalki Town and 23 enroute villages by gravity only. Hence, pure water pumping is not required which saves energy, man power and cost of maintenance. Also uninterrupted drinking water supply can be maintained to **Bhalki town** and 23 villages namely.

1.	Katti Tugaoan	9.	Haranl	17.	Yeklasapur wadi
2.	Chalkapur	10.	Kaplapur	18.	Ramtheerth
3.	Chalkarpur Wadi	11.	Kuntessirsi	19.	Kalwadi
4.	Nelwad	12.	Bajolga	20.	Dawaragoan
5.	Khatak Chincholi	13.	Yenkura	21.	Bardapur
6.	Sikandrabad Wadi	14.	Navadagi	22.	Chitta
7.	Kurub Khelgi	15.	Navadagi Tanda	23.	Masimadu
8.	Bhagyanagar	16.	Dadgi		

Date. 01.03.2018

Place: Bidar

Executive Engineer
KUWS & D. Division.
Bidar.

13/8