

Forest Diversion Proposal under FC Act, 1980

(Construction of 132 kV D/C Pare HEP to Lakhimpur Transmission Line)

JUSTIFICATION FOR LOCATING OF THE PROJECT IN FOREST AREA

1. PROJECT BACKGROUND

WRSS-IXI & NERSS-IX is a System Strengthening Project of Western and North Eastern Grid for the states of Gujarat, Maharashtra, Assam & Arunachal Pradesh being developed on built own operate and maintain basis through tariff based competitive bidding. This prestigious project is a part of National Grid and a vital link for bulk power transfer in the states of Gujarat, Maharashtra, Assam & Arunachal Pradesh by creating strong transmission link with adjoining states. Pare HEP to Lakhimpur Transmission Line is passing through the Doimukh Reserve forest and unclassified State Forest under Banderdewa and Sagalee Forest Division respectively in Papum Pare District of the State of Arunachal Pradesh.

2. JUSTIFICATION

Three alternative route corridors were studied largely by maximizing linear sighting opportunities, such as following existing roadways and power line corridors, negotiation with river, railway, road, electric power, and telephone line crossing and least crossing of notified/ reserved forest areas. All efforts have been made to provide minimum numbers of angle points and utmost care have been taken on the ground with possible angle of deviation. Similarly, power line crossings have been fixed as close as possible to the right angle but not less than the 60-degree crossing.

The line passes through Banderdewa and Sagalee Forest Division of the State of Arunachal Pradesh. Every effort has been made to avoid and minimize the forest area but considering the technical feasibility of the alignment and space constraints, the forest area could not be avoided completely. The alignment with minimum crossing of the forest & having minimum length has been selected as the proposed alignment. After detailed analysis, it was observed that Alternative-1 among the 3 alternative routes has the minimum involvement of forest area and is best suitable for construction point of view. Alternative-1 is also best in terms of approachability for construction as well as maintenance purpose.

Keeping the above points in consideration, Alternative - 1 is proposed as the final route alignment.

Comparative Statement for Alternative-1, 2, 3 Routes: -

Comparative Statement of 3 Alternative Routes			
Description	ALT-1 (Proposed Route)	ALT-2	ALT-3
Bee Line Length (Km)	9.381 Km.	9.381 Km.	9.381 Km.
Total Line Length (Km)	9.112 Km.	9.332 Km.	14.606 Km.
Length of Transmission Line in Forest Area (Km)	9.112 Km.	9.332 Km.	14.606 Km.
Forest Area (Ha.)	24.602 (Ha.)	25.196 (Ha.)	39.436 (Ha.)
Density of Forest Area	Moderate	Moderate	Moderate
Protected Area	NA	NA	NA
Places of Archaeological Importance	NIL	NIL	NIL
Places of historical / cultural / religious / tourist importance	NIL	NIL	NIL
Line Pass through any Town/ City	NO	NO	NO
Line Pass through any Defense establishments	NO	NO	NO

3. LEGAL FRAMEWORK

The Prior approval of the Government of India under Section 68 of the Electricity (Supply) Act, 2003 for the subject project has been obtained vide MoP's letter dated 07.01.2019. It is proposed to execute the transmission scheme as provision contained in the Indian Electricity Act, 2003 and the rules made there under and the Electricity (Supply) Act, 1910 and 1948, in so far as these are applicable.

4. ENVIRONMENTAL RISK

Transmission line Projects are environment friendly and do not involve any disposal of solid effluents and hazardous substance in land, air and water. Moreover, in forest area trees are felled at the tower spotting area and below each conductor to facilitate tower erection and stringing work. On completion of construction activity, only one strip is maintained for

O&M purpose and natural regeneration of vegetation is allowed in rest of the corridor area. Therefore, the actual impact on the Environment and Forest is temporary and minimal as it is restricted to some selected area only. However, as per the requirement of Forest (Conservation) Act, 1980 approval of Ministry of Environment, Forests & Climate Change, Govt. of India for diversion of forest land shall be taken before construction of line in forest area. Further, compensatory afforestation shall be done in double the degraded forest land to compensate the loss of vegetation, due to diversion of forest.

5. CONCLUSION

The route alignment has been made with a goal of minimizing the Forest and Wildlife area. After detailed analysis, it is observed that the Alternative-1 (Proposed Route) has the least route length and forest area involvement. **Hence, the Alternative -1 (Proposed Route) has been selected as final route as it contains minimum forest area and has least No. of trees to be felled.**

Place : Lakhimpur

Signature & Seal :



Name

: Narottam Chakraborty

Designation

: Assistant Vice President

Address

: Vapi II-North Lakhimpur
Transmission Ltd, C.D. Road, Ward
No. - 4, Lakhimpur, Assam - 787001