



PH. 0522- 2786245
E-mail- eeconst2lesa@gmail.com

OFFICE OF THE EXECUTIVE ENGINEER
ELECT. URBAN CONSTRUCTION DIVISION- II, LESA
33/11KV SUB STATION (PATEL PARK)
NIRALA NAGAR, LUCKNOW.

No. 80 /EUCD-II/LESA/

Date: 03.03.2015

Justification

To meet out the growing demand of electricity and ensuring uninterrupted supply to consumers in Radhagram and Thakurganj area of state capital Lucknow, a 33/11 KV, 2x5 MVA is proposed in Radhagram, Lucknow. To give supply to this new substation 33 KV underground cable has to be laid from Dubagga TV tower to this proposed substation. This cable will be laid along the Luckow-Pallia UP SH 25. There is no alternate route other than the UP SH 25, there will be no cutting of trees involved in this laying of cable. Minimum area is to be used.


Executive Engineer
EUCD-II, LESA
Lucknow