



KERALA STATE ELECTRICITY BOARD Ltd.

Office of the Assistant Engineer,

Electrical Section, Chelakkara, Thrissur - 680586.

Phone (Bsnl): 04884 – 252039, CUG : 9496009754

E-mail : aecka54@gmail.com

DB /ESCKA/17-18/DDUGJY

03-07-2017

NOTE

Due to the high interruption rate at Elanad area under Electrical section, Chelakkara, an alternate arrangement of feeders ie HT Interlinking of 11 kV Pazhayannur feeder and 11 kV Elanad feeder at Nadappakund is proposed. Stringing of 1.8 km 11 kV Aerial Bunched Cable (ABC) for this work is sanctioned under the Central Govt. Scheme named DDUGJY. ABCable is insulated cable having high endurance to conductor snapping compared to ACSR conductors. Since this stringing of 11 kv ABC is along the roadside through reserved forest, necessary forest clearance is required. There is no alternate route to string the ABCable for this HT Interlinking work.