


Justification for locating the project in forest area to be submitted by User Agency and countersigned by DCF

This project involves forest area for diversion and for electrification of Shree Kishorbhai Valjibhai Donga, Shree Mahendrabhai Valjibhai Donga and Shree Vasantben Govindbhai Prajapati village : KHICHA is 0.161 ha. Above land Survey No is surrounded by LS 220 & 220/1(Reserved Forest Land). So no any other alternative is available to pass the 11 KV Overhead Line.

Total area passing through forest area is **0.161** ha.

PGVCL does not need any acquisition of land for this purpose. **Only Poles will be inserted in the reserve forest land survey no as per the Electric standards to pass the Electric line. As the 11kv overhead line needs to pass through Reserve Forest Land, 11kv line is proposed by 11kv Arial Bunch Cable.**

So after erecting of this line, above applicant can survive better. And it will help out to applicant for Agriculture purpose. The requirement of forest land is unavoidable and barest minimum. No alternatives are available.


Dy.Engineer(TECH)
P.G.V.C.L.
AMRELI DIVISION -2

Place: AMRELI

Date: 19.08.19