


Justification and Detailed note of the Project


The TSNPDCL has proposed for Erection of 33KV Inter link line facilities at Penchikalpet Village to loadpally Cut point in Penchikalpet Mandal of Komarambheem Asifabad for 24Hrs supply to water grid services, agriculture services and local village, as the existing 33 KV line is length of 170 KM which is emanating from 132 KV SS Easgaon, due to lengthy line, frequently power interruption is occurring.


Erection of proposed line may increase the cultivation to the farmers with 24 hours uninterrupted electricity and also provide an option for developing new industries which creates employment. Hence, proposed for erection of 33KV line.


The extent of forest land required is as follows:

Division Name	Block Name	Length in Mts	Width in Mts	Area in Ha
Kagaznagar	Penchikalpet	4451.08	15	6.6766


Asst. Divisional Engineer
Operation SD, Kowtala.


Asst. Engineer
Operation, Bejjur.


Superintending Engineer
Operation Circle, Kumrambheem Asifabad


Divisional Engineer Elec.
Operation Division, Kagaznagar