



Visvesvaraya Jala Nigam Limited

(A Government of Karnataka Enterprise)

Email: eeubp2@rediffmail.com
eeubp1@gmail.com
Ph: 08282-256345
CIN: U41000KA2016SGC097260



Office of the,

Executive Engineer,
VJNL, Upper Bhadra Project
Division-02, B R Project

Declaration for Self Authorisation

Hereby it is declare that Executive Engineer, VJNL, UBP Division-2, B R Project to act as Authorised Signatory on behalf of User Agency Visvesvaraya Jala Nigam Limited for which application for the work of **Re Diversion and change in land use of 7.53 Ha forest land for 220 kV Transmission line work of Upper Bhadra Project, Package-1 from diverted forest land of Upper Tunga Project** is being made.

Place: B R Project
Date: 23-07-2020


Executive Engineer,
VJNL, UBP Division-02,
 B R Project

Proceedings of the meeting held between KPTCL and VJNL on 25.03.2017 at the office of the Executive Engineer, Upper Bhadra Project Division-1, Muthinakoppa for construction of 220 kV Station at Muthinakoppa.

Officers present:

- | | |
|----------------------------|---|
| 1. Sri R. Cheluvaraj, | CE, Upper Bhadra Project, Chitradurga |
| 2. Sri Manoj Kumar Poojar | CE, KPTCL., Transmission Zone, Hassan |
| 3. Sri K. Thippeswamy, | SE, Upper Bhadra Project, BRP |
| 4. Sri M.G. Jeevan Kumar | EE, Upper Bhadra Project, Muthinakoppa |
| 5. Sri M. Renuprasad | SEE(Tech), KPTCL., Bengaluru |
| 6. Sri D. Nataraja | SEE, Tr(W&M) Circle, KPTCL., Shivamogga |
| 7. Sri H.R. Prakash | EEE, (Tech), KPTCL., Bengaluru |
| 8. Sri K. Suresh | EE, O/o Tr.(W&M) Circle, KPTCL., Shivamogga |
| 9. Sri C. Pradeep | I/c EE, Chickmagalur M.W. Dvn., KPTCL., |
| 10. Sri Kenchanagowda, | I/c EE, M.W. Dvn., KPTCL., Shivamogga. |
| 11. Sri M.K. Praveen | AEE(Civil), M.W. Division, KPTCL., Shivamogga |
| 12. Sri N.S. Shashidhar | AEE(E), VJNL |
| 13. Sri H.B. Chandrashekar | AEE(E), M.W. Sub-division-3, KPTCL., shivamogga |
| 14. Sri M.S. Premkumar | AEE, QC, UTP, Gajanoor |
| 15. Sri K.S. Manjunath | AE(E), MWSD-3, KPTCL., Shivamogga |
| 16. Sri J.A. Somashekar | AEE, UBP Sub-division, Muthinakoppa |
| 17. Sri K. Nagaraja | TA(AEE), UBP Dyn., Muthinakoppa |
| 18. Sri Ramesh Babu. M. | AEE, Tech Section, KPTCL., Bengaluru |
| 19. Sri Nithya. H.J. | AE, UBP, Muthinakoppa |

After detailed deliberation in the meeting it is concluded as follows:

- Because of the corridor problem encountered, passing through rubber plantation, forest, etc., it is not possible to draw main 220 kV line as per the already approved scheme of KPTCL.
- It is decided to change the location from proposed 220/110 kV Sub-station already acquired by M/s VJNL.
- Due to change in location, it was requested by VJNL to have two numbers of 220/11 KV switching stations instead of one 220/110 KV


Station under KPTCL control and further 2 No.s of 110 kV Sub-station with VJNL by extending 110 kV line.


- Further, VJNL requested to consider extending power supply of 220 kV instead on 110 kV. In this regard, the request of VJNL may be considered by changing the scheme approval already communicated. As per the new scheme, VJNL has to construct one 220 kV switching station by LILO of Shimoga to Varahi-3 line for 1st pump house and they have to extend 220 kV line to their station near 2nd pump house.
- Hence, CEE, KPTCL requested CEE, VJNL to instruct to conduct the block level survey of the new station site and to submit to CEE, P&C, KPTCL, Kaveri Bhavan, Bangalore.
- As the scheme was approved during 2011, the entire subject project is of urgent nature, CE, VJNL has requested CEE, KPTCL to allow them to work under self execution. The CEE, KPTCL requested to submit the proposal.
- In the meeting, EE, Major Works, Chickmagalur is directed to submit the request of EE, VJNL to competent authority to obtain the permission for self execution.
- During the meeting, SEE(Tech) and the EE(Tech) suggested that minimum area of 120 x 180 Mtrs. Is required for proposed 220/11 kV Station.
- In this regard, CEE, KPTCL requested CEE, VJNL to spare the extent of land measuring 120 x 180 Mtrs. and to hand over to KPTCL as per KPTCL norms.
- It is instructed to conduct Geo Tech survey of the earmarked land for the proposed 220/11 kV Stations and to submit the report to the EE, MW Division, chickmagalur for necessary preparation of estimate.

- It is decided during the meeting, the KPTCL and VJNL are requested to make go over survey along with proposed 220 kV Sub-station, Muthinakoppa and instructed to submit the new proposal for approval.
- As per new scheme, the 220 kV line from 220 kV Shimoga-Varahi line to the first 220/11 kV Station will be in control of KPTCL. Beyond 220 kV metering point and second 220/11 kV Station will be in control of VJNL.

It is requested to all the officers attended the meeting by both the Chief Engineers to take importance of establishing the 220/11 kV Sub-station with 220 kV associated line in phased manner should be carried out simultaneously with due co-ordination and co-operation by both KPTCL and VJNL officers and to take extra care for early completion of the entire project.


The meeting concluded with vote of thanks by both the Chief Engineers.

 25/03/2017
Chief Engineer, Elec.,
Transmission Zone, KPTCL., Hassan
Camp: Muthinakoppa

 25/3/17
Chief Engineer,
UBP, VJNL, Chitradurga
Camp: Muthinakoppa

- ❖ Copy to the Personal Secretary to the Hon'ble Managing Director, KPTCL, Kaveri Bhvan, Bangalore for information with a request to bring to the knowledge of the Hon'ble Managing Director

"ATTESTED"


Executive Engineer,
V.J.N.L., No.2, U.B.P. Division,
B.R. Project-577 115

Scanned by CamScanner

Scanned by CamScanner