



EXECUTIVE ENGINEER  
NEMMELI DESALINATION

**CHENNAI METROPOLITAN WATER SUPPLY  
AND SEWERAGE BOARD**

Lr.No. CMWSSB/SE(Desal)/150MLD Product Water Main/Forest/2022

Dt.12.08.2022

To

The Principal Chief Conservator of Forest,  
Panagal Maaligai,  
Saidapet,  
Chennai – 600 015.

Sir,

Sub: CMWSSB – Conveyance of 150 MLD of Product Water through Pipeline from the Desalination Plant at Nemmeli on East Coast Road, South of Chennai and upto Pallavaram and all allied works including O&M for 20 Years – Laying of Pipes for 1.2 Km along Medavakkam Main Road (near Nanmangalam Reserve Forest area) – Compliance Report for Stage – II approval – Furnished - reg.

Ref: Proposal No.: FP/TN/Pipeline/146983/2021 dated 08.09.2021

\*\*\*

With reference to the above subject, the Stage-I (In-principle) approval for Forest Clearance for the laying of 1200 mm dia MS Pipeline for 1.2 Km in Medavakkam Main Road (near Nanmangalam Reserve Forest area), was accorded by the Competent Authority on 11.05.2022.

Further, the Compliance Report for the Stage – II approval is prepared and submitted herewith, for further action.

Your kind co-operation is much solicited.


*S. K. Srinivasan*  
12/08/2022  
EXECUTIVE ENGINEER  
NEMMELI DESALINATION

Encl: Compliance Report

Sl. No.	Condition	Status of Compliance
a)	The legal status of the diverted forest land remains unchanged.	Accepted and Noted.
b)	The demarcation of the proposed forest land shall be carried out by the User Agency by erecting 4 feet high cement concrete pillars duly numbered at an interval of 20 metres at their cost.	<p>The demarcated land proposed for laying the 1200 mm dia pipes is on existing road maintained by State Highways Department &amp; the User Agency cannot erect 4 feet high cement concrete pillars.</p> <p>Further, during the site joint inspection made with the District Forest Officer, Chennai on 11.07.2022 along with CMWSSB Engineers, it was explained that the erection of 4 feet high cement concrete pillars at an interval of 20 m along the entire stretch of 1200 m is not practically feasible, as it may cause huge obstruction to the vehicular movements along the road. Photos enclosed in Annexure- I.</p>
c)	The User Agency has to pay the amount of Net Present Value which will be fixed as per the guidelines of Hon'ble Supreme Court of India.	As per the demand letter dated 12.07.2022 furnished by the District Forest Officer, an amount of Rs.1,60,834/- has to be paid for Net Present Value through Online Portal.
d)	The User Agency has to bear the additional amount of Net Present Value which will be fixed as per the guideline of Hon'ble Supreme Court of India as fixed by Forest Department in future.	Accepted and Noted.
e)	Amount of Net Present Value of forest area under the project shall be transferred / deposited to Compensatory Afforestation Fund Management and Planning Authority fund only through e-portal ( <a href="https://parivesh.nic.in/">https://parivesh.nic.in/</a> )	Payment of Rs.1,60,834/- was made through the e-portal ( <a href="https://parivesh.nic.in/">https://parivesh.nic.in/</a> ) via NEFT DR-P215220183219976 on 04.08.2022.
f)	The User Agency has to pay the cost towards annual lease rent as fixed by the Forest Department at the time of sanction along with any escalation for the forest land to be diverted of the above project in future for the entire project period.	Accepted and Noted.
g)	The total forest area utilized for the project shall not exceed 0.24 ha comprising water supply pipeline to a length of 1200 m and width is 2.00 m and after completion of underground laying of pipeline, area should be restored to its normalcy.	Accepted and Noted.

Sl. No.	Condition	Status of Compliance
h)	The pipeline shall be laid down at least 1.50 m below the ground and after lying down of pipeline the ground level will be levelled.	Accepted and Maintained.
i)	Period of lease can be twenty (20) years. The User Agency has to apply renewal proposal before one year of expiry of lease with the State Forest Department.	Accepted and Noted.

  
 12/8/22  
 AE/ISDMLD  
 (cl)

  
 12/8/22  
 ABE/PL



## Annexure – I

### Site Inspection by the District Forest Officer, Chennai on 11.07.2022

