



Office of the Divisional Forest Officer, Chatra North Forest Division.

E-mail ID- dfo-chatranorth@gov.in, Telephone No.- 06541-296022, Mobile No.- 8987790214

Memo No. 2812...../Dated 05.12.2020

From,

Vikas Meena, IFS
Divisional Forest Officer,
Chatra North Forest Division.

To,

Sunil Kumar,
Manager, (T)
Transmission Sub Division,
(JUSNL) Chatra.

Subject: Corrections in 132KV DC Transmission Line From Hunterganj to Chatra, Forest diversion online proposal no. FP/JH/TRANS/50112/2020 (Diversion Area-23.3033Ha.)

Ref.:- Your Online submitted proposal No.- FP/JH/TRANS/50112/2020 & Letter No. 157 Dt. 05.11.2020

In reference to cited above, it is submitted that following corrections are needed in the submitted Online Proposal No. FP/JH/TRANS/50112/2020 and Hard Copy submit Dated 06.11.2020

1. NOC for GMJJ from Deputy Commissioner is not attached.
2. All pages in the main application form needs to be duly filled up and signed by the competent authority with the date, place and their official seal
3. There are multiple errors in land schedule i.e. length and width of proposed forest land to be diverted for line is not mentioned village wise and plot wise, also plot no. are not correctly mentioned.
4. GPS coordinates of proposed Forest land to be diverted are not mentioned in all cadastral maps.
5. Undertaking for Additional NPV and Additional CA and additional condition is not attached.
6. Certificate from the Deputy Commissioner that no alternative suitable non-forest land is available for the project in question.
7. Detailed note on the project is not attached.
8. Geo-referenced digital data of the boundaries of the proposed forest land for diversion in shape file (soft copy in a DVD along with the raw and post-processed data) and digital map in hard copy duly authenticated by competent authority is not attached.

9. Make and model of the DGPS equipment used, name of the agency/persons involved in the DGPS survey, period of the survey, name of the authenticating agency for the accuracy of the survey is not attached.
10. Geo referencing map needs to be corrected.
11. Undertaking regarding project area not falling within any Protected Areas (PAs) Eco Sensitive Zones needs to be provided.
12. Undertaking for muck disposal and non use of any forest produce.
13. Certificate for minimum use of forest land giving details of alternatives examined and reasons for their rejection.
14. Undertaking of Tree Enumeration is not attached
15. In case of transmission line, the following details should also be given :-
 - a. Number of towers to be erected both in forest and non-forest area.
 - b. Width of the right of way for transmission line.
 - c. Length and Width of Transmission line passing through forest and non forest area.

It is further submitted that 8 copies of your proposal are being returned and it is requested that correct proposal should be submitted in 9 copies in this division so that the proposal can be processed further.

Encl. – as above.

Your Faithfully

Vikas
5/12/2020
Vikas Meena, IFS

Divisional Forest Officer,
Chatra North Forest Division.

dy
5/12/2020