



उपवनसंरक्षक, यावल वनविभाग, जळगांव यांचे कार्यालय
डिएपी चौक, आरटीओ ऑफीस जवळ, जळगांव फोन/फॅक्स न. ०२५७-२२६२७२२ ईमेल-dycfyawal@yahoo.com

विषय:- Diversion of 23.10 ha of Reserved forest Land
in favour of Maharashtra State Electricity
Distribution Co. Ltd, Dharangaon Division,
Jalgaon for erection of ३३ KV Karjane
Transmission Line for ३३/११ KV Karjana
Substation from Malapur to Karjane Village,
Tal. Chopda, Dist Jalgaon in the State of
Maharashtra regarding.

जावक क्र. ब/कक्ष-७/दक्षता/ 1283 /२०२२-२३
जळगाव- ४२५ ००१, दिनांक. ०६/०२/२०२३

प्रति,
✓ म. वनसंरक्षक (प्रादेशिक)
धुळे

- संदर्भ :- १. म. प्रधान मुख्य वनसंरक्षक(वनबल प्रमुख) म. रा. नागपुर यांचे कडील पत्र क्र. कक्ष- 17/नोडल/धुळे/
आयडी- 12658/2704/2022-23 दिनांक. 17.01.2023.
2. कार्यकारी अभियंता, महाराष्ट्र राज्य, विद्युत वितरण मंडळ मर्या. धरणगाव यांचेकडील पत्र क्र. EE/
DRN/TECH/0210/ दिनांक. 19. जाने. 2023

कार्यकारी अभियंता, महाराष्ट्र राज्य, विद्युत वितरण मंडळ मर्या. धरणगाव यांनी सादर केलेल्या वन
(संवर्धन) अधिनियम 1980 अंतर्गत 33 के.व्ही. कर्जाणे ट्रान्समिशन लाईन 33/11 33 के.व्ही. कर्जाणे सबस्टेशन
मालापुर ते कर्जाणे गाव ता. चोपडा जिल्हा जळगाव या प्रस्तावात केंद्र शासनाने संदर्भीय क्र. 01 अन्वये दोन मुददे
उपस्थित केल्याने, संबंधीत यंत्रणेकडून त्रुटीची पुर्तता अहवाल तयार करुन त्या कागदपत्राच्या प्रतीसह सादर
करणेबाबत कळविण्यात आले होते.

त्या अनुषंगाने कार्यकारी अभियंता, महाराष्ट्र राज्य, विद्युत वितरण मंडळ मर्या. धरणगाव यांनी 33/11
33 के.व्ही. कर्जाणे सबस्टेशन मालापुर ते कर्जाणे गाव ता. चोपडा जिल्हा जळगाव या प्रस्तावात आवश्यक असलेल्या
त्रुटीची पुर्तता अहवाल 4 प्रति या सोबत जोडुन सादर करण्यात येत आहे.

सोबत :- बरील प्रमाणे (4 CD)

(विवेक वि. होशिंग)


उपवनसंरक्षक,

यावल वनविभाग, जळगांव.

प्रतिलिपी :- कार्यकारी अभियंता, महाराष्ट्र राज्य, विद्युत वितरण मंडळ मर्या. धरणगाव यांना उचित कार्यवाहीस्तव
अग्रेषित.

33 KV Karjane Transmission line from Virwade to Karjane via Bormali

Sr.No	Condition	Complaince
1.	Correct KML file of area proposed for diversion highlighting Forest patches in compliance to point no. I is not submitted along with query reply. The same needs to be submitted.	KML file च्या एकूण 04 CD या सोबत जोडून सादर करण्यात येत आहे.
2.	Inconsistency in the statement made by the User Agency is observed w.r.t. alternative alignments examined. In statement it is mentioned that in alignment no. 3 less trees will be cut compared to alignment no. 1 & 2, whoever, number of trees appears to be less in alignment no. 1 & 2 compared to alignment no. 3. Further, inconsistency is observed in the statement made in alignment no. 1 & 2 regarding tree felling is observed. Correct information needs to be submitted.	Statement Regarding rejection of alternative alignment is hereby submitting with this letter after verbal communication regarding tree felling and forest density with DCF Yawal forest office Jalgaon.



(Vivek V. Hoshing)

Deputy Conservator Of forest,
Yawal Forest Division Jalgaon