



महाराष्ट्र शासन

वन विभाग

मुख्य वनसंरक्षक, चंद्रपुर वनवृत्त, चंद्रपुर यांचे कार्यालय

सिन्धील लाईन, नागपुर रोड, चंद्रपुर- 442401

दुरध्वनी क्र. 07172-256279, 252232

Email id- ccfcchandrapur@gmail.com, ccftchandrapur@mahaforest.gov.in

Desk-3(1)/Land/C.R.- 446/2021-22/ 604
503

Date :- 25-8-2021

To

Additional Principal Chief Conservator of Forest &

Nodal Officer

Maharashtra State, Nagpur

Sub.:- Diversion of 44.0397 ha. forest land under the Forest (Conservation) Act, 1980 for laying of 132 KV Mul-SICOM Chandrapur Transmission Line.

- Ref. :-** 1. Additional Principal Chief Conservator of Forest & Nodal Officer, M.S., Nagpur vide Letter No. Desk-17/NC/RS-I/ID-12899/363/21-22, dated 23/06/2021.
2. Divisional Forest Office, Chandrapur letter No. Desk-14/Survey/Land/865, dated 12/08/2021.
3. Executive Engineer, EHV Projects Division MSETCL, Chandrapur letter No. EE/EHV/Projects/DM/CHAD/Tech/1451, dated 10/08/2021.



As per the instructions given by the Additional Principal Chief Conservator of Forest & Nodal Officer, M.S., Nagpur regarding the issue of reference letter no. 1, the DFO & Agency has submitted the compliance report by their reference letter no. 2 & 3. This office compliance report has being 3 copies submitted as follows.

FORM - A

Sr. No.	Condition	Compliance
1.	To obtain the prior permission of the NBWL as the proposed transmission line passes through Tiger Corridors of Eastern Vidharbha Landscape.	The User Agency has submitted an undertaking. A copy of the same is enclosed herewith as on Page No. 1 & 2.
2.	To submit remarks of DCF & CCF on wildlife mitigation measures required due to the project for further needful action.	The following mitigation measures proposed by user agency. 1) A 5.8 M vertical clearance & 1.2 M horizontal clearance from the vegetation will be maintained as per Indian Electricity Rule 1956. 2) Any felling / pollarding / of trees will be done as permitted for electrical clearance. 3) Vegetation clearance along forest stretches will be

	<p>avoided or minimized by increasing height of towers structures to shall maintain safe vertical clearance.</p> <p>4) Adhedre to guidelines issued by National Green Tribunal if applicable.</p> <p>5) Guidelines issued by forest clearance division pertaining to transmission line passing through forest will be strictly followed.</p> <p>6) No construction activity 6.00 PM to 7.00 AM.</p> <p>7) Labour at least 1.00 Km. away.</p> <p>8) Installation of 'Bird Reflectors' at proper places.</p> <p>This office is of the opinion that all the tree vegetation below the transmission line passing through forest area should be cleared and permanent grass lands should be developed for the benefit of wild life at the cost of user agency.</p>
--	---

Encl.:- As Above.


 (N.R.Praveen)
Chief Conservator of Forest
Chandrapur Circle, Chandrapur


Copy forwarded to Divisional Forest Office, Chandrapur for information and necessary action.

Copy forwarded to Executive Engineer, EHV Projects Division MSETCL, Chandrapur for information and necessary action.