



H.P. Forest Department

Shimla Forest Circle (T)

Email:- head-forcirshi-hp@hp.gov.in

Ph.:-0177-2624850



No. C-28-b-1603/FCA (Online)/Chopal/ 7235 Dated- 15-3-25

From: CCF Shimla To: Nodal Officer-cum-APCCF (FCA)
O/o Pr.CCF (HoFF) HP, Shimla

Sub: Diversion of 2.8573 ha of forest land in favour of M/s Hydro More Power Pvt. Ltd. TRV Building Secyo-II New Shimla for construction of 2.00 MW Tranh-Charoli SHEP, within the Jurisdiction of Chopal Forest Division. District Shimla, Himachal Pradesh.

Memo:


Kindly refer to your office Memo No. Ft 48-3768/2018 (FCA) dated 31.12.2024 on the subject cited above.

2. The Point wise reply given is as under:-

Sr.	Observation	Reply
1.	Document regarding Length & Width uploaded at Sr. No. 30 in additional information of Part-I is not in readable format.	In this respect, it is submitted that the Revised length & Width Certificate has been uploaded by the User Agency against additional information detail in online Part-I at Sr. No. 35 by the user agency.
2.	Legal Status of land in Part-II needs to be revised and area wise legal status shall be mentioned.	The area wise legal status has been mentioned and uploaded on the portal Part-II at Sr. No. 13 by the DCF.
3.	Digital map has prepared whereas Digital map is required to be uploaded.	Distance map in Digital Form has been uploaded against additional information detail in online Part-I at Sr. No. 32 by the user agency.
4.	Approved capacity in terms of hydroelectricity generation of the river/rivulet still not provided.	Approved Capacity is 3.00 MW and Installed capacity is 2.10 MW with seasonal (Max.) power 2.31 MWDPR is attached for information detail in online Part-I at Sr. No. 37 by the user agency.

5.	Though comments regarding ensuring of e-flow during rainy season have been provided but detail of water available in Nallah in the rainy season and volume of water to run the turbine has not been provided.	User agency has been submitted that the Tranh Stream is the tributary of Sainj Khad. The main source of Tranh stream is the monsoon run-off as well as the run-off on account of snow melting. The elevation of catchment area of the Tranh stream varies between 3600 meter to 1610 meter and it lies in the Shivalik ranges in Shimla Distt. Of Himachal Pradesh. The flow of the Tranh stream are low during Nov. to Feb. But strats increasing from Feb. on wards with high flows during July to October due to monsoon rain fall. Discharge observation has been recorded on Tranh stream at Chroli village since 2008 to 2011 and detail of the same is attached in the Hydrology at Annexure 5.4 Hydrology data has been uploaded detail in online Part-I at Sr. No.30. Also, the volume of water to run the turbine is 1.25 Cumecs by the user agency.
----	---	--

This is for your information and further necessary action at your end please.


 Chief Conservator of Forest
 Shimla Forest Circle, Shimla.