

कार्यालय अपर प्रमुख वन संरक्षक एवं नोडल अधिकारी, वन संरक्षण,
इन्दिरानगर फॉरेस्ट कालोनी, उत्तराखण्ड, देहरादून।

Email- Nodalofficerddn@gmail.com

Phone/Fax-2767611

पत्रांक:- 2751 FP/UK/HYD/42080/2019 दिनांक: देहरादून 19 मई, 2021

सेवा में,

अपर प्रमुख वन संरक्षक,
भारत सरकार पर्यावरण, वन
एवं जलवायु परिवर्तन मंत्रालय एकीकृत क्षेत्रीय कार्यालय,
25 सुभाष रोड़, देहरादून।

विषय:- Regarding transfer of 9.397 hac forest land for construction of 4x3 MW Tankul SHP at Tehsil Dharchula of district Pithoragarh in the name of UJVN Limited FP/UK/HYD/42080/2019.

सन्दर्भ:- भारत सरकार पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय, क्षेत्रीय कार्यालय, देहरादून के पत्र दिनांक 17.03.2021

महोदय,

उपरोक्त विषयक सन्दर्भित पत्र के क्रम में उक्त प्रकरण में दिनांक 17.03.2021 को ऑनलाईन माध्यम से लगाई आपत्तियों का निराकरण बिन्दुवार निम्नवत है:-


क्र०सं०	आपत्तियाँ	निराकरण
1	In reply to point no. 01 State Government was requested to submit the enabling provisions prescribing charging of lease rent @1% of the total value of the forest land as no such provisions have been provided under the FC act, 1980. State Government submitted that the same desired by Uttarakhand Government vide letter dt. 09.09.2005. Which show that the reply is just a copy of the reply submitted by the user agency. State Government is requested to submit the enabling provision for charging of lease rent.	The copy of enabling provision prescribing charging of lease rent has been uploaded as additional column of Part-II.
2	In reply to point no. 01 State Government again forwarded the reply of user agency without examining at their level. User agency informed that they are already having 33 KV substation and in addition also having 11 KV transmission line and the same shall be upgraded to 33 KV line for evacuation of power. It is submitted that RoW approved for 11 KV line is 7 mtr and for 33 KV is 15 m. State Government may submit clarification in this regard.	No land has been included for transmission line from Tankul SHP to 33 KV sub station, Tawaghat in land case under consideration. Shape of the land to be diverted for construction of 33 KV transmission line is liner. If required, separate land case shall be prepared for acquiring additional land for construction of 33 KV transmission line. UPCL has also proposed 33 KV line from Sub Station, Tawaghat to Gunji which shall pass through 12 MW Tankul SHP.

3	In reply to point no. 03, State Government is requested to submit the revised muck disposal plan after incorporating swell factor.	User agency has inform that the balance quantity of muck i.e. 26263 Cum after considering swell factor shall be disposed of at quarry site and shall also be used locally in construction activities at the Project camp building area. (Copy of Calculation uploaded in part-I as additional information)
4	In reply to point no. 04, neither any administrative approval found enclosed with the letter nor found uploaded online. State Government may submit the administrative approval of the project.	D.P.R. of the Project was approved by the board of UJVNL. Board of UJVNL having Secretary Energy, GoU as Chairman and whole time Managing Director & Directors of UJVNL as members including part time Directors. Approval of DPR of Tankul SHP by Board of Directors is administrative approval of the Project. (Copy of approval uploaded in part-I as additional Information)

अतः प्रकरण पर वन संरक्षक अधिनियम 1980 के अन्तर्गत स्वीकृति निर्गत करने का कष्ट करें।

संलग्नक:- यथोपरि।

भवदीय,


(डी०जे०के० शर्मा) 19/5/24

प्रमुख वन संरक्षक एवं
नोडल अधिकारी, वन संरक्षण,
उत्तराखण्ड, देहरादून।

प्रतिलिपि:- निम्नलिखित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित।

1. वन संरक्षक, उत्तरी कुमाऊँ वृत्त, अल्मोड़ा।
2. प्रभागीय वनाधिकारी, पिथौरागढ़ वन प्रभाग, पिथौरागढ़।



(डी०जे०के० शर्मा)

प्रमुख वन संरक्षक एवं
नोडल अधिकारी, वन संरक्षण,
उत्तराखण्ड, देहरादून।