

I/319641/2023

**GOVERNMENT OF ASSAM**  
**ENVIRONMENT AND FOREST DEPARTMENT**  
**JANATA BHAWAN, DISPUR, GUWAHATI-6**

eCF No.358347/95

Dated Dispur, the    October, 2023

From : Smti. Neera Daulagupu, ACS,  
 Secretary to the Govt. of Assam,  
 Environment and Forest Department.

To : The Deputy Director General of Forests (C),  
 Government of India,  
 Ministry of Environment, Forest & Climate Change,  
 Sub office, Guwahati,  
 4<sup>th</sup> Floor, Housefed Building,  
 G.S Road, Rukminigaon, Guwahati-781022

Sub : Proposal for diversion of 2.1249 ha forest land for  
 construction 132 KV single circuit transmission line double circuit  
 tower from 220 KV Salakati GSS to 132 KV APM GSS in Bhairab Hill  
 PRF under Aie Valley Division, Bongaigaon by AEGCL -reg.

Ref : Government of India letter No. 3-AS B/120/2022/GHY/4466-  
 67 dated 04.09.2023.

Sir,

In inviting reference to your letter on the subject cited above, I am directed to furnish herewith the following additional information/document as sought vide letter under reference for favour of your kind information and necessary action: -

<b>Govt. of India letter No.3-AS B/120/2022/GHY/4466- 67 dated 04.09.2023</b>	<b>Information Provided</b>
Condition No. (1)	The User Agency (AEGCL) has submitted the original colour SoI map indicating the 3-alternate route with proper legend vide letter No. AEGCL/AGM/DLG/T-60/2023/1490 dated 12.10.2023 ( <b>copy enclosed</b> )
Condition No. (2)	The User Agency (AEGCL) has submitted the justification on 3-alternate route in the forest area including the propose area mentioning the ecological perimeters vide letter No. AEGCL/AGM/DLG/T-60/2023/1490 dated 12.10.2023 ( <b>copy enclosed</b> )

I/319641/2023

Condition No. (3)	The User Agency (AEGCL) has submitted the ROW permission vide letter No. AEGCL/AGM/DLG/T-60/2023/1490 dated 12.10.2023 ( <b>copy enclosed</b> )
-------------------	---

Enclo : As stated above.

Yours faithfully,

Signed by

Neera Daulagupu

Secretary to the Govt. of Assam  
Date: 27-10-2023 15:54:58  
Environment and Forest Department

Memo eCF No.358347/95 -A Dated Dispur, the October, 2023  
Copy to:-

The Principal Chief Conservator of Forests & HoFF, Assam,  
Panjabari, Guwahati-37.

e-signed  
Secretary to the Govt. of Assam  
Environment and Forest Department

**GOVERNMENT OF ASSAM**  
**OFFICE OF THE PRINCIPAL CHIEF CONSERVATOR OF FORESTS AND**  
**HEAD OF FOREST FORCE, ASSAM**  
**ARANYA BHAWAN, PANJABARI, GUWAHATI-37**

Email: [adtlpccf.nodal@gmail.com](mailto:adtlpccf.nodal@gmail.com)

No. FG.27/FCA/Proposal/Salakati Trans Line/AEGCL

Dated 17.10.2023

To,

✓ The Additional Chief Secretary to the Government of Assam,  
Environment and Forest Department, Dispur, Guwahati-6.

**Sub: Proposal for diversion of 2.1249 Ha. of forest land for construction of 132 KV single circuit transmission line double circuit tower from 220 KV Salakati GSS to 132 KV APM GSS in Bhairab Hill PRF under Aie Valley Division, Bongaigaon by AEGCL.**

Ref: Government of India letter No. 3-AS B/120/2022/GHY/4466-67 dated 4.9.2023

Sir,

With reference to the above, I am submitting herewith the additional information/documents as sought by the Government of India, MoEF &CC, Sub Office, Guwahati vide their letter No. 3-AS B/120/2022/GHY/4466-67 dated 4.9.2023 as under-

Govt. of India letter No 3-AS B/120/2022/ GHY/4466-67 dated 4.9.2023	Information Provided
Condition No. (1)	The User Agency (AEGCL) has submitted the original colour Sol map indicating the 3-alternate route with proper legend vide letter No. AEGCL/AGM/DLG/T-60/2023/1490 dated 12.10.2023 (copy enclosed)
Condition No. (2)	The User Agency (AEGCL) has submitted the justification on 3-alternate route in the forest area including the proposed area mentioning the ecological perimeters vide letter No. AEGCL/AGM/DLG/T-60/2023/1490 dated 12.10.2023 (copy enclosed)
Condition No. (3)	The User Agency (AEGCL) has submitted the ROW permission vide letter No. AEGCL/AGM/DLG/T-60/2023/1490 dated 12.10.2023 (copy enclosed)

The above-mentioned information may kindly be sent to the Government of India, MoEF&CC, Sub Office, Guwahati (Under Regional Office, Shillong), Guwahati accordingly.

Encl: As stated above.

Yours faithfully,

(Dr. C Muthukumaravel, IFS)

Chief Conservator of Forests &  
Nodal Officer (FC Act), Assam

O/o the Principal Chief Conservator of Forests and  
Head of Forest Force, Assam

SO (SC)  
19/10/23

SB  
20/10/23

Copy to:

1. The Divisional Forest Officer, Aie Valley Division, Bongaigaon for information.
2. The AGM, Assam Electricity Grid Corporation Ltd., 132 KV Grid Substation, Dhaligaon, Chirang-783385 for information.

/

Chief Conservator of Forests &  
Nodal Officer (FC Act), Assam  
O/o the Principal Chief Conservator of Forests and  
Head of Forest Force, Assam



GOVT OF ASSAM  
OFFICE OF THE DIVISIONAL FOREST OFFICER:::AIE VALLEY DIVISION  
BONGAIGAON

Ph. No-03664-295166

E-mail-dfo.t.aievalley@gmail.com

No. A/AVD/132KV/2023/ 2560-61

Date: 18/10/23

To,

The Chief Conservator of Forests &  
Nodal Officer (FC Act.), Assam  
O/o the Principal Chief Conservator of Forest  
& Head Of Forest Force, Assam,  
Panjabari, Guwahati-37

Sub:- Proposal for diversion of 2.1249 Ha. of forest land for construction of 132 KV single circuit transmission line double circuit tower form 220 KV Salakati GSS to 132 KV APM in Bhairab Hill PRF under Aie Valley Division, Bongaigaon by AEGCL.

Ref:- Your letter no. FG.FCA/Proposal/Salakati Trans Line/AEGCL, dated 19/09/2023. - 8.52<sup>c</sup>


Sir,

With reference to the above, I have the honour to re-submit the information / documents as per point wise submitted by Asstt. General Manager, 132 KV Assam 132 KV Grid Sub-Station AEGCL, Dhaligaon vide his letter no. AEGCL/AGM/DLG/T-60/2023/1490, dated 12/10/2023 in respect of forest diversion of 2.1249 Ha. of forest land for construction of 132 KV single circuit transmission line double circuit tower form 220 KV Salakati GSS to 132 KV APM in Bhairab Hill PRF under Aie Valley Division, Bongaigaon by AEGCL.


This is for favour of your kind information and necessary action.

Encl: i) 3 sets of Annexure-I and Annexure-II  
ii) ROW permission

Yours faithfully

  
Divisional Forest Officer  
Aie Valley Division  
Bongaigaon


Copy to the Conservator of Forest, Lower Assam Social Forestry Circle, Bongaigaon for favour of his kind information.

  
Divisional Forest Officer  
Aie Valley Division  
Bongaigaon

No. B/AVD/132KV/2023/

Date:

Copy to the AGM, Assam 132 KV Grid Sub-Station AEGCL, Dhaligaon for information.

  
Divisional Forest Officer  
Aie Valley Division  
Bongaigaon





# ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd Office: 1<sup>st</sup> Floor, AEGCL, BijuleeBhawan, Paltan Bazar, Guwahati-01

CIN:U4010AS2003SGC007238

Phone- 0361-2739520/Fax: 0361-2739513: Website: [www.aegcl.co.in](http://www.aegcl.co.in)

65  
Rgh

No: AEGCL/AGM/DLG/T-60/2023/1158

Dated: 12/10/23

To

The Divisional Forest Officer  
AIE Valley Division  
Bongaigaon, Assam

Sub: Submission of scanned copy of SOI map indicating the 3-alternate route of the proposed transmission line along with justification of selecting the proposed route.

Ref: 1) AEGCL/AGM/DLG/T-60/2023/1158; dtd.31.05.2023.  
2) AEGCL/AGM/DLG/T-60/2023/1235; dtd.10.07.2023.

Sir,

With reference to the above, the undersigned would like to submit herewith 3 scanned copies of SOI map (Ann-I) indicating the 3-alternate route of the proposed transmission line along with justification of selecting the proposed route (Ann-II). The Row permission is also enclosed herewith for your ready reference. Thanking you.

Encl: 1) 3 sets of Annexure-I and Annexure-II  
2) ROW permission.


Yours faithfully

(S. Biswas)  
Assistant General Manager  
132 kV Grid Substation Division,  
AEGCL, Dhaligaon.

Memo No: AEGCL/AGM/DLG/T-60/2023/1158  
Copy to,

Dated: 12/10/23

1. The Deputy General Manager, Bongaigaon T&T Circle, Dhaligaon for favor of information.



Assistant General Manager  
132 kV Grid Substation Division,  
AEGCL, Dhaligaon.

OFFICE OF THE ASSTT GENERAL MANAGER, SUB-STATION DIVISION

P.O.- Dhaligaon, Dist Chirang, Assam-783385; Phone No.03664-241223 (CR), 03664-241278 (off),  
Fax No. 03664-241223; Email Id:agm.dhaligaon@aegcl.co.in





**Justification for choosing the Proposed Route for the Transmission Line**

Alternative Route	Total Length (Km)	Total Forest Area Covered(Km)	Name of the Resreve Forest	Type of Forest	Habitation
Route I (Final Route Marked in Magenta)	42.767	1.658	Nadangiri Hilly RF & Bhairab PRF	Resreve Forest	Nil
Alternative Route II (Marked in Blue)	50.065	5.0	Bhumeshwar Hill RF & Nakati RF	Reserve Forest	Nil
Alternative Route III (Marked in Green)	48.669	13.48	Nadangiri Hilly RF(1.0 Km), Chakrasila RF(5.150 Km), Shrigram RF(3.1 Km) & Bhairab PRF(4.230 Km)	Reserve Forest	Present

The transmission line handled by two Divisions of AEGCL separately. Both the divisions manages half part of the total length of the line i.e., 42.767Km. It can be seen from the above table, comparing all three alternative route, the minimum forest area is covered by Route I. Out of 1.658 Km area covered under forest land, Dhaligaon Division Handles 0.939 Km of Forest land of Bhairab PRF for which, forest clearance has been obtained.

Moreover, all the parameters such as total forest covered, name of the forest, type of forest, habitation has been mentioned clearly in the above table.

  
 24/11/22  
 Junior Manager  
 S/S Maintenance  
 MSD, AEGCL, Dhaligaon

  
 24/11/22  
 Assistant Manager  
 Maintenance Sub-Division  
 AEGCL, Dhaligaon



- vii. Crossings of communication lines should be minimum and should be preferably at right angles. Proximity and parallelism with telecommunication lines should be eliminated to avoid danger of induction between them.
- viii. Areas subject to flooding such as nalah should be avoided.
- ix. Restricted areas such as civil and military airfields should be avoided including aircraft landing approaches.
- x. All alignments should be easily approachable in dry and rainy seasons to enable maintenance throughout the year.
- xi. Areas that will present the problems of "Right of Way" and "Way Leave" during construction and maintenance should be avoided.
- xii. Routing of transmission lines through protected/reserved forest area should be avoided/restricted as far as possible
- xiii. Effort should be made to keep the route at a distance from mining areas.

#### **RECONNAISSANCE REPORT FOR THREE ALTERNATIVES ALONG WITH BEE LINE:-**

In course of our preliminary survey apart from the Bee Line with three alternative routes were considered which marked in Black, Magenta, Blue & Green have been indicated in the attached Topographical maps for final selection before detail survey of the selection route is undertaken by us. Please note that those routes indicated in the attached maps are tentative. Comparative details with respect to the above routes with their merits and demerits are indicated below for kind perusal and approval of the selected route.

#### **(A) BEE LINE (Marked in Black).**

From the enclosed map it may please be observed that the 'BEE' line is the straight line connecting the BTPS Sub Station and the APM Sub Station. Length of the BEE Line is about 28.80 KM. This 'BEE' route in comparison to the other investigated routes is shorter. However, the aforesaid route is not a practical proposition for the following reasons: -

- 1) BEE Line passes through near about 5km (Nadangiri R.F and Bhayrab R.F) Reserved forest land area
- 2) This line also passes through Village area near Talguri, Bangalpara, Dholmara, Sidaguri, Balapara etc.
- 3) The crossing point of NH-31 & Proposed Railway is not suitable for tower location.

PROPOSED 132 KV D/C TRANSMISSION  
LINE FROM BTPS TO APM (JOGIDHOPA).

SUBMITTED BY: - G B CONSTRUCTION

*Swi*



- 4) BEE line crossing 132KV S/C BTPS - Dhaligaon Tr. Line two times near BTPS S/S which is not possible.
- 5) This route passes through Dalni Bill area near about 2Km, that bill is a permanent water lodged area, so there was 6 nos. Pile foundation required.
- 6) This route passes maximum altitude area, so there was benching or leg extension proposal required.

Finding the 'BEE' line route not feasible, we have explored alternative routes in close proximity to the said 'BEE' line.

**(B) FINAL ROUTE (Marked in Magenta)(Proposed).**

The Length of the final route (Proposed) is 42.767KM (approx). This route passes through the villages, Salakati, Rasalpara, Banduguri, Dholmara, Bagutamari, Shilkatari, Tamulbajan, Nankuras, Singimari, Durgamari, Bamitila, Dhuntala, Pochhagaon, salbar, Radrapara, Mechpara, Kathalguri, Naldubi, Kharbazar, Barapukhuri, Bonagaon, Chakom, Kumarkata, Barbhola, Dhadaumar, Putipara, Palital and Jogidhopa. The Line passes through unavoidable Reserve Forest Nadangiri Hilly RF & Bhairab R.F land near about 1.658Km.

**(C) ALTERNATIVE-II (Marked in Blue).**

The Length of the final route (Proposed) is 50.086KM (approx). This route passes through the villages, Salakati, Rasalpara, Banduguri, Dholgaon, Naitamara, Tilapara, Bijaygaon, Duramart, Bhadargaon, Kujia, Bidyapur, Chengmari, Majhigaon, Ujanpara, Dholagaon, Dekamari, Tilapara, Laidhapara, Jcgipara, Barkhata, Nalbari, Saopara, Naidubi, Khuramari, Pknnapara, Kerkhabari, Uttar Kerkhabari, Simlaguri, Besimai, Haripani, Chaiantapara, Khuclamari and Jogidhopa. The Line passes through Bhumeswar Hill Reserve Forest (4.000Km approx) and Nakat Reserved forest (1.000Km. approx).

**(D) ALTERNATIVE-III (Marked in Green).**

The Length of the final route (Proposed) is 48.669KM (approx). This route passes through the villages, Salakati, Dogra para, Kathalguri, Nadangiri, Chhagalkhuti, Pundibari, Mourigaon, Dabargaon, Anujuli, Malsingpara, Chokrasila, Alubhul, Suksuka, Areyarjhar, Bataldal, Bhokatpara, Kurshakati, Hordemari, Jalikura, Balajani, Dampara, Kherpuji, Beltali, Pellital, Bharali Kundi & APM Colony. The Line passes through Nadangiri Hill Reserve Forest (1.00Km approx), Chakrasila Reserved forest (5.150Km. approx), Shrigam Reserve Forest (3.100Km approx) & Bhairabi Reserved forest (4.230Km. approx).

PROPOSED 132 KV D/C TRANSMISSION  
LINE FROM BTPS TO APM (JOGIDHOPA).

SUBMITTED BY: - G B CONSTRUCTION

*Sqm*



## COMPARATIVE STATEMENTS AT A GLANCE

1.0 The comparative features of alternatives for selecting the optimum route are as under:

Description	Final Route (Marked in magenta)	Alternative-II. (Marked in blue)	Alternative-III. (Marked in green)
Route Length (in Kms)	42.767 K.M.	50.086 K.M.	48.669 Km.
Angle Point	99	115	113
River Crossing (Major)	1	1	1
River Crossing (Minor)	Nil	Nil	Nil
Forest (Reserve Forest & Protect Forest)	Kokrajhar Dist.- .719km. & Bongaigaon Dist.- .939km.	5.000Km	13.480 Km.
No. Of Railway Crossing	1	1	1
N.H. Crossing	1	3	Nil
S.H. Crossing	Nil	Nil	Nil
400 KV D/C Line	Nil	Nil	Nil
400 KV S/C Line	Nil	Nil	Nil
220 KV D/C Line	Nil	4	Nil
220 KV S/C Line	Nil	Nil	Nil
132 KV D/C Line	1	1	1
132 KV S/C Line	1	1	1
66 KV Line	Nil	Nil	Nil
No Of Pole Location	1	1	1

PROPOSED 132 KV D/C TRANSMISSION  
LINE FROM BTPS(SALAKAT) TO APM (JOGIGHOPA).

SUBMITTED BY: - G B CONSTRUCTION

*Sani*





**GOVT OF ASSAM**  
**OFFICE OF THE DEPUTY COMMISSIONER:::.....BONGAIGAON**

Tel No. (03664)-230889(O)/230891(R)  
Fax No. (03664)-231338(O)/230490(R)  
E-mail: bongaiga@nic.in  
PIN- 783380

No. BLA. 20/2015/9

Dated, Bongaigaon the 29<sup>th</sup> July'2015


**ORDER**

Whereas the construction of 132 KV BTS, Salakati to Jogighopa, APM Line Salakati Grid Sub-Section to the proposed Bongaigaon District 132 KV Sub-Section at Bongaigaon District requested to accord "Right of Way" permission for carrying out survey and construction of the said transmission line under TDF Scheme.

Now, therefore, Sri Biswajit Pegu, IAS, Deputy Commissioner, Bongaigaon in exercise of the power conferred on me under the provision laid down in the Indian Electricity Act 2003, do hereby allow Assam Electricity Grid Corporation Limited to carry out necessary construction works of the proposed transmission alignment on observing usual formalities in areas falling under Bongaigaon District.

It is further stipulated that the AEGCL will pay reasonable compensation to land owners for any damage of land, their crops, Zirat, House and other properties while doing the survey and construction works.


Given under my hand and seal today the 20<sup>th</sup> July' 2015.


  
Deputy Commissioner,  
Bongaigaon.

Memo No. 20/2015/9 -A  
Copy to:

Dated, Bongaigaon the 29<sup>th</sup> July'2015

1. The Commissioner & Secretary to the Govt of Assam, Revenue & DM (LR) Deptt for favour of information.
2. The Senior manager, 132 KV Salakati Grid Sub-Section, AEGCL for information.
3. The SDO(C), North Salmara/ Bijnai for information.
4. The Circle Officer, Bongaigaon /Boltamari/Srijangram/ Dantol /Bijnai Rev. Circle for information.
5. Office order file

  
Deputy Commissioner,  
Bongaigaon

92-11  
8-2015  






# ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd Office: 1<sup>st</sup> Floor, AEGCL, Bijulee Bhawan, Paltan Bazar, Guwahati-01  
CIN:U4010AS20035GC007233

Phone- 0361-2739520/Fax: 0361-2739513; Website: [www.aegcl.co.in](http://www.aegcl.co.in)

Dated: 31.05.2022

No: AEGCL/AGM/DLG/T-60/2023/ 1158

To

The Divisional Forest Officer  
AIE Valley Division  
Bongaigaon, Assam

Sub: Submission of queries raised against forest diversion proposal of 2.1249Ha forest and for 132kV S/C transmission line of D/C tower from 220kV Salakati GSS to 132kV APM GSS in Bhaibrab Hill PRF under Aie Valley Division.

Ref: 1) AEGCL/DGM/Bong/T&T circle/T-45/2023/96; dtd. 25/05/2022.  
2) AEGCL/MD/TL-87/Pt-IV/Pt/06; dtd. 22.05.2023.  
3) B/AVD/132kV/2022/3043; dtd. 18/08/2022.  
4) Letter No. 3-AS B 120/2022-GHY/2820—2821; dtd. 29/07/2022, Govt. of India

Sir,

With reference to the above, responses against the queries raised from your end vide letter under ref (3) & (4) is provided below:

Sl. No.	Queries Raised	Response
1	Query No. ii)	Scanned copy of SOI indicating 3-alternate route of the proposed transmission line (Ann-I) is attached herewith. Also, justification of selecting the proposed route is enclosed at annexure-II.
2	Query No. iii)	No, court case/ violation of F(C) Act, 1980 involved in the proposed area is known to the undersigned.
3	Query No. iv)	Undertaking attached herewith (Ann-III)
4	Query No. v)	ROW permission is enclosed herewith.

Regarding Query No. i), the undersigned would like to inform you that AEGCL does not hold the expertise in preparation of Golden Langur conservation and wildlife mitigation plan to be approved by CWLW. As such, you are requested to kindly provide your expert assistance in this regard. It may be noted that, cost of consultancy etc. in this regard shall be borne by AEGCL. Thanking You.

Encls: 1) Letter under reference (1), (2), & (4)  
2) Annexure-I, II, III  
3) ROW permission.

Yours faithfully

(S. Biswas)

Assistant General Manager  
132 kV Grid Substation Division,  
AEGCL, Dhaligaon.

Dated: 31.05.2022

Memo No: AEGCL/AGM/DLG/T-60/2023/ 1158(a-e)

Copy to,


1. The Chief General Manager (PP&D), AEGCL, Bijulee Bhawan, Paltan Bazar, Ghy-01 for favor of information.
2. The General Manager, LA T&T Zone, AEGCL, Narengi, Ghy-26 for favor of information.
3. The Deputy General Manager, Bongaigaon T&T Circle, Dhaligaon for favor of information.

Assistant General Manager  
132 kV Grid Substation Division,  
AEGCL, Dhaligaon.

OFFICE OF THE ASSTT GENERAL MANAGER, SUB-STATION DIVISION

P.O.- Dhaligaon, Dist Chirang, Assam-783385; Phone No.03664-241223 (CR), 03664-241278 (off),  
Fax No. 03664-241223; Email Id: agm.dhaligaon@aegcl.co.in






सत्यमेव जयते

INDIA NON JUDICIAL

Government of Assam

e-Stamp

Certificate No. : IN-AS42845719514966V  
 Certificate Issued Date : 08-Jun-2023 01:59 PM  
 Account Reference : CSCACC (GV)/ ascscceg07/ AS-CGGOL0026/ AS-CG  
 Unique Doc. Reference : SUBIN-ASASCSCCEG0779616032732931V  
 Purchased by : AGM AEGCL DHALIGAON  
 Description of Document : Article 4 Affidavit  
 Property Description : Not Applicable  
 Consideration Price (Rs.) : 0  
 (Zero)  
 First Party : AGM AEGCL DHALIGAON  
 Second Party : Not Applicable  
 Stamp Duty Paid By : AGM AEGCL DHALIGAON  
 Stamp Duty Amount(Rs.) : 100  
 (One Hundred only)



**UNDERTAKING OF PAYMENT FOR EXTRACTION CHARGES**

I Subrata Biswas, AGM, AEGCL, Dhaligaon, hereby undertake to pay the entire amount for extraction charges of tree to be removed from the proposed area of Bhairab Hill as per the scheme prepared by State Government again diversion of 2.1249ha of forest land for Construction of 132kV Transmission Line on D/C Tower from 220kV BTP Salakati GSS to 132kV APM GSS, Jogighopa.

Date:

Place: Dhaligaon

Signature of User Agency

Office Seal:

0001512670

**Statutory Alert:**

1. The authenticity of this Stamp certificate should be verified at 'www.hclicstamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.





# ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd Office: 1<sup>st</sup> Floor, AEGCL, Bijulee Bhawan, Paltan Bazar, Guwahati-01

CIN: U4010AS 2003SGC007238

Phone- 0361-2739520/Fax: 0361-2739513; Website: [www.aegcl.co.in](http://www.aegcl.co.in)

No: AEGCL/AGM/DLG/T-60/2023/

Dated: 10.07.2023

To

The Divisional Forest Officer  
AIE Valley Division  
Bongaigaon, Assam

Sub: Submission of undertaking regarding preparation of Golden langur conservation and wildlife mitigation plan for construction of 132kV S/C transmission line of D/C tower from 220kV Salakati GSS to 132kV APM GSS in Bhairab Hill PRF under Aie Valley Division.

- Ref: 1) AEGCL/AGM/DLG/T-60/2023/1158; dtd. 31.05.2023  
2) AEGCL/DGM/Bong/T&T circle/T-45/2023/96; dtd. 25/05/2023.  
3) B/AVD/132kV/2022/3043; dtd. 18/08/2022.  
4) Letter No. 3-AS B 120/2022-GHY/2820—2821; dtd. 29/07/2022, Govt. of India

Sir,

With reference to the above, the undersigned would like to inform you that the, "Golden Langur conservation and wildlife mitigation plan" will be prepared and submitted in consultation with Forest Department. An undertaking in this regard is enclosed herewith for your kind consideration.

You are therefore requested to kindly consider the same and process the proposal of forest clearance of phase-I. Thanking You.

Encl: Undertaking.

Yours faithfully

(S. Biswas)

Assistant General Manager  
132 kV Grid Substation Division,  
AEGCL, Dhaligaon.

Memo No: AEGCL/AGM/DLG/T-60/2023/ 1235 (2nd)

Dated: 10.07.2023

Copy to,

1. The Chief General Manager (PP&D), AEGCL, Bijulee Bhawan, Paltan Bazar, Ghy-01 for favor of information.
2. The Chief General Manager (O&M), LAR, AEGCL, Bijulee Bhawan, Paltan Bazar, Ghy-01 for favor of information.
3. The General Manager, LA T&T Zone, AEGCL, Narengi, Ghy-26 for favor of information.
4. The Deputy General Manager, Bongaigaon T&T Circle, Dhaligaon for favor of information.

Assistant General Manager  
132 kV Grid Substation Division,  
AEGCL, Dhaligaon.








सत्यमेव जयते

INDIA NON JUDICIAL

Government of Assam

e-Stamp

Certificate No. : IN-AS45858424594091V  
 Certificate Issued Date : 07-Jul-2023 12:36 PM  
 Account Reference : CSCACC (GV)/ ascscceg07/ AS-CGGOL0026/ AS-CG  
 Unique Doc. Reference : SUBIN-ASASC'SCEG0785400960181140V  
 Purchased by : AGM AEGCL DHALIGAON  
 Description of Document : Article 4 Affidavit  
 Property Description : Not Applicable  
 Consideration Price (Rs.) : 0  
 (Zero)  
 First Party : AGM AEGCL DHALIGAON  
 Second Party : Not Applicable  
 Stamp Duty Paid By : AGM AEGCL DHALIGAON  
 Stamp Duty Amount(Rs.) : 100  
 (One Hundred only)



Please write or type below this line

**UNDERTAKING FOR SUBMISSION OF GOLDEN LANGUR CONSERVATION AND  
WILDLIFE MITIGATION PLAN**

I, Subrata Biswas, AGM, AEGCL, Dhaligaon, hereby undertake that the "Golden Langur conservation and wildlife mitigation plan" for diversion of 2.149Ha of forest land for construction of 132kV Transmission Line on D/C Tower from 220kV Salakati GSS to 132kV APM GSS, Jogighopa in Bhairab PRF under Aie Valley Division will be prepared in consultation with Forest & Wildlife Dept. and shall be submitted to the Forest Department. The cost involvement in this regard, as per the statutory guidelines of the MoEFCC will be deposited in due course.

Date:

Place: Dhaligaon

Signature of User Agency

Office Seal: Subrata Biswas  
132 KV Grid Sub-Station Division  
AEGCL, Dhaligaon  
0001513456

**Statutory Alert:**

1. The authenticity of this Stamp certificate should be verified at 'www.cholastamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.



