

संघ शासित प्रदेश दादरा एवं नगर हवेली प्रशासन,  
ADMINISTRATION OF DADRA AND NAGAR HAVELI (U.T.),  
वन संरक्षक (प्रादेशिक) का कार्यालय,  
OFFICE OF THE DEPUTY CONSERVATOR OF FORESTS (TERRITORIAL),  
सिलवासा, SILVASSA.

सं.7-5/3-FD/606/272

दिनांक: 08<sup>th</sup> February, 2018.

To,

The Executive Engineer (Distrib.)  
DNH Power Distribution Corp. Ltd.,  
Dadra and Nagar Haveli,  
Silvassa.

Sub: **Diversion of 0.48 Ha of Erection of 100 KVA Transformer Centre with 11 KV HT Line Sindoni - Loharmal for release of water supply scheme** - reg.,

Ref: This office letter No: 7-5/3-FD/606/202 dated 30/01/2018

Sir,

In continuation of the joint field inspection carried out for the above mentioned subject, it is to inform that the proposal is not in accordance with the circulars issued by the Ministry of Environment, Forest and Climate Change in this regard. The width of the proposal for 11 KV should be 7 metre.

Hence, you are kindly requested to modify the proposal as per the Standard.

Yours faithfully,



Deputy Conservator of Forest,  
Territorial, DNH, Silvassa.

Copy to:

1. The Nodal Officer/Chief Conservator of Forests, DD&DNH for kind information please.
2. The Conservator of Forest, DD&DNH for kind information please.