

I/41282/2023



75
आज़ादी का
अमृत महोत्सव

भारत सरकार / GOVERNMENT OF INDIA
एकीकृत क्षेत्रीय कार्यालय
Integrated Regional Office
पर्यावरण, वन और जलवायु परिवर्तन मंत्रालय
Ministry of Environment, Forest and Climate Change
सी.जी.ओ. कॉम्प्लेक्स, शिवालिक खण्ड, लॉंगवुड
CGO Complex, Shivalik Khand, Longwood
शिमला, हिमाचल प्रदेश - 171001
Shimla, Himachal Pradesh - 171001



ईमेल/Email : iro.shimla-mefcc@gov.in
दूरभाष/Tel.: 0177.2658285, 0177.2652541
फैक्स/Fax: 0177.2657517



21.04.2023

सेवा में,

अतिरिक्त मुख्य सचिव (वन)

हिमाचल प्रदेश सरकार

आर्म्सडेल बिल्डिंग, शिमला।

(E-mail: forestsecy-hp@nic.in)

विषय: Diversion of 0.7995 ha. of forest land for the construction of Sajla SHEP 2.00 MW located near Khakhnal Village of Tehsil Manali in Distt. Kullu (HP) within the jurisdiction of Kullu Forest Division, District Kullu, H.P. (Online Proposal No. FP/HP/HYD/150023/2021).-reg.

सन्दर्भ: ऑनलाइन प्राप्त प्रस्ताव संख्या FP/HP/HYD/150023/2021, दिनांक 30.01.2023.

महोदय,

उपरोक्त विषय पर संदर्भित पत्र का आशय ग्रहण करते हुए सूचित करना है कि प्रस्ताव में निम्नलिखित कमियां पाई गई हैं। अतः राज्य सरकार निम्न बिंदुओं पर आवश्यक सूचनाएं प्रेषित करने का कष्ट करें, ताकि अग्रिम कार्यवाही सुनिश्चित की जा सके :-

1. It has been observed from KML file that legends are not marked. Therefore proper KML file with legends as well as components is required to be uploaded.
2. Dimensions of some of the components mentioned in Layout Plan like approach road, tail race etc. are not matching with dimensions mentioned in component wise break-up. Therefore, revised Layout Plan with correct dimensions of components is required to be submitted.
3. Transmission Line component is not marked in KML file. Same is required to be marked.
4. TEC and IA are not provided and undertaking of TEC and IA is also not found uploaded in downloadable form.
5. FRA Certificate is not provided. Therefore, FRA Certificate with all prescribed annexures including all records of consultation and meetings with Gram Sabha and FRC of concerned villages may be submitted.
6. 05 number of trees are proposed for felling in the proposal. State Government may explore the possibilities to reduce the felling number to zero. Additionally, a list of trees which are to be retained and to be felled may be provided.
7. As per DSS analysis, proposed diversion area is found "Inviolable" due to presence of Very Dense Forest in 01 sq. km area. Therefore, density of proposed diversion area may be reviewed and rectified accordingly.
8. Small HEPs are not covered under the purview of EIA, 2006. Therefore, State Government may provide comments in terms of mitigation measures to counter the adverse effects due to the construction of project. Additionally, Soil and Moisture Conservation Plan along with detailed

I/41282/2023

- cost of its implementation in CAMPA as per Ministry's direction vide letter dated 07.06.2022 may be submitted.
9. Proposed project is located at an altitude of 2250 meters and there may be the possibility of presence of important Wild Life. Therefore, Wild Life Management Plan along with detailed cost of its implementation in CAMPA as per Ministry's direction vide letter dated 07.06.2022 may be submitted.
 10. All the dumping sites are proposed in forest land. Therefore, suitable non-forest land for dumping of muck may be explored. Additionally a list of trees in standing in dumping sites may be provided, if forest land is required for dumping sites.
 11. As per MoEF&CC directions given on 13.05.2022 for all Hydel projects of Himachal Pradesh, following documents may be provided:
 - i. A detailed list of approved/existing/proposed projects in the landscape showing generation capacity, Evacuation detail, Transmission Plan along with impacts of these projects on the ecology of the area may be provided.
 - ii. A KML file and Geo-referenced map showing boundaries of nearest Protected Area and their Eco-Sensitive Zone and the distance of each of these HEP from nearest Protected Areas and their ESZ may be provided.
 - iii. Approved capacity of the river/rivulet in terms of Hydro-Electricity generation potential may be provided.
 - iv. The status of River Basin Study of Beas River along with carrying capacity of the Beas River in terms of power generation, how much is harnessed so far and how much is yet to be harnessed by the State may be provided.
 12. Approved Power Evacuation Plan is not uploaded in Part-I. Same may be provided along with the detail of Transmission Line like RoW, transmission capacity, underground or overhead, length and width etc.
 13. Revenue maps (Tatima etc.) of Diversion area are required to be uploaded in Part-II.

भवदीय,

हो/-

(सत्य प्रकाश नेगी)

क्षेत्रीय अधिकारी

प्रतिलिपि सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित:

- 1- नोडल अधिकारी-सह-अतिरिक्त प्रधान मुख्य अरण्यपाल (एफ.सी.ए.), हिमाचल प्रदेश सरकार, वन विभाग टालैंड, शिमला, (E-mail: nodalcahp@yahoo.com).
- 2- वन मण्डल अधिकारी, कुल्लू वन मण्डल, जिला कुल्लू, हिमाचल प्रदेश (E-mail dfokul-hp@nic.in).