

No.Ft.48-3907/2019 (FCA)


EDS on Proposal No.FP/HP/HYD/39107/2019 Dated

21 JUL 2020

Diversion of 0.56 ha of forest land in favour of Bhup Raj, 162/9 Bhojnagar Bazar Sundernagar, Distt Mandi, HP for the construction of Dhanwan Small HEP (1.00 MW), within the jurisdiction of Mandi Forest Division distt Mandi, HP.

The following points are to be attended.

1. In reply to point No. the total command area has still been mentioned. Only the installed power generation capacity is to be mentioned against column No.M(i) and against column No.M(ii), the total command area is required to be deleted.
2. In reply to point No.7, a document showing the width of 33 KV Tr. Line as 72 mtrs has been supplied and total length of the proposed Tr. Line has not been mentioned. As per GoI guidelines, for 33 KV Tr. Line, only 15 mtrs Row (width) is required. Further the length of the proposed Tr. Line is also required to be mentioned in the requisite document.


Divisional Forest Officer(FCA)
O/O Nodal Officer-cum-APCCF(FCA)