

भारत सरकार  
पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय  
एकीकृत क्षेत्रीय कार्यालय, देहरादून  
25 सुभाष रोड, देहरादून-248001  
दूरभाष: 0135-2650809  
फैक्स-0135-2653010  
ईमेल- [moef.ddn@gov.in](mailto:moef.ddn@gov.in)



GOVERNMENT OF INDIA  
MINISTRY OF ENVIRONMENT, FOREST &  
CLIMATE CHANGE  
INTEGRATED REGIONAL OFFICE, DEHRADUN  
25 SUBASH ROAD, DEHRADUN-248001  
PHONE- 0135-2650809  
FAX- 0135-2653010  
Email- [moef.ddn@gov.in](mailto:moef.ddn@gov.in)

फाईल संख्या 8बी./यू.सी.पी./04/65/2022/एफ0 सी0/070

दिनांक: 23/09/2022

सेवा में,

✓ अपर प्रमुख वन संरक्षक एवं नोडल अधिकारी  
वन संरक्षण, इन्दिरानगर फॉरेस्ट कालोनी,  
उत्तराखण्ड, देहरादून।

विषय:- जनपद- टिहरी गढ़वाल के विधानसभा नरेन्द्रनगर के अन्तर्गत 126 कि०मी० ऋषिकेश-कर्णप्रयाग नई ब्रॉड गेज रेल मार्ग को विद्युत लाईन का गुल्लर सबस्टेशन से शिवपुरी टनल-टी-02 के निर्माण हेतु 1.68 है० वन भूमि का गैर वानिकी कार्यों हेतु उत्तराखण्ड पॉवर कार्पोरेशन लि० टिहरी गढ़वाल को प्रत्यावर्तन। (Online No. FP/UK/TRANS/154613/2022)

सन्दर्भ:-कार्यालय-अपर प्रमुख वन संरक्षक एवं नोडल अधिकारी, वन संरक्षण, उत्तराखण्ड का पत्रांक – 467 / FP/UK/ TRANS/154613/2022 दिनांक 18-08-2022

महोदय,


उपर्युक्त प्रस्ताव पर ध्यानपूर्वक विचार करने के उपरान्त मुझे आपको यह सूचित करने का निर्देश हुआ है कि प्रस्ताव में निम्नलिखित त्रुटियाँ पाई गयी। राज्य सरकार निम्नलिखित बिन्दुओं पर आवश्यक सूचनायें प्रेषित करने का कष्ट करें, ताकि अग्रिम कार्यवाही सुनिश्चित की जा सके:-

1. The reason for not including this proposal in the initial original proposal shall be submitted.
2. Details of all the components i.e. tower shall be mentioned at para B 2.4 in part I.
3. Date shall be mentioned on the proceedings of the SDLC meeting.
4. Proceedings of Village Level Committee (VLC) meeting of village 'Gular' are not uploaded. However, the same could be submitted prior to the Stage-II approval.
5. The total length of the project is 260 meters. The width in forest land required for the project is proposed in the range of 1m to 50m. As per the guidelines, the width of right of way for 33 Kv transmission lines is to be considered as 15 m. Hence, State Govt. is requested to submit the justification for the same and the user agency revise the requirement of width in forest land to a minimum requirement of 15m. The number of trees affected, CA area etc. shall also be revised accordingly and uploaded at designated places.
6. Total 585 trees are proposed to be affected. However, it is mentioned in प्रपत्र-21 that no tree felling shall be involved in the proposal. State Govt. is requested to submit a list of the trees proposed for lopping separately.

7. As per the DSS analysis of CA area, 1 ha area is found to be MDF. DFO shall inspect the area and submit Site Inspection Report & if the area is found suitable for planting 1000 trees a certificate mentioning that 1000 trees per hectare can be accommodated in the said area shall be submitted by the DFO. If not, then the area shall be replaced by some other area suitable for raising CA.
8. Administrative approval is not found uploaded. State govt. is requested to submit the administrative approval of the project.

उपरोक्त त्रुटियों की पूर्तता के उपरांत ही प्रस्ताव पर अग्रिम कार्यवाही की जा सकेगी एवं यदि चाही गई सूचना पत्र जारी होने की तिथि के 60 दिनों के भीतर (अधिकतम 90 दिन) इस कार्यालय में प्राप्त नहीं हुई तो प्रस्ताव को निरस्त किया जा सकता है।

भवदीय,

  
(गजेन्द्र प्रकाश नरवणे) 23.09.22  
सहायक महानिरीक्षक (वन)

प्रतिलिपि सूचनार्थ एवं आवश्यक कार्यवाही हेतु :-

1. अपर मुख्य सचिव (वन), उत्तराखण्ड शासन, सुभाष रोड़, देहरादून।

↑  
(गजेन्द्र प्रकाश नरवणे)  
सहायक महानिरीक्षक (वन)